

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518222

Luminaire Tested: HVL8-8-LD4-2LO-30-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518222
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2LO-30-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 8102.0 lumens
Efficiency: N/A
Efficacy: 87.9 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct


Input Watts (W): 92.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518222

CATALOG NUMBER: HVL8-8-LD4-2LO-30-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518222

CATALOG NUMBER: HVL8-8-LD4-2LO-30-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		87
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		60
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		54
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5408	5408	5408
5°	5408	5294	5292
10°	5381	5206	5187
15°	5345	5107	5059
20°	5305	4996	4936
25°	5256	4881	4810
30°	5199	4759	4667
35°	5124	4623	4526
40°	5046	4481	4361
45°	4963	4325	4183
50°	4852	4143	3991
55°	4734	3944	3780
60°	4592	3684	3533
65°	4352	3391	3289
70°	3998	3045	3005
75°	3487	2666	2747
80°	2706	2295	2511
85°	1560	1922	2286

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 4963 cd/sqm

TEST NUMBER: P518222

CATALOG NUMBER: HVL8-8-LD4-2LO-30-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	253.6	3.1
10°-20°	727.4	9.0
20°-30°	1103.7	13.6
30°-40°	1334.5	16.5
40°-50°	1392.5	17.2
50°-60°	1273.1	15.7
60°-70°	992.5	12.2
70°-80°	620.8	7.7
80°-90°	282.0	3.5
90°-100°	94.5	1.2
100°-110°	23.7	0.3
110°-120°	3.7	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2084.6	25.7
0°-40°	3419.1	42.2
0°-60°	6084.7	75.1
0°-90°	7980.0	98.5
90°-120°	122.0	1.5
90°-150°	122.0	1.5
90°-180°	122.0	1.5
0°-180°	8102.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2680	2680	2680	2680	2680	
5°	2674	2669	2657	2670	2670	254
15°	2572	2577	2570	2584	2584	726
25°	2383	2385	2388	2408	2412	1098
35°	2110	2119	2128	2150	2158	1321
45°	1775	1791	1805	1823	1832	1368
55°	1385	1402	1428	1448	1458	1238
65°	952	968	1002	1042	1058	942
75°	482	512	586	656	681	514
85°	83	154	265	350	381	106
90°	1	58	156	234	263	3
95°	1	15	81	147	169	0
105°	1	2	13	39	52	1
115°	2	2	2	7	10	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518222

CATALOG NUMBER: HVL8-8-LD4-2LO-30-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2679.7	2679.7	2679.7	2679.7	2679.7
2.5°	2682.8	2679.0	2667.0	2679.0	2678.4
5°	2674.0	2668.9	2656.9	2669.5	2669.5
7.5°	2656.3	2654.4	2643.6	2658.2	2658.2
10°	2635.4	2634.8	2626.0	2641.8	2642.4
12.5°	2606.4	2608.9	2600.7	2615.9	2617.7
15°	2572.3	2576.7	2569.7	2584.3	2583.6
17.5°	2535.0	2537.5	2532.5	2548.9	2548.3
20°	2488.9	2492.0	2488.2	2505.3	2507.2
22.5°	2437.7	2442.1	2441.5	2459.2	2464.2
25°	2383.4	2385.3	2387.8	2408.0	2411.8
27.5°	2323.4	2326.5	2331.0	2349.3	2353.1
30°	2257.7	2262.7	2267.8	2286.7	2291.8
32.5°	2188.2	2193.2	2199.6	2224.2	2226.7
35°	2109.9	2119.3	2128.2	2149.7	2158.5
37.5°	2031.5	2043.5	2051.7	2074.5	2081.4
40°	1948.8	1960.8	1974.0	1998.1	2002.5
42.5°	1862.2	1876.1	1891.9	1913.4	1921.0
45°	1775.1	1790.9	1805.4	1823.1	1831.9
47.5°	1680.9	1696.7	1714.4	1734.6	1740.3
50°	1583.7	1602.0	1620.9	1639.9	1650.0
52.5°	1483.9	1506.0	1527.4	1547.7	1557.1
55°	1385.3	1401.7	1427.6	1448.5	1458.0
57.5°	1283.0	1296.9	1320.2	1354.4	1359.4
60°	1178.7	1191.4	1215.4	1243.2	1254.5
62.5°	1063.8	1080.8	1106.1	1141.5	1151.6
65°	952.0	968.4	1001.9	1041.7	1058.1
67.5°	843.9	849.6	892.6	934.3	960.8
70°	716.3	737.8	787.7	838.9	859.1
72.5°	606.4	627.9	682.9	742.9	768.1
75°	482.0	511.7	586.2	656.3	681.0
77.5°	372.7	405.5	497.8	568.5	597.0
80°	260.3	311.4	411.9	491.5	522.4
82.5°	163.6	226.8	334.2	417.6	444.7
85°	83.4	154.1	264.7	350.0	380.9
87.5°	22.1	99.8	205.9	287.4	319.0
90°	0.6	57.5	156.0	234.4	262.8
92.5°	0.6	32.2	116.2	186.4	215.4
95°	0.6	15.2	80.9	146.6	169.3
97.5°	0.6	6.3	55.6	110.5	133.3
100°	0.6	3.2	35.4	80.2	99.8
102.5°	1.3	1.9	22.1	57.5	73.3
105°	1.3	1.9	13.3	39.2	52.4
107.5°	1.3	1.9	7.6	26.5	36.0
110°	1.9	1.9	4.4	16.4	24.0

TEST NUMBER: P518222

CATALOG NUMBER: HVL8-8-LD4-2LO-30-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.9	1.9	2.5	10.7	15.8
115°	1.9	1.9	2.5	6.9	10.1
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)