

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518226

Luminaire Tested: HVL8-8-LD4-2LO-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518226
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2LO-35-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8211.0 lumens
Efficiency: N/A
Efficacy: 89.1 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct

Input Watts (W): 92.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518226
CATALOG NUMBER: HVL8-8-LD4-2LO-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518226

CATALOG NUMBER: HVL8-8-LD4-2LO-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	110	110	110		105	105	105		101
1	108	102	98	94	105	100	96	92	95	92	89		91	88	86		87
2	98	89	82	76	95	87	80	75	83	77	73		79	75	71		76
3	89	78	69	63	86	76	68	62	73	66	61		70	64	59		67
4	81	69	60	53	79	67	59	52	65	57	52		62	56	51		60
5	75	61	52	45	72	60	52	45	58	50	44		56	49	44		54
6	69	55	46	40	67	54	46	39	52	45	39		50	44	38		49
7	64	50	41	35	62	49	41	35	47	40	34		46	39	34		44
8	59	46	37	31	58	45	37	31	43	36	31		42	35	30		41
9	55	42	34	28	54	41	33	28	40	33	28		39	32	27		38
10	52	39	31	25	51	38	30	25	37	30	25		36	29	25		35

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5481	5481	5481
5°	5480	5365	5364
10°	5454	5276	5256
15°	5417	5176	5127
20°	5377	5063	5002
25°	5327	4947	4875
30°	5269	4823	4730
35°	5192	4686	4587
40°	5114	4541	4419
45°	5030	4383	4239
50°	4917	4199	4045
55°	4797	3997	3831
60°	4654	3733	3581
65°	4410	3437	3333
70°	4052	3086	3046
75°	3534	2702	2784
80°	2742	2325	2545
85°	1580	1947	2317

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 5030 cd/sqm

TEST NUMBER: P518226

CATALOG NUMBER: HVL8-8-LD4-2LO-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	257.0	3.1
10°-20°	737.2	9.0
20°-30°	1118.5	13.6
30°-40°	1352.5	16.5
40°-50°	1411.2	17.2
50°-60°	1290.3	15.7
60°-70°	1005.8	12.2
70°-80°	629.2	7.7
80°-90°	285.8	3.5
90°-100°	95.8	1.2
100°-110°	24.0	0.3
110°-120°	3.8	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2112.7	25.7
0°-40°	3465.1	42.2
0°-60°	6166.6	75.1
0°-90°	8087.4	98.5
90°-120°	123.6	1.5
90°-150°	123.6	1.5
90°-180°	124.0	1.5
0°-180°	8211.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2716	2716	2716	2716	2716	
5°	2710	2705	2693	2706	2706	257
15°	2607	2611	2604	2619	2618	736
25°	2416	2417	2420	2440	2444	1113
35°	2138	2148	2157	2179	2188	1338
45°	1799	1815	1830	1848	1857	1386
55°	1404	1421	1447	1468	1478	1254
65°	965	981	1015	1056	1072	955
75°	488	519	594	665	690	521
85°	84	156	268	355	386	107
90°	1	58	158	238	266	3
95°	1	15	82	148	172	0
105°	1	2	13	40	53	1
115°	2	2	3	7	10	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518226

CATALOG NUMBER: HVL8-8-LD4-2LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2715.7	2715.7	2715.7	2715.7	2715.7
2.5°	2718.9	2715.1	2702.9	2715.1	2714.4
5°	2709.9	2704.8	2692.7	2705.5	2705.5
7.5°	2692.0	2690.1	2679.2	2693.9	2693.9
10°	2670.9	2670.2	2661.3	2677.3	2677.9
12.5°	2641.4	2644.0	2635.7	2651.0	2653.0
15°	2606.9	2611.4	2604.3	2619.0	2618.4
17.5°	2569.1	2571.7	2566.5	2583.2	2582.5
20°	2522.4	2525.6	2521.7	2539.0	2540.9
22.5°	2470.5	2475.0	2474.3	2492.3	2497.4
25°	2415.5	2417.4	2419.9	2440.4	2444.3
27.5°	2354.6	2357.8	2362.3	2380.9	2384.7
30°	2288.1	2293.2	2298.3	2317.5	2322.6
32.5°	2217.6	2222.8	2229.2	2254.1	2256.7
35°	2138.2	2147.9	2156.8	2178.6	2187.5
37.5°	2058.9	2071.0	2079.4	2102.4	2109.4
40°	1975.0	1987.2	2000.6	2024.9	2029.4
42.5°	1887.3	1901.4	1917.4	1939.1	1946.8
45°	1798.9	1814.9	1829.7	1847.6	1856.6
47.5°	1703.6	1719.6	1737.5	1758.0	1763.7
50°	1605.0	1623.5	1642.7	1661.9	1672.2
52.5°	1503.8	1526.2	1548.0	1568.5	1578.1
55°	1403.9	1420.6	1446.8	1468.0	1477.6
57.5°	1300.2	1314.3	1338.0	1372.6	1377.7
60°	1194.6	1207.4	1231.7	1259.9	1271.4
62.5°	1078.1	1095.4	1121.0	1156.8	1167.1
65°	964.8	981.4	1015.3	1055.7	1072.3
67.5°	855.3	861.1	904.6	946.8	973.7
70°	726.0	747.7	798.3	850.2	870.7
72.5°	614.6	636.4	692.0	752.9	778.5
75°	488.5	518.6	594.1	665.2	690.1
77.5°	377.7	411.0	504.5	576.2	605.0
80°	263.8	315.6	417.4	498.1	529.4
82.5°	165.8	229.8	338.7	423.2	450.7
85°	84.5	156.2	268.2	354.7	386.0
87.5°	22.4	101.2	208.7	291.3	323.3
90°	0.6	58.3	158.1	237.5	266.3
92.5°	0.6	32.6	117.8	188.9	218.3
95°	0.6	15.4	81.9	148.5	171.6
97.5°	0.6	6.4	56.3	112.0	135.1
100°	0.6	3.2	35.9	81.3	101.2
102.5°	1.3	1.9	22.4	58.3	74.3
105°	1.3	1.9	13.4	39.7	53.1
107.5°	1.3	1.9	7.7	26.9	36.5
110°	1.9	1.9	4.5	16.6	24.3

TEST NUMBER: P518226

CATALOG NUMBER: HVL8-8-LD4-2LO-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.9	1.9	2.6	10.9	16.0
115°	1.9	1.9	2.6	7.0	10.2
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)