

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518230

Luminaire Tested: HVL8-8-LD4-2LO-40-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518230
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2LO-40-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 4000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8327.0 lumens
Efficiency: N/A
Efficacy: 90.3 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct

Input Watts (W): 92.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518230
CATALOG NUMBER: HVL8-8-LD4-2LO-40-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518230

CATALOG NUMBER: HVL8-8-LD4-2LO-40-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	5558	5558	5558
5°	5558	5441	5440
10°	5531	5350	5331
15°	5493	5249	5200
20°	5453	5135	5073
25°	5402	5017	4944
30°	5343	4891	4797
35°	5266	4752	4651
40°	5186	4605	4482
45°	5101	4445	4299
50°	4987	4259	4102
55°	4865	4054	3885
60°	4720	3786	3632
65°	4473	3486	3381
70°	4109	3130	3089
75°	3584	2740	2823
80°	2780	2358	2581
85°	1603	1975	2350

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 5101 cd/sqm

TEST NUMBER: P518230

CATALOG NUMBER: HVL8-8-LD4-2LO-40-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	260.6	3.1
10°-20°	747.6	9.0
20°-30°	1134.3	13.6
30°-40°	1371.6	16.5
40°-50°	1431.1	17.2
50°-60°	1308.5	15.7
60°-70°	1020.0	12.2
70°-80°	638.1	7.7
80°-90°	289.8	3.5
90°-100°	97.1	1.2
100°-110°	24.4	0.3
110°-120°	3.8	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2142.5	25.7
0°-40°	3514.1	42.2
0°-60°	6253.7	75.1
0°-90°	8201.7	98.5
90°-120°	125.3	1.5
90°-150°	125.3	1.5
90°-180°	125.0	1.5
0°-180°	8327.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2754	2754	2754	2754	2754	
5°	2748	2743	2731	2744	2744	261
15°	2644	2648	2641	2656	2655	746
25°	2450	2452	2454	2475	2479	1129
35°	2168	2178	2187	2209	2218	1357
45°	1824	1841	1856	1874	1883	1406
55°	1424	1441	1467	1489	1498	1272
65°	978	995	1030	1071	1088	968
75°	495	526	602	675	700	528
85°	86	158	272	360	392	108
90°	1	59	160	241	270	3
95°	1	16	83	151	174	0
105°	1	2	14	40	54	1
115°	2	2	3	7	10	1
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518230

CATALOG NUMBER: HVL8-8-LD4-2LO-40-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2754.1	2754.1	2754.1	2754.1	2754.1
2.5°	2757.3	2753.4	2741.1	2753.4	2752.8
5°	2748.2	2743.0	2730.7	2743.7	2743.7
7.5°	2730.0	2728.1	2717.1	2732.0	2732.0
10°	2708.6	2708.0	2698.9	2715.1	2715.8
12.5°	2678.8	2681.4	2672.9	2688.5	2690.4
15°	2643.7	2648.2	2641.1	2656.0	2655.4
17.5°	2605.4	2608.0	2602.8	2619.7	2619.0
20°	2558.0	2561.2	2557.3	2574.9	2576.8
22.5°	2505.4	2510.0	2509.3	2527.5	2532.7
25°	2449.6	2451.5	2454.1	2474.9	2478.8
27.5°	2387.9	2391.1	2395.7	2414.5	2418.4
30°	2320.4	2325.6	2330.8	2350.2	2355.4
32.5°	2249.0	2254.2	2260.6	2286.0	2288.6
35°	2168.5	2178.2	2187.3	2209.4	2218.4
37.5°	2088.0	2100.3	2108.7	2132.1	2139.2
40°	2002.9	2015.2	2028.9	2053.5	2058.1
42.5°	1914.0	1928.2	1944.5	1966.5	1974.3
45°	1824.4	1840.6	1855.5	1873.7	1882.8
47.5°	1727.6	1743.9	1762.0	1782.8	1788.7
50°	1627.6	1646.5	1665.9	1685.4	1695.8
52.5°	1525.1	1547.8	1569.9	1590.6	1600.4
55°	1423.8	1440.7	1467.3	1488.7	1498.4
57.5°	1318.6	1332.9	1356.9	1392.0	1397.2
60°	1211.5	1224.5	1249.1	1277.7	1289.4
62.5°	1093.3	1110.8	1136.8	1173.2	1183.6
65°	978.4	995.3	1029.7	1070.6	1087.5
67.5°	867.4	873.2	917.4	960.2	987.5
70°	736.2	758.3	809.6	862.2	883.0
72.5°	623.3	645.3	701.8	763.5	789.5
75°	495.4	525.9	602.5	674.6	699.9
77.5°	383.1	416.8	511.6	584.3	613.5
80°	267.5	320.1	423.3	505.1	536.9
82.5°	168.2	233.1	343.4	429.1	457.1
85°	85.7	158.4	272.0	359.7	391.5
87.5°	22.7	102.6	211.7	295.4	327.9
90°	0.6	59.1	160.4	240.9	270.1
92.5°	0.6	33.1	119.5	191.5	221.4
95°	0.6	15.6	83.1	150.6	174.0
97.5°	0.6	6.5	57.1	113.6	137.0
100°	0.6	3.2	36.4	82.5	102.6
102.5°	1.3	1.9	22.7	59.1	75.3
105°	1.3	1.9	13.6	40.3	53.9
107.5°	1.3	1.9	7.8	27.3	37.0
110°	1.9	1.9	4.5	16.9	24.7

TEST NUMBER: P518230

CATALOG NUMBER: HVL8-8-LD4-2LO-40-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	1.9	1.9	2.6	11.0	16.2
115°	1.9	1.9	2.6	7.1	10.4
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)