

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518242

Luminaire Tested: HVL8-8-LD4-2STD-35-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518242
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2STD-35-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 3500K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 10577.0 lumens
Efficiency: N/A
Efficacy: 80.9 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct


Input Watts (W): 130.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518242

CATALOG NUMBER: HVL8-8-LD4-2STD-35-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518242

CATALOG NUMBER: HVL8-8-LD4-2STD-35-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	7060	7060	7060
5°	7059	6911	6909
10°	7025	6796	6771
15°	6977	6667	6605
20°	6926	6522	6443
25°	6862	6372	6279
30°	6787	6213	6093
35°	6689	6036	5908
40°	6588	5850	5693
45°	6479	5646	5460
50°	6334	5409	5210
55°	6180	5149	4935
60°	5995	4809	4613
65°	5681	4427	4294
70°	5220	3976	3923
75°	4552	3480	3586
80°	3532	2995	3278
85°	2037	2509	2985

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6479 cd/sqm

TEST NUMBER: P518242

CATALOG NUMBER: HVL8-8-LD4-2STD-35-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	331.0	3.1
10°-20°	949.6	9.0
20°-30°	1440.8	13.6
30°-40°	1742.2	16.5
40°-50°	1817.8	17.2
50°-60°	1662.0	15.7
60°-70°	1295.7	12.2
70°-80°	810.5	7.7
80°-90°	368.1	3.5
90°-100°	123.4	1.2
100°-110°	31.0	0.3
110°-120°	4.9	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2721.4	25.7
0°-40°	4463.6	42.2
0°-60°	7943.5	75.1
0°-90°	10417.8	98.5
90°-120°	159.2	1.5
90°-150°	159.2	1.5
90°-180°	159.0	1.5
0°-180°	10577.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3498	3498	3498	3498	3498	
5°	3491	3484	3468	3485	3485	332
15°	3358	3364	3355	3374	3373	948
25°	3112	3114	3117	3144	3149	1434
35°	2754	2767	2778	2806	2818	1724
45°	2317	2338	2357	2380	2392	1786
55°	1808	1830	1864	1891	1903	1616
65°	1243	1264	1308	1360	1381	1230
75°	629	668	765	857	889	671
85°	109	201	346	457	497	138
90°	1	75	204	306	343	4
95°	1	20	106	191	221	1
105°	2	2	17	51	68	2
115°	2	2	3	9	13	2
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518242

CATALOG NUMBER: HVL8-8-LD4-2STD-35-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3498.2	3498.2	3498.2	3498.2	3498.2
2.5°	3502.4	3497.4	3481.7	3497.4	3496.6
5°	3490.8	3484.2	3468.5	3485.0	3485.0
7.5°	3467.7	3465.2	3451.2	3470.2	3470.2
10°	3440.5	3439.7	3428.1	3448.8	3449.6
12.5°	3402.6	3405.9	3395.1	3414.9	3417.4
15°	3358.0	3363.8	3354.7	3373.7	3372.9
17.5°	3309.4	3312.7	3306.1	3327.5	3326.7
20°	3249.2	3253.3	3248.4	3270.6	3273.1
22.5°	3182.4	3188.2	3187.3	3210.4	3217.0
25°	3111.5	3113.9	3117.2	3143.6	3148.6
27.5°	3033.1	3037.2	3043.0	3066.9	3071.9
30°	2947.4	2954.0	2960.6	2985.3	2991.9
32.5°	2856.6	2863.2	2871.5	2903.6	2906.9
35°	2754.4	2766.8	2778.3	2806.3	2817.9
37.5°	2652.1	2667.8	2678.5	2708.2	2717.3
40°	2544.1	2559.8	2577.1	2608.4	2614.2
42.5°	2431.1	2449.3	2469.9	2497.9	2507.8
45°	2317.3	2337.9	2356.9	2380.0	2391.5
47.5°	2194.4	2215.1	2238.1	2264.5	2272.0
50°	2067.4	2091.4	2116.1	2140.8	2154.0
52.5°	1937.1	1966.0	1994.0	2020.4	2032.8
55°	1808.5	1829.9	1863.7	1891.0	1903.3
57.5°	1674.9	1693.0	1723.6	1768.1	1774.7
60°	1538.8	1555.3	1586.7	1622.9	1637.8
62.5°	1388.7	1411.0	1444.0	1490.2	1503.4
65°	1242.8	1264.2	1307.9	1359.9	1381.3
67.5°	1101.8	1109.2	1165.3	1219.7	1254.3
70°	935.2	963.2	1028.4	1095.2	1121.5
72.5°	791.7	819.7	891.5	969.8	1002.8
75°	629.2	668.0	765.3	856.8	889.0
77.5°	486.6	529.4	649.8	742.2	779.3
80°	339.8	406.6	537.7	641.6	682.0
82.5°	213.6	296.1	436.2	545.1	580.6
85°	108.9	201.2	345.5	456.9	497.3
87.5°	28.9	130.3	268.8	375.2	416.5
90°	0.8	75.0	203.7	306.0	343.1
92.5°	0.8	42.1	151.7	243.3	281.2
95°	0.8	19.8	105.6	191.3	221.0
97.5°	0.8	8.2	72.6	144.3	174.0
100°	0.8	4.1	46.2	104.7	130.3
102.5°	1.6	2.5	28.9	75.0	95.7
105°	1.6	2.5	17.3	51.1	68.4
107.5°	1.6	2.5	9.9	34.6	47.0
110°	2.5	2.5	5.8	21.4	31.3

TEST NUMBER: P518242

CATALOG NUMBER: HVL8-8-LD4-2STD-35-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	2.5	2.5	3.3	14.0	20.6
115°	2.5	2.5	3.3	9.1	13.2
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)