

LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: FAIL-SAFE

Report Number: P518250

Luminaire Tested: HVL8-8-LD4-2STD-50-UNV-O-EDD

Issue Date: 4/27/2021

Tested By:

Approved By:



NVLAP Lab Code: 200050-0

Cooper Lighting Solutions laboratories have been accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that it adheres to the requirements of ISO/IEC 17025:2005 and appropriate IESNA test methods. This report must not be used to claim product certification, approval or endorsement by NVLAP, NIST or any agency of the Federal Government. Results contained in this report are valid for luminaire sample tested, as supplied by requestor. Information related to the luminaire tested has been supplied by requestor and can affect the validity of the test results. Report shall not be reproduced except in full without approval of Cooper Lighting Solutions Lighting Laboratory. Test performed at address noted above.

Test Information

Test Method: LM-79-2019
Report Number: P518250
Test Lab: INNOVATION CENTER
Issue Date: 4/27/2021
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: FAIL-SAFE
Catalog Number: HVL8-8-LD4-2STD-50-UNV-O-EDD
Description: 8 FOOT, 8 INCH WIDE, HVL LED LUMINAIRE, WITH 5000K, 80 CRI LEDS
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 11295.0 lumens
Efficiency: N/A
Efficacy: 86.4 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.27 / 1.38
Luminous Opening: Rectangular w/ Sides (W: 0.67' x L: 8' x H: 0.17')
CIE Type: Direct


Input Watts (W): 130.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

Measurement and Test Equipment			
Instrument	Identification Number	Calibration Date	Calibration Due Date
Photometer	P3	10/30/2015	4/30/2016
Power Meter	IN0214	1/12/2016	1/12/2017
AC Power Source	IN0062	1/12/2016	1/12/2017
DC Power Supply	--	--	--
Room Thermometer	IN0145	1/13/2016	1/13/2017

TEST NUMBER: P518250

CATALOG NUMBER: HVL8-8-LD4-2STD-50-UNV-O-EDD

Luminous Intensity Polar Plot



TEST NUMBER: P518250

CATALOG NUMBER: HVL8-8-LD4-2STD-50-UNV-O-EDD

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	110	110	110	105	105	105	101	101	101			98
1	108	102	98	94	105	100	96	92	95	92	89	91	88	86	87	85	83			81
2	98	89	82	76	95	87	80	75	83	77	73	79	75	71	76	72	69			67
3	89	78	69	63	86	76	68	62	73	66	61	70	64	59	67	62	58			56
4	81	69	60	53	79	67	59	52	65	57	52	62	56	51	60	54	50			47
5	75	61	52	45	72	60	52	45	58	50	44	56	49	44	54	48	43			41
6	69	55	46	40	67	54	46	39	52	45	39	50	44	38	49	43	38			36
7	64	50	41	35	62	49	41	35	47	40	34	46	39	34	44	38	34			32
8	59	46	37	31	58	45	37	31	43	36	31	42	35	30	41	35	30			28
9	55	42	34	28	54	41	33	28	40	33	28	39	32	27	38	32	27			25
10	52	39	31	25	51	38	30	25	37	30	25	36	29	25	35	29	25			23

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	7540	7540	7540
5°	7539	7380	7378
10°	7502	7257	7230
15°	7451	7120	7053
20°	7396	6965	6881
25°	7328	6805	6706
30°	7248	6634	6506
35°	7143	6445	6309
40°	7035	6246	6079
45°	6919	6029	5831
50°	6764	5776	5564
55°	6599	5499	5270
60°	6402	5136	4926
65°	6067	4728	4586
70°	5574	4246	4189
75°	4861	3716	3829
80°	3771	3199	3501
85°	2173	2679	3187

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6919 cd/sqm

TEST NUMBER: P518250

CATALOG NUMBER: HVL8-8-LD4-2STD-50-UNV-O-EDD

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	353.5	3.1
10°-20°	1014.0	9.0
20°-30°	1538.6	13.6
30°-40°	1860.5	16.5
40°-50°	1941.2	17.2
50°-60°	1774.9	15.7
60°-70°	1383.6	12.2
70°-80°	865.5	7.7
80°-90°	393.1	3.5
90°-100°	131.7	1.2
100°-110°	33.1	0.3
110°-120°	5.2	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2906.2	25.7
0°-40°	4766.6	42.2
0°-60°	8482.7	75.1
0°-90°	11125.0	98.5
90°-120°	170.0	1.5
90°-150°	170.0	1.5
90°-180°	170.0	1.5
0°-180°	11295.0	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	3736	3736	3736	3736	3736	
5°	3728	3721	3704	3722	3722	354
15°	3586	3592	3582	3603	3602	1012
25°	3323	3325	3329	3357	3362	1531
35°	2941	2955	2967	2997	3009	1841
45°	2475	2497	2517	2542	2554	1907
55°	1931	1954	1990	2019	2032	1725
65°	1327	1350	1397	1452	1475	1313
75°	672	713	817	915	949	716
85°	116	215	369	488	531	147
90°	1	80	218	327	366	5
95°	1	21	113	204	236	1
105°	2	3	18	55	73	2
115°	3	3	4	10	14	2
125°	0	0	0	0	0	0
135°	0	0	0	0	0	0
145°	0	0	0	0	0	0
155°	0	0	0	0	0	0
165°	0	0	0	0	0	0
175°	0	0	0	0	0	0
180°	0	0	0	0	0	0

TEST NUMBER: P518250

CATALOG NUMBER: HVL8-8-LD4-2STD-50-UNV-O-EDD

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	3735.7	3735.7	3735.7	3735.7	3735.7
2.5°	3740.1	3734.8	3718.1	3734.8	3733.9
5°	3727.8	3720.7	3704.0	3721.6	3721.6
7.5°	3703.1	3700.5	3685.5	3705.8	3705.8
10°	3674.1	3673.2	3660.8	3682.9	3683.7
12.5°	3633.5	3637.1	3625.6	3646.8	3649.4
15°	3586.0	3592.2	3582.5	3602.7	3601.8
17.5°	3534.0	3537.6	3530.5	3553.4	3552.5
20°	3469.7	3474.2	3468.9	3492.6	3495.3
22.5°	3398.4	3404.6	3403.7	3428.4	3435.4
25°	3322.7	3325.3	3328.8	3357.0	3362.3
27.5°	3239.0	3243.4	3249.6	3275.1	3280.4
30°	3147.4	3154.5	3161.5	3187.9	3195.0
32.5°	3050.6	3057.6	3066.4	3100.8	3104.3
35°	2941.4	2954.6	2966.9	2996.8	3009.2
37.5°	2832.2	2848.9	2860.3	2892.0	2901.7
40°	2716.8	2733.5	2752.0	2785.5	2791.7
42.5°	2596.1	2615.5	2637.5	2667.5	2678.0
45°	2474.6	2496.6	2516.9	2541.5	2553.9
47.5°	2343.4	2365.4	2390.1	2418.3	2426.2
50°	2207.8	2233.3	2259.7	2286.2	2300.2
52.5°	2068.6	2099.5	2129.4	2157.6	2170.8
55°	1931.3	1954.2	1990.3	2019.3	2032.5
57.5°	1788.6	1808.0	1840.6	1888.1	1895.2
60°	1643.3	1660.9	1694.4	1733.1	1749.0
62.5°	1483.0	1506.8	1542.0	1591.3	1605.4
65°	1327.1	1350.0	1396.7	1452.2	1475.1
67.5°	1176.5	1184.5	1244.4	1302.5	1339.5
70°	998.7	1028.6	1098.2	1169.5	1197.7
72.5°	845.4	875.4	952.0	1035.6	1070.9
75°	671.9	713.3	817.2	915.0	949.3
77.5°	519.6	565.4	693.9	792.6	832.2
80°	362.8	434.2	574.2	685.1	728.3
82.5°	228.1	316.2	465.9	582.1	620.0
85°	116.2	214.9	369.0	487.9	531.0
87.5°	30.8	139.1	287.1	400.7	444.7
90°	0.9	80.1	217.5	326.7	366.3
92.5°	0.9	44.9	162.0	259.8	300.3
95°	0.9	21.1	112.7	204.3	236.0
97.5°	0.9	8.8	77.5	154.1	185.8
100°	0.9	4.4	49.3	111.8	139.1
102.5°	1.8	2.6	30.8	80.1	102.2
105°	1.8	2.6	18.5	54.6	73.1
107.5°	1.8	2.6	10.6	37.0	50.2
110°	2.6	2.6	6.2	22.9	33.5

TEST NUMBER: P518250

CATALOG NUMBER: HVL8-8-LD4-2STD-50-UNV-O-EDD

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°
112.5°	2.6	2.6	3.5	15.0	22.0
115°	2.6	2.6	3.5	9.7	14.1
117.5°	0.0	0.0	0.0	0.0	0.0
120°	0.0	0.0	0.0	0.0	0.0
122.5°	0.0	0.0	0.0	0.0	0.0
125°	0.0	0.0	0.0	0.0	0.0
127.5°	0.0	0.0	0.0	0.0	0.0
130°	0.0	0.0	0.0	0.0	0.0
132.5°	0.0	0.0	0.0	0.0	0.0
135°	0.0	0.0	0.0	0.0	0.0
137.5°	0.0	0.0	0.0	0.0	0.0
140°	0.0	0.0	0.0	0.0	0.0
142.5°	0.0	0.0	0.0	0.0	0.0
145°	0.0	0.0	0.0	0.0	0.0
147.5°	0.0	0.0	0.0	0.0	0.0
150°	0.0	0.0	0.0	0.0	0.0
152.5°	0.0	0.0	0.0	0.0	0.0
155°	0.0	0.0	0.0	0.0	0.0
157.5°	0.0	0.0	0.0	0.0	0.0
160°	0.0	0.0	0.0	0.0	0.0
162.5°	0.0	0.0	0.0	0.0	0.0
165°	0.0	0.0	0.0	0.0	0.0
167.5°	0.0	0.0	0.0	0.0	0.0
170°	0.0	0.0	0.0	0.0	0.0
172.5°	0.0	0.0	0.0	0.0	0.0
175°	0.0	0.0	0.0	0.0	0.0
177.5°	0.0	0.0	0.0	0.0	0.0
180°	0.0	0.0	0.0	0.0	0.0

(END OF REPORT)