

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P571711

Luminaire Tested: **FLD4C-02-D010 FEU4C-X-90-35 F4X-M-X-H-BL84**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P571711
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P207151)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-02-D010 FEU4C-X-90-35 F4X-M-X-H-BL84
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 3500K, 90 CRI LEDS, 4LBMH TRIM
AND BOTTOM LENS, 0.125" CLEAR POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 232.1 lumens
Efficiency: N/A
Efficacy: 66.3 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.93
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 3.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P571711

CATALOG NUMBER: FLD4C-02-D010 FEU4C-X-90-35 F4X-M-X-H-BL84

Luminous Intensity Polar Plot





TEST NUMBER: P571711

CATALOG NUMBER: FLD4C-02-D010 FEU4C-X-90-35 F4X-M-X-H-BL84

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	113	110	108	105		111	108	106	104		104	102	100		100	99	97		97	96	95
2	107	102	98	94		105	100	96	93		97	94	91		94	91	89		91	89	87
3	101	94	89	85		99	93	88	84		90	86	83		88	84	82		86	83	80
4	96	88	82	77		94	86	81	77		84	80	76		82	78	75		80	77	74
5	90	82	75	71		89	81	75	70		79	74	70		77	73	69		75	72	69
6	85	76	70	65		84	75	69	65		74	68	64		72	68	64		71	67	64
7	81	71	65	60		80	70	64	60		69	64	60		68	63	59		67	62	59
8	77	67	60	56		75	66	60	56		65	59	56		64	59	55		63	58	55
9	73	63	56	52		72	62	56	52		61	56	52		60	55	52		59	55	51
10	69	59	53	49		68	59	53	49		58	52	49		57	52	48		56	52	48

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	28256
5°	27846
10°	26684
15°	25209
20°	23533
25°	21363
30°	17832
35°	12913
40°	8083
45°	4622
50°	2408
55°	1349
60°	860
65°	523
70°	395
75°	190
80°	283
85°	0



TEST NUMBER: P571711

CATALOG NUMBER: FLD4C-02-D010 FEU4C-X-90-35 F4X-M-X-H-BL84

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	21.2	9.1
10°-20°	55.5	23.9
20°-30°	71.4	30.8
30°-40°	53.7	23.1
40°-50°	21.6	9.3
50°-60°	6.1	2.6
60°-70°	2.0	0.8
70°-80°	0.6	0.3
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	148.1	63.8
0°-40°	201.8	86.9
0°-60°	229.5	98.9
0°-90°	232.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	232.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	230	
5°	226	21
15°	198	56
25°	158	71
35°	86	54
45°	27	22
55°	6	6
65°	2	2
75°	0	1
85°	0	0
90°	0	



TEST NUMBER: P571711

CATALOG NUMBER: FLD4C-02-D010 FEU4C-X-90-35 F4X-M-X-H-BL84

CANDELA DISTRIBUTION (FULL):

	0°
0°	230.0
2.5°	228.6
5°	225.8
7.5°	220.6
10°	213.9
12.5°	205.9
15°	198.2
17.5°	189.4
20°	180.0
22.5°	169.8
25°	157.6
27.5°	142.9
30°	125.7
32.5°	106.4
35°	86.1
37.5°	67.2
40°	50.4
42.5°	37.1
45°	26.6
47.5°	18.2
50°	12.6
52.5°	8.8
55°	6.3
57.5°	4.6
60°	3.5
62.5°	2.5
65°	1.8
67.5°	1.4
70°	1.1
72.5°	0.7
75°	0.4
77.5°	0.4
80°	0.4
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)