

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P572833

Luminaire Tested: **FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-LI-BL84**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P572833
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205108)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-LI-BL84
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 4000K, 90 CRI LEDS, 4LBMLI TRIM
AND BOTTOM LENS, 0.125" CLEAR POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2203.9 lumens
Efficiency: N/A
Efficacy: 70.0 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 31.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P572833

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-LI-BL84

Luminous Intensity Polar Plot





TEST NUMBER: P572833

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-LI-BL84

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	114	111	109	106		111	109	107	105		105	103	101		101	100	98		98	97	96
2	108	103	100	96		106	102	98	95		99	96	93		96	93	91		93	91	89
3	103	97	92	88		101	95	91	87		93	89	86		90	87	85		88	85	83
4	98	91	85	81		96	89	84	81		87	83	80		85	82	79		83	80	78
5	93	85	79	75		91	84	79	75		82	78	74		81	77	73		79	76	73
6	89	80	74	70		87	79	74	70		78	73	69		76	72	69		75	71	68
7	84	75	69	65		83	75	69	65		73	68	65		72	68	64		71	67	64
8	80	71	65	61		79	70	65	61		69	64	61		68	64	60		67	63	60
9	77	67	61	57		75	67	61	57		66	61	57		65	60	57		64	60	57
10	73	64	58	54		72	63	58	54		62	57	54		62	57	54		61	57	54

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	338854
5°	335635
10°	318047
15°	288753
20°	255148
25°	220587
30°	172430
35°	105748
40°	54271
45°	21561
50°	6995
55°	2420
60°	2064
65°	1657
70°	1006
75°	1329
80°	0
85°	0



TEST NUMBER: P572833

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-LI-BL84

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	254.1	11.5
10°-20°	632.6	28.7
20°-30°	735.4	33.4
30°-40°	450.3	20.4
40°-50°	111.8	5.1
50°-60°	13.0	0.6
60°-70°	4.9	0.2
70°-80°	1.8	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1622.0	73.6
0°-40°	2072.3	94.0
0°-60°	2197.2	99.7
0°-90°	2203.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2203.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2758	
5°	2722	254
15°	2270	633
25°	1627	735
35°	705	450
45°	124	112
55°	11	13
65°	6	5
75°	3	2
85°	0	0
90°	0	



TEST NUMBER: P572833

CATALOG NUMBER: FLD4C-25-D010 FEU4C-X-90-40 F4X-M-X-LI-BL84

CANDELA DISTRIBUTION (FULL):

	0°
0°	2758.2
2.5°	2755.4
5°	2721.6
7.5°	2648.2
10°	2549.5
12.5°	2419.8
15°	2270.3
17.5°	2109.5
20°	1951.6
22.5°	1793.6
25°	1627.3
27.5°	1435.5
30°	1215.5
32.5°	958.9
35°	705.1
37.5°	496.3
40°	338.4
42.5°	211.5
45°	124.1
47.5°	70.5
50°	36.6
52.5°	16.9
55°	11.3
57.5°	8.4
60°	8.4
62.5°	5.7
65°	5.7
67.5°	2.8
70°	2.8
72.5°	2.8
75°	2.8
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)