

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573049

Luminaire Tested: **FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL84**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573049
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205108)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL84
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 5000K, 90 CRI LEDS, 4LBMLI TRIM
AND BOTTOM LENS, 0.125" CLEAR POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2641.0 lumens
Efficiency: N/A
Efficacy: 83.6 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 31.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573049

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL84

Luminous Intensity Polar Plot





TEST NUMBER: P573049

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL84

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20							
RC	80				70				50				30				10				0			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																								
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100						
1	114	111	109	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94						
2	108	103	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88						
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	85	83	82						
4	98	91	85	81	96	89	84	81	87	83	80	85	82	79	83	80	78	76						
5	93	85	79	75	91	84	79	75	82	78	74	81	77	73	79	76	73	71						
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67						
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63						
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59						
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55						
10	73	64	58	54	72	63	58	54	62	57	54	62	57	54	61	57	54	52						

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	406043
5°	402180
10°	381107
15°	346000
20°	305744
25°	264330
30°	206618
35°	126715
40°	65032
45°	25835
50°	8390
55°	2892
60°	2482
65°	1977
70°	1221
75°	1614
80°	0
85°	0



TEST NUMBER: P573049

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL84

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	304.5	11.5
10°-20°	758.0	28.7
20°-30°	881.2	33.4
30°-40°	539.6	20.4
40°-50°	134.0	5.1
50°-60°	15.7	0.6
60°-70°	5.9	0.2
70°-80°	2.2	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1943.7	73.6
0°-40°	2483.3	94.0
0°-60°	2632.9	99.7
0°-90°	2641.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2641.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3305	
5°	3261	304
15°	2720	758
25°	1950	881
35°	845	540
45°	149	134
55°	14	16
65°	7	6
75°	3	2
85°	0	0
90°	0	



TEST NUMBER: P573049

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL84

CANDELA DISTRIBUTION (FULL):

	0°
0°	3305.1
2.5°	3301.7
5°	3261.2
7.5°	3173.3
10°	3055.0
12.5°	2899.5
15°	2720.4
17.5°	2527.8
20°	2338.6
22.5°	2149.3
25°	1950.0
27.5°	1720.2
30°	1456.5
32.5°	1149.0
35°	844.9
37.5°	594.7
40°	405.5
42.5°	253.4
45°	148.7
47.5°	84.5
50°	43.9
52.5°	20.3
55°	13.5
57.5°	10.1
60°	10.1
62.5°	6.8
65°	6.8
67.5°	3.4
70°	3.4
72.5°	3.4
75°	3.4
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)