

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573052

Luminaire Tested: **FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL89AM**

Issue Date: 3/1/2023



**Test Information**

Test Method: LM-79-08  
Report Number: P573052  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205108)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/1/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: FAIL-SAFE  
Catalog Number: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL89AM  
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 5000K, 90 CRI LEDS, 4LBMLI TRIM  
AND BOTTOM LENS, 0.125" OPAL POLYCARBONATE  
  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1146.1 lumens  
Efficiency: N/A  
Efficacy: 36.3 lumens/watt  
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85  
Luminous Opening: Circular (Dia: 0.33' x H: 0')  
CIE Type: Direct

Input Watts (W): 31.6  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P573052

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL89AM

### Luminous Intensity Polar Plot



TEST NUMBER: P573052

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL89AM

### COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

|     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |   |  |  |  |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|---|--|--|--|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |     |     | 20  |     |    |    |   |  |  |  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |     | 30  |     |     |     | 10  |     |    |    | 0 |  |  |  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30 | 10 | 0 |  |  |  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |    |    |   |  |  |  |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 |    |    |   |  |  |  |
| 1   | 114 | 111 | 109 | 106 | 111 | 109 | 107 | 105 | 105 | 103 | 101 | 101 | 100 | 98  | 98  | 97  | 96  | 94  |    |    |   |  |  |  |
| 2   | 108 | 103 | 100 | 96  | 106 | 102 | 98  | 95  | 99  | 96  | 93  | 96  | 93  | 91  | 93  | 91  | 89  | 88  |    |    |   |  |  |  |
| 3   | 103 | 97  | 92  | 88  | 101 | 95  | 91  | 87  | 93  | 89  | 86  | 90  | 87  | 85  | 88  | 85  | 83  | 82  |    |    |   |  |  |  |
| 4   | 98  | 91  | 85  | 81  | 96  | 89  | 84  | 81  | 87  | 83  | 80  | 85  | 82  | 79  | 83  | 80  | 78  | 76  |    |    |   |  |  |  |
| 5   | 93  | 85  | 79  | 75  | 91  | 84  | 79  | 75  | 82  | 78  | 74  | 81  | 77  | 73  | 79  | 76  | 73  | 71  |    |    |   |  |  |  |
| 6   | 89  | 80  | 74  | 70  | 87  | 79  | 74  | 70  | 78  | 73  | 69  | 76  | 72  | 69  | 75  | 71  | 68  | 67  |    |    |   |  |  |  |
| 7   | 84  | 75  | 69  | 65  | 83  | 75  | 69  | 65  | 73  | 68  | 65  | 72  | 68  | 64  | 71  | 67  | 64  | 63  |    |    |   |  |  |  |
| 8   | 80  | 71  | 65  | 61  | 79  | 70  | 65  | 61  | 69  | 64  | 61  | 68  | 64  | 60  | 67  | 63  | 60  | 59  |    |    |   |  |  |  |
| 9   | 77  | 67  | 61  | 57  | 75  | 67  | 61  | 57  | 66  | 61  | 57  | 65  | 60  | 57  | 64  | 60  | 57  | 55  |    |    |   |  |  |  |
| 10  | 73  | 64  | 58  | 54  | 72  | 63  | 58  | 54  | 62  | 57  | 54  | 62  | 57  | 54  | 61  | 57  | 54  | 52  |    |    |   |  |  |  |

**AVERAGE LUMINANCE (cd/sqm):**

|     | 0°     |
|-----|--------|
| 0°  | 176196 |
| 5°  | 174514 |
| 10° | 165367 |
| 15° | 150145 |
| 20° | 132673 |
| 25° | 114692 |
| 30° | 89655  |
| 35° | 54981  |
| 40° | 28226  |
| 45° | 11206  |
| 50° | 3631   |
| 55° | 1264   |
| 60° | 1081   |
| 65° | 872    |
| 70° | 539    |
| 75° | 712    |
| 80° | 0      |
| 85° | 0      |



TEST NUMBER: P573052

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL89AM

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 132.1  | 11.5      |
| 10°-20°   | 328.9  | 28.7      |
| 20°-30°   | 382.4  | 33.4      |
| 30°-40°   | 234.2  | 20.4      |
| 40°-50°   | 58.1   | 5.1       |
| 50°-60°   | 6.8    | 0.6       |
| 60°-70°   | 2.6    | 0.2       |
| 70°-80°   | 1.0    | 0.1       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 843.4  | 73.6      |
| 0°-40°    | 1077.6 | 94.0      |
| 0°-60°    | 1142.5 | 99.7      |
| 0°-90°    | 1146.1 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 1146.1 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 1434 |      |
| 5°  | 1415 | 132  |
| 15° | 1180 | 329  |
| 25° | 846  | 382  |
| 35° | 367  | 234  |
| 45° | 64   | 58   |
| 55° | 6    | 7    |
| 65° | 3    | 3    |
| 75° | 2    | 1    |
| 85° | 0    | 0    |
| 90° | 0    |      |



TEST NUMBER: P573052

CATALOG NUMBER: FLD4C-30-D010 FEU4C-X-90-50 F4X-M-X-LI-BL89AM

**CANDELA DISTRIBUTION (FULL):**

|       | 0°     |
|-------|--------|
| 0°    | 1434.2 |
| 2.5°  | 1432.7 |
| 5°    | 1415.1 |
| 7.5°  | 1377.0 |
| 10°   | 1325.6 |
| 12.5° | 1258.2 |
| 15°   | 1180.5 |
| 17.5° | 1096.9 |
| 20°   | 1014.8 |
| 22.5° | 932.6  |
| 25°   | 846.1  |
| 27.5° | 746.4  |
| 30°   | 632.0  |
| 32.5° | 498.6  |
| 35°   | 366.6  |
| 37.5° | 258.1  |
| 40°   | 176.0  |
| 42.5° | 110.0  |
| 45°   | 64.5   |
| 47.5° | 36.7   |
| 50°   | 19.0   |
| 52.5° | 8.8    |
| 55°   | 5.9    |
| 57.5° | 4.4    |
| 60°   | 4.4    |
| 62.5° | 3.0    |
| 65°   | 3.0    |
| 67.5° | 1.5    |
| 70°   | 1.5    |
| 72.5° | 1.5    |
| 75°   | 1.5    |
| 77.5° | 0.0    |
| 80°   | 0.0    |
| 82.5° | 0.0    |
| 85°   | 0.0    |
| 87.5° | 0.0    |
| 90°   | 0.0    |



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)