

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573082

Luminaire Tested: **FLD4C-35-D010 FEU4C-X-90-27 F4X-M-X-H-BL89AM**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573082
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P207151)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-35-D010 FEU4C-X-90-27 F4X-M-X-H-BL89AM
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 2700K, 90 CRI LEDS, 4LBMH TRIM
AND BOTTOM LENS, 0.125" OPAL POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1006.0 lumens
Efficiency: N/A
Efficacy: 24.9 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.93
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 40.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573082

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-27 F4X-M-X-H-BL89AM

Luminous Intensity Polar Plot





TEST NUMBER: P573082

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-27 F4X-M-X-H-BL89AM

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	113	110	108	105		111	108	106	104		104	102	100		100	99	97		97	96	95
2	107	102	98	94		105	100	96	93		97	94	91		94	91	89		91	89	87
3	101	94	89	85		99	93	88	84		90	86	83		88	84	82		86	83	80
4	96	88	82	77		94	86	81	77		84	80	76		82	78	75		80	77	74
5	90	82	75	71		89	81	75	70		79	74	70		77	73	69		75	72	69
6	86	76	70	65		84	75	69	65		74	68	64		72	68	64		71	67	64
7	81	71	65	60		80	70	64	60		69	64	60		68	63	59		67	62	59
8	77	67	60	56		75	66	60	56		65	59	56		64	59	55		63	58	55
9	73	63	56	52		72	62	56	52		61	56	52		60	55	52		59	55	52
10	69	59	53	49		68	59	53	49		58	52	49		57	52	48		56	52	48

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	122546
5°	120770
10°	115717
15°	109305
20°	102028
25°	92610
30°	77327
35°	56016
40°	35074
45°	20050
50°	10455
55°	5847
60°	3735
65°	2209
70°	1652
75°	712
80°	1061
85°	0



TEST NUMBER: P573082

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-27 F4X-M-X-H-BL89AM

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	91.8	9.1
10°-20°	240.8	23.9
20°-30°	309.5	30.8
30°-40°	232.8	23.1
40°-50°	93.5	9.3
50°-60°	26.6	2.6
60°-70°	8.4	0.8
70°-80°	2.4	0.2
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	642.0	63.8
0°-40°	874.9	87.0
0°-60°	995.0	98.9
0°-90°	1006.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1006.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	998	
5°	979	92
15°	859	241
25°	683	309
35°	374	233
45°	115	94
55°	27	27
65°	8	8
75°	2	2
85°	0	0
90°	0	



TEST NUMBER: P573082

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-27 F4X-M-X-H-BL89AM

CANDELA DISTRIBUTION (FULL):

	0°
0°	997.5
2.5°	991.4
5°	979.3
7.5°	956.5
10°	927.6
12.5°	892.8
15°	859.4
17.5°	821.4
20°	780.4
22.5°	736.4
25°	683.2
27.5°	619.4
30°	545.1
32.5°	461.5
35°	373.5
37.5°	291.5
40°	218.7
42.5°	160.9
45°	115.4
47.5°	79.0
50°	54.7
52.5°	38.0
55°	27.3
57.5°	19.7
60°	15.2
62.5°	10.6
65°	7.6
67.5°	6.1
70°	4.6
72.5°	3.0
75°	1.5
77.5°	1.5
80°	1.5
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)