

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573154

Luminaire Tested: **FLD4C-35-D010 FEU4C-X-90-35 F4X-M-X-H-BL89AM**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573154
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P207151)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-35-D010 FEU4C-X-90-35 F4X-M-X-H-BL89AM
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 3500K, 90 CRI LEDS, 4LBMH TRIM
AND BOTTOM LENS, 0.125" OPAL POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1060.0 lumens
Efficiency: N/A
Efficacy: 26.2 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.93
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 40.4
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573154

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-35 F4X-M-X-H-BL89AM

Luminous Intensity Polar Plot





TEST NUMBER: P573154

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-35 F4X-M-X-H-BL89AM

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	113	110	108	105		111	108	106	104		104	102	100		100	99	97		97	96	95
2	107	102	98	94		105	100	96	93		97	94	91		94	91	89		91	89	87
3	101	94	89	85		99	93	88	84		90	86	83		88	84	82		86	83	80
4	96	88	82	77		94	86	81	77		84	80	76		82	78	75		80	77	74
5	90	82	75	71		89	81	75	70		79	74	70		77	73	69		75	72	69
6	86	76	70	65		84	75	69	65		74	68	64		72	68	64		71	67	64
7	81	71	65	60		80	70	64	60		69	64	60		68	63	59		67	62	59
8	77	67	60	56		75	66	60	56		65	59	56		64	59	55		63	58	55
9	73	63	56	52		72	62	56	52		61	56	52		60	55	52		59	55	52
10	69	59	53	49		68	59	53	49		58	52	49		57	52	48		56	52	48

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	129131
5°	127257
10°	121929
15°	115168
20°	107506
25°	97585
30°	81470
35°	59031
40°	36950
45°	21127
50°	11009
55°	6169
60°	3931
65°	2326
70°	1724
75°	759
80°	1132
85°	0



TEST NUMBER: P573154

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-35 F4X-M-X-H-BL89AM

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	96.7	9.1
10°-20°	253.7	23.9
20°-30°	326.1	30.8
30°-40°	245.3	23.1
40°-50°	98.5	9.3
50°-60°	28.0	2.6
60°-70°	8.9	0.8
70°-80°	2.5	0.2
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	676.5	63.8
0°-40°	921.8	87.0
0°-60°	1048.4	98.9
0°-90°	1060.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1060.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1051	
5°	1032	97
15°	906	254
25°	720	326
35°	394	245
45°	122	99
55°	29	28
65°	8	9
75°	2	3
85°	0	0
90°	0	



TEST NUMBER: P573154

CATALOG NUMBER: FLD4C-35-D010 FEU4C-X-90-35 F4X-M-X-H-BL89AM

CANDELA DISTRIBUTION (FULL):

	0°
0°	1051.1
2.5°	1044.7
5°	1031.9
7.5°	1007.8
10°	977.4
12.5°	940.7
15°	905.5
17.5°	865.5
20°	822.3
22.5°	775.9
25°	719.9
27.5°	652.7
30°	574.3
32.5°	486.3
35°	393.6
37.5°	307.1
40°	230.4
42.5°	169.6
45°	121.6
47.5°	83.2
50°	57.6
52.5°	40.0
55°	28.8
57.5°	20.8
60°	16.0
62.5°	11.2
65°	8.0
67.5°	6.4
70°	4.8
72.5°	3.2
75°	1.6
77.5°	1.6
80°	1.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)