

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573392

Luminaire Tested: **FLD4C-40-D010 FEU4C-X-90-40 F4X-W-X-H-BL85**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573392
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P206636)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-40-D010 FEU4C-X-90-40 F4X-W-X-H-BL85
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 4000K, 90 CRI LEDS, 4LBWH TRIM
AND BOTTOM LENS, 0.187" CLEAR POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3011.0 lumens
Efficiency: N/A
Efficacy: 64.1 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.13
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 47
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573392

CATALOG NUMBER: FLD4C-40-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

Luminous Intensity Polar Plot





TEST NUMBER: P573392

CATALOG NUMBER: FLD4C-40-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	97	96		96
2	105	100	95	91	103	98	93	90	95	91	88		91	88	86		89
3	99	91	85	80	97	90	84	80	87	82	78		84	80	77		82
4	92	83	77	72	90	82	76	71	80	75	70		78	73	70		76
5	87	77	70	65	85	76	69	64	74	68	64		72	67	63		70
6	81	71	64	58	80	70	63	58	68	62	58		67	61	57		65
7	76	65	58	53	75	65	58	53	63	57	53		62	56	52		61
8	72	60	53	49	70	60	53	49	59	53	48		58	52	48		57
9	68	56	49	45	66	56	49	45	55	49	44		54	48	44		53
10	64	52	46	41	63	52	46	41	51	45	41		50	45	41		49

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	238434
5°	239345
10°	240066
15°	240079
20°	238767
25°	233166
30°	217938
35°	188715
40°	147432
45°	105774
50°	68710
55°	41124
60°	24079
65°	15465
70°	10273
75°	7785
80°	5801
85°	0



TEST NUMBER: P573392

CATALOG NUMBER: FLD4C-40-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	184.8	6.1
10°-20°	532.6	17.7
20°-30°	785.8	26.1
30°-40°	775.5	25.8
40°-50°	474.6	15.8
50°-60°	181.9	6.0
60°-70°	56.9	1.9
70°-80°	16.7	0.6
80°-90°	2.2	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1503.2	49.9
0°-40°	2278.7	75.7
0°-60°	2935.2	97.5
0°-90°	3011.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3011.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1941	
5°	1941	185
15°	1888	533
25°	1720	786
35°	1258	775
45°	609	475
55°	192	182
65°	53	57
75°	16	17
85°	0	2
90°	0	



TEST NUMBER: P573392

CATALOG NUMBER: FLD4C-40-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

CANDELA DISTRIBUTION (FULL):

	0°
0°	1940.8
2.5°	1944.9
5°	1940.8
7.5°	1936.7
10°	1924.4
12.5°	1908.1
15°	1887.6
17.5°	1863.1
20°	1826.3
22.5°	1785.5
25°	1720.1
27.5°	1638.3
30°	1536.3
32.5°	1409.7
35°	1258.3
37.5°	1090.8
40°	919.3
42.5°	759.9
45°	608.8
47.5°	473.9
50°	359.5
52.5°	265.6
55°	192.0
57.5°	134.8
60°	98.0
62.5°	73.6
65°	53.2
67.5°	40.9
70°	28.6
72.5°	20.4
75°	16.4
77.5°	8.2
80°	8.2
82.5°	4.1
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)