

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573464

Luminaire Tested: **FLD4C-45-D010 FEU4C-X-90-27 F4X-W-X-H-BL85**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573464
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P206636)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-45-D010 FEU4C-X-90-27 F4X-W-X-H-BL85
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 2700K, 90 CRI LEDS, 4LBWH TRIM
AND BOTTOM LENS, 0.187" CLEAR POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3302.0 lumens
Efficiency: N/A
Efficacy: 66.6 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.13
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 49.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573464

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-27 F4X-W-X-H-BL85

Luminous Intensity Polar Plot





TEST NUMBER: P573464

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-27 F4X-W-X-H-BL85

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	112	109	106	104		110	107	104	102		103	101	99		99	97	96		96	94	93
2	105	100	95	91		103	98	93	90		95	91	88		91	88	86		89	86	84
3	99	91	85	80		97	90	84	80		87	82	78		84	80	77		82	79	76
4	92	83	77	72		90	82	76	71		80	75	70		78	73	70		76	72	69
5	87	77	70	65		85	76	69	64		74	68	64		72	67	63		70	66	62
6	81	71	64	58		80	70	63	58		68	62	58		67	61	57		65	61	57
7	76	65	58	53		75	65	58	53		63	57	53		62	56	52		61	56	52
8	72	60	53	49		70	60	53	49		59	53	48		58	52	48		57	52	48
9	68	56	49	45		66	56	49	45		55	49	44		54	48	44		53	48	44
10	64	52	46	41		63	52	46	41		51	45	41		50	45	41		49	44	41

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	261469
5°	262468
10°	263270
15°	263278
20°	261842
25°	255709
30°	238990
35°	206967
40°	161673
45°	116007
50°	75361
55°	45108
60°	26389
65°	16948
70°	11279
75°	8497
80°	6367
85°	0



TEST NUMBER: P573464

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-27 F4X-W-X-H-BL85

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	202.7	6.1
10°-20°	584.0	17.7
20°-30°	861.8	26.1
30°-40°	850.5	25.8
40°-50°	520.4	15.8
50°-60°	199.5	6.0
60°-70°	62.4	1.9
70°-80°	18.3	0.6
80°-90°	2.4	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1648.5	49.9
0°-40°	2499.0	75.7
0°-60°	3218.9	97.5
0°-90°	3302.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3302.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2128	
5°	2128	203
15°	2070	584
25°	1886	862
35°	1380	850
45°	668	520
55°	211	200
65°	58	62
75°	18	18
85°	0	2
90°	0	



TEST NUMBER: P573464

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-27 F4X-W-X-H-BL85

CANDELA DISTRIBUTION (FULL):

	0°
0°	2128.3
2.5°	2132.8
5°	2128.3
7.5°	2123.9
10°	2110.4
12.5°	2092.5
15°	2070.0
17.5°	2043.1
20°	2002.8
22.5°	1958.1
25°	1886.4
27.5°	1796.7
30°	1684.7
32.5°	1545.9
35°	1380.0
37.5°	1196.3
40°	1008.1
42.5°	833.4
45°	667.7
47.5°	519.6
50°	394.3
52.5°	291.3
55°	210.6
57.5°	147.8
60°	107.4
62.5°	80.7
65°	58.3
67.5°	44.9
70°	31.4
72.5°	22.4
75°	17.9
77.5°	9.0
80°	9.0
82.5°	4.5
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)