

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573502

Luminaire Tested: **FLD4C-45-D010 FEU4C-X-90-30 F4X-W-X-H-BL89AM**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573502
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P206636)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-45-D010 FEU4C-X-90-30 F4X-W-X-H-BL89AM
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 3000K, 90 CRI LEDS, 4LBWH TRIM
AND BOTTOM LENS, 0.125" OPAL POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1562.0 lumens
Efficiency: N/A
Efficacy: 31.5 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.13
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 49.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573502

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-30 F4X-W-X-H-BL89AM

Luminous Intensity Polar Plot





TEST NUMBER: P573502

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-30 F4X-W-X-H-BL89AM

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	112	109	106	104		110	107	104	102		103	101	99		99	97	96		96	94	93
2	105	100	95	91		103	98	93	90		95	91	88		91	88	86		89	86	84
3	99	91	85	80		97	90	84	80		87	82	78		84	80	77		82	79	76
4	92	83	77	72		90	82	76	71		80	75	70		78	73	70		76	72	69
5	87	77	70	65		85	76	69	64		74	68	64		72	67	63		70	66	62
6	81	71	64	58		80	70	63	58		68	62	58		67	61	57		65	61	57
7	76	65	58	53		75	65	58	53		63	57	53		62	56	52		61	56	52
8	72	60	53	49		70	60	53	49		59	53	48		58	52	48		57	52	48
9	68	56	49	45		66	56	49	45		55	49	44		54	48	44		53	48	44
10	64	52	46	41		63	52	46	41		51	45	41		50	45	41		49	44	41

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	123689
5°	124161
10°	124537
15°	124542
20°	123861
25°	120955
30°	113062
35°	97905
40°	76482
45°	54867
50°	35645
55°	21333
60°	12482
65°	8023
70°	5352
75°	4035
80°	2971
85°	0



TEST NUMBER: P573502

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-30 F4X-W-X-H-BL89AM

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	95.9	6.1
10°-20°	276.3	17.7
20°-30°	407.7	26.1
30°-40°	402.3	25.8
40°-50°	246.2	15.8
50°-60°	94.4	6.0
60°-70°	29.5	1.9
70°-80°	8.6	0.6
80°-90°	1.1	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	779.8	49.9
0°-40°	1182.1	75.7
0°-60°	1522.7	97.5
0°-90°	1562.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1562.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1007	
5°	1007	96
15°	979	276
25°	892	408
35°	653	402
45°	316	246
55°	100	94
65°	28	30
75°	8	9
85°	0	1
90°	0	



TEST NUMBER: P573502

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-30 F4X-W-X-H-BL89AM

CANDELA DISTRIBUTION (FULL):

	0°
0°	1006.8
2.5°	1008.9
5°	1006.8
7.5°	1004.7
10°	998.3
12.5°	989.8
15°	979.2
17.5°	966.5
20°	947.4
22.5°	926.3
25°	892.3
27.5°	849.9
30°	797.0
32.5°	731.3
35°	652.8
37.5°	565.9
40°	476.9
42.5°	394.2
45°	315.8
47.5°	245.8
50°	186.5
52.5°	137.8
55°	99.6
57.5°	69.9
60°	50.8
62.5°	38.2
65°	27.6
67.5°	21.2
70°	14.9
72.5°	10.6
75°	8.5
77.5°	4.2
80°	4.2
82.5°	2.1
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)