

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573521

Luminaire Tested: **FLD4C-45-D010 FEU4C-X-90-35 F4X-M-X-LI-BL89BV**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573521
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205108)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-45-D010 FEU4C-X-90-35 F4X-M-X-LI-BL89BV
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 3500K, 90 CRI LEDS, 4LBMLI TRIM
AND BOTTOM LENS, 0.125" CLEAR ACRYLIC

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 4311.0 lumens
Efficiency: N/A
Efficacy: 86.9 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 49.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573521

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-35 F4X-M-X-LI-BL89BV

Luminous Intensity Polar Plot



TEST NUMBER: P573521

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-35 F4X-M-X-LI-BL89BV

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20							
RC	80				70				50				30				10				0			
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0			
RCR																								
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100						
1	114	111	109	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94						
2	108	103	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88						
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	85	83	82						
4	98	91	85	81	96	89	84	81	87	83	80	85	82	79	83	80	78	76						
5	93	85	79	75	91	84	79	75	82	78	74	81	77	73	79	76	73	71						
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67						
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63						
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59						
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55						
10	73	64	58	54	72	63	58	54	62	57	54	62	57	54	61	57	54	52						

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	662794
5°	656496
10°	622084
15°	564801
20°	499079
25°	431468
30°	337270
35°	206832
40°	106167
45°	42184
50°	13704
55°	4712
60°	4054
65°	3227
70°	2012
75°	2658
80°	0
85°	0



TEST NUMBER: P573521

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-35 F4X-M-X-LI-BL89BV

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	497.0	11.5
10°-20°	1237.3	28.7
20°-30°	1438.4	33.4
30°-40°	880.8	20.4
40°-50°	218.8	5.1
50°-60°	25.5	0.6
60°-70°	9.6	0.2
70°-80°	3.7	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3172.7	73.6
0°-40°	4053.5	94.0
0°-60°	4297.8	99.7
0°-90°	4311.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4311.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5395	
5°	5323	497
15°	4441	1237
25°	3183	1438
35°	1379	881
45°	243	219
55°	22	26
65°	11	10
75°	6	4
85°	0	0
90°	0	



TEST NUMBER: P573521

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-35 F4X-M-X-LI-BL89BV

CANDELA DISTRIBUTION (FULL):

0°	
0°	5395.0
2.5°	5389.4
5°	5323.4
7.5°	5179.8
10°	4986.7
12.5°	4733.0
15°	4440.7
17.5°	4126.2
20°	3817.4
22.5°	3508.3
25°	3183.0
27.5°	2807.9
30°	2377.5
32.5°	1875.5
35°	1379.1
37.5°	970.8
40°	662.0
42.5°	413.7
45°	242.8
47.5°	138.0
50°	71.7
52.5°	33.1
55°	22.0
57.5°	16.5
60°	16.5
62.5°	11.1
65°	11.1
67.5°	5.6
70°	5.6
72.5°	5.6
75°	5.6
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)