

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573607

Luminaire Tested: **FLD4C-45-D010 FEU4C-X-90-50 F4X-W-X-H-BL84**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573607
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P206636)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-45-D010 FEU4C-X-90-50 F4X-W-X-H-BL84
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 5000K, 90 CRI LEDS, 4LBWH TRIM
AND BOTTOM LENS, 0.125" CLEAR POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3731.0 lumens
Efficiency: N/A
Efficacy: 75.2 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.13
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 49.6
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573607

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-50 F4X-W-X-H-BL84

Luminous Intensity Polar Plot





TEST NUMBER: P573607

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-50 F4X-W-X-H-BL84

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	97	96		96
2	105	100	95	91	103	98	93	90	95	91	88		91	88	86		89
3	99	91	85	80	97	90	84	80	87	82	78		84	80	77		82
4	92	83	77	72	90	82	76	71	80	75	70		78	73	70		76
5	87	77	70	65	85	76	69	64	74	68	64		72	67	63		70
6	81	71	64	58	80	70	63	58	68	62	58		67	61	57		65
7	76	65	58	53	75	65	58	53	63	57	53		62	56	52		61
8	72	60	53	49	70	60	53	49	59	53	48		58	52	48		57
9	68	56	49	45	66	56	49	45	55	49	44		54	48	44		53
10	64	52	46	41	63	52	46	41	51	45	41		50	45	41		49

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	295450
5°	296579
10°	297476
15°	297491
20°	295860
25°	288919
30°	270043
35°	233843
40°	182682
45°	131070
50°	85147
55°	50977
60°	29829
65°	19157
70°	12752
75°	9636
80°	7146
85°	0



TEST NUMBER: P573607

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-50 F4X-W-X-H-BL84

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	229.0	6.1
10°-20°	659.9	17.7
20°-30°	973.8	26.1
30°-40°	960.9	25.8
40°-50°	588.1	15.8
50°-60°	225.5	6.0
60°-70°	70.5	1.9
70°-80°	20.7	0.6
80°-90°	2.8	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1862.7	49.9
0°-40°	2823.6	75.7
0°-60°	3637.1	97.5
0°-90°	3731.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3731.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2405	
5°	2405	229
15°	2339	660
25°	2131	974
35°	1559	961
45°	754	588
55°	238	225
65°	66	71
75°	20	21
85°	0	3
90°	0	



TEST NUMBER: P573607

CATALOG NUMBER: FLD4C-45-D010 FEU4C-X-90-50 F4X-W-X-H-BL84

CANDELA DISTRIBUTION (FULL):

0°	
0°	2404.9
2.5°	2409.9
5°	2404.9
7.5°	2399.8
10°	2384.6
12.5°	2364.3
15°	2339.0
17.5°	2308.6
20°	2263.0
22.5°	2212.5
25°	2131.4
27.5°	2030.1
30°	1903.6
32.5°	1746.7
35°	1559.2
37.5°	1351.7
40°	1139.1
42.5°	941.7
45°	754.4
47.5°	587.2
50°	445.5
52.5°	329.2
55°	238.0
57.5°	167.0
60°	121.4
62.5°	91.2
65°	65.9
67.5°	50.7
70°	35.5
72.5°	25.3
75°	20.3
77.5°	10.1
80°	10.1
82.5°	5.1
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)