

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: FAIL-SAFE

Report Number: P573752

Luminaire Tested: **FLD4C-50-D010 FEU4C-X-90-40 F4X-W-X-H-BL85**

Issue Date: 3/1/2023



Test Information

Test Method: LM-79-08
Report Number: P573752
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P206636)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/1/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: FAIL-SAFE
Catalog Number: FLD4C-50-D010 FEU4C-X-90-40 F4X-W-X-H-BL85
Description: 4 INCH FAIL-SAFE LED DOWNLIGHT WITH 4000K, 90 CRI LEDS, 4LBWH TRIM
AND BOTTOM LENS, 0.187" CLEAR POLYCARBONATE

Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3949.0 lumens
Efficiency: N/A
Efficacy: 67.6 lumens/watt
Spacing Criteria (0/90/45): 1.18 / 1.18 / 1.13
Luminous Opening: Circular (Dia: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 58.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P573752

CATALOG NUMBER: FLD4C-50-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

Luminous Intensity Polar Plot





TEST NUMBER: P573752

CATALOG NUMBER: FLD4C-50-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	112	109	106	104		110	107	104	102		103	101	99		99	97	96		96	94	93
2	105	100	95	91		103	98	93	90		95	91	88		91	88	86		89	86	84
3	99	91	85	80		97	90	84	80		87	82	78		84	80	77		82	79	76
4	92	83	77	72		90	82	76	71		80	75	70		78	73	70		76	72	69
5	87	77	70	65		85	76	69	64		74	68	64		72	67	63		70	66	62
6	81	71	64	58		80	70	63	58		68	62	58		67	61	57		65	61	57
7	76	65	58	53		75	65	58	53		63	57	53		62	56	52		61	56	52
8	72	60	53	49		70	60	53	49		59	53	48		58	52	48		57	52	48
9	68	56	49	45		66	56	49	45		55	49	44		54	48	44		53	48	44
10	64	52	46	41		63	52	46	41		51	45	41		50	45	41		49	44	41

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	312711
5°	313906
10°	314853
15°	314865
20°	313144
25°	305809
30°	285817
35°	247506
40°	193347
45°	138732
50°	90116
55°	53954
60°	31573
65°	20262
70°	13470
75°	10205
80°	7570
85°	0



TEST NUMBER: P573752

CATALOG NUMBER: FLD4C-50-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	242.4	6.1
10°-20°	698.4	17.7
20°-30°	1030.7	26.1
30°-40°	1017.1	25.8
40°-50°	622.4	15.8
50°-60°	238.6	6.0
60°-70°	74.6	1.9
70°-80°	21.9	0.6
80°-90°	2.9	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1971.5	49.9
0°-40°	2988.6	75.7
0°-60°	3849.6	97.5
0°-90°	3949.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3949.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2545	
5°	2545	242
15°	2476	698
25°	2256	1031
35°	1650	1017
45°	798	622
55°	252	239
65°	70	75
75°	22	22
85°	0	3
90°	0	



TEST NUMBER: P573752

CATALOG NUMBER: FLD4C-50-D010 FEU4C-X-90-40 F4X-W-X-H-BL85

CANDELA DISTRIBUTION (FULL):

0°	
0°	2545.4
2.5°	2550.7
5°	2545.4
7.5°	2540.0
10°	2523.9
12.5°	2502.5
15°	2475.6
17.5°	2443.5
20°	2395.2
22.5°	2341.8
25°	2256.0
27.5°	2148.7
30°	2014.8
32.5°	1848.8
35°	1650.3
37.5°	1430.7
40°	1205.6
42.5°	996.7
45°	798.5
47.5°	621.5
50°	471.5
52.5°	348.4
55°	251.9
57.5°	176.8
60°	128.5
62.5°	96.5
65°	69.7
67.5°	53.6
70°	37.5
72.5°	26.8
75°	21.5
77.5°	10.7
80°	10.7
82.5°	5.4
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-MV3F9LC





— 0°-180°







(END OF REPORT)