

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO COMMERCIAL

Report Number: P582388

Luminaire Tested: **HC635D010-HM63040935-61WDBB**

Issue Date: 9/16/2021

Test Information

Test Method: LM-41-14
Report Number: P582388
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G2-2105-241-11)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 9/16/2021
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO COMMERCIAL
Catalog Number: HC635D010-HM63040935-61WDBB
Description: HALO COMMERCIAL 6" ROUND, NEW CONSTRUCTION FRAME, WITH 6" WIDE DISTRIBUTION, BLACK BAFFLE TRIM
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3192.8 lumens
Efficiency: N/A
Efficacy: 94.7 lumens/watt
Spacing Criteria (0/90/45): 1.32 / 1.32 / 1.14
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 33.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P582388

CATALOG NUMBER: HC635D010-HM63040935-61WDBB

Luminous Intensity Polar Plot





TEST NUMBER: P582388

CATALOG NUMBER: HC635D010-HM63040935-61WDBB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	107	105	110	108	105	103	104	102	100		100	98	97		97
2	107	101	97	93	104	100	95	92	96	93	90		93	91	88		90
3	100	93	88	83	98	92	87	83	89	85	81		87	83	80		84
4	95	86	80	75	93	85	79	75	83	78	74		81	77	73		79
5	89	80	73	68	87	79	73	68	77	72	67		75	70	67		73
6	84	74	67	62	82	73	67	62	71	66	62		70	65	61		69
7	79	68	62	57	77	68	61	57	66	61	57		65	60	56		64
8	74	64	57	52	73	63	57	52	62	56	52		61	56	52		60
9	70	59	53	48	69	59	53	48	58	52	48		57	52	48		56
10	66	56	49	45	65	55	49	45	54	48	45		53	48	44		53

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	113390
5°	114219
10°	116219
15°	120818
20°	125888
25°	130374
30°	128634
35°	107177
40°	68729
45°	34329
50°	13611
55°	4626
60°	1327
65°	934
70°	769
75°	1017
80°	789
85°	0



TEST NUMBER: P582388

CATALOG NUMBER: HC635D010-HM63040935-61WDBB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	198.5	6.2
10°-20°	603.8	18.9
20°-30°	985.9	30.9
30°-40°	966.5	30.3
40°-50°	370.6	11.6
50°-60°	54.4	1.7
60°-70°	8.0	0.3
70°-80°	4.2	0.1
80°-90°	1.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1788.2	56.0
0°-40°	2754.6	86.3
0°-60°	3179.6	99.6
0°-90°	3192.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3192.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2068	
5°	2076	198
15°	2129	604
25°	2155	986
35°	1602	966
45°	443	371
55°	48	54
65°	7	8
75°	5	4
85°	0	1
90°	0	



TEST NUMBER: P582388

CATALOG NUMBER: HC635D010-HM63040935-61WDBB

CANDELA DISTRIBUTION (FULL):

	0°
0°	2068.4
2.5°	2063.6
5°	2075.6
7.5°	2082.9
10°	2087.8
12.5°	2104.7
15°	2128.8
17.5°	2148.2
20°	2157.9
22.5°	2160.4
25°	2155.4
27.5°	2121.6
30°	2032.1
32.5°	1862.8
35°	1601.5
37.5°	1279.7
40°	960.4
42.5°	684.7
45°	442.8
47.5°	271.0
50°	159.6
52.5°	92.0
55°	48.4
57.5°	21.8
60°	12.1
62.5°	9.7
65°	7.2
67.5°	7.2
70°	4.8
72.5°	4.8
75°	4.8
77.5°	2.5
80°	2.5
82.5°	2.5
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670245859 / DESKTOP-HRDQ47P





— 0°-180°







(END OF REPORT)