

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO

Report Number: P997156

Luminaire Tested: **SMX4SLSF010-650LM-2700K**

Issue Date: 3/11/2025



Test Information

Test Method: LM-41-14
Report Number: P997156
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (A2410943A001)
Test Lab:
Issue Date: 3/11/2025
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO
Catalog Number: SMX4SLSFS010-650LM-2700K
Description: 4IN SQAURE, 90CRI, 0-10V DIMMING, DAMP LOCATION
Light Source: SELECTABLE CCT 90CRI / 2700K CCT
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 612.5 lumens
Efficiency: N/A
Efficacy: 90.1 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.26 / 1.37
Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 6.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	109	104	100	96	106	102	98	94	97	94	91	94	91	89	90	88	86	84		
2	99	91	84	78	96	89	82	77	85	80	75	82	77	73	79	75	72	70		
3	90	79	71	65	88	78	70	64	75	68	63	72	66	62	69	65	61	59		
4	82	70	61	55	80	69	61	54	66	59	54	64	58	53	62	57	52	50		
5	76	63	54	47	74	62	53	47	59	52	46	57	51	46	56	50	45	43		
6	70	56	47	41	68	55	47	41	54	46	40	52	45	40	50	44	40	38		
7	65	51	42	36	63	50	42	36	49	41	36	47	41	35	46	40	35	33		
8	60	47	38	32	59	46	38	32	45	37	32	43	37	32	42	36	31	30		
9	56	43	35	29	55	42	34	29	41	34	29	40	33	29	39	33	28	27		
10	53	39	32	26	51	39	31	26	38	31	26	37	31	26	36	30	26	24		

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	21212	21212	21212	21212
5°	21154	21213	21213	21203
10°	21087	21198	21198	21147
15°	20988	21110	21131	21049
20°	20816	20985	21069	20942
25°	20678	20863	20961	20798
30°	20498	20738	20864	20647
35°	20272	20549	20694	20453
40°	20038	20361	20541	20258
45°	19724	20143	20311	19961
50°	19360	19806	20083	19652
55°	18921	19456	19783	19283
60°	18286	18958	19334	18701
65°	17447	18289	18734	17915
70°	16213	17311	17889	16762
75°	14359	15734	16498	15009
80°	11384	13320	14344	12409
85°	7031	9753	11114	8392



TEST NUMBER: P997156
CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	20.3	3.3
10°-20°	58.1	9.5
20°-30°	88.0	14.4
30°-40°	106.2	17.3
40°-50°	110.5	18.0
50°-60°	100.3	16.4
60°-70°	76.5	12.5
70°-80°	42.7	7.0
80°-90°	9.9	1.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	166.4	27.2
0°-40°	272.7	44.5
0°-60°	483.5	78.9
0°-90°	612.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	612.5	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	215	215	215	215	215	
5°	213	214	214	214	213	20
15°	205	206	206	206	205	58
25°	190	191	192	191	190	87
35°	168	170	172	170	168	105
45°	141	144	145	143	141	109
55°	110	113	115	112	110	98
65°	75	78	80	77	75	74
75°	38	41	43	39	38	40
85°	6	9	10	7	6	8
90°	0	0	0	0	0	

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
0°	214.6	214.6	214.6	214.6	214.6	214.6	214.6	214.6	214.6	214.6	214.6
0.5°	214.4	214.4	214.5	214.4	214.5	214.5	214.8	214.5	214.5	214.6	214.4
1°	214.4	214.4	214.4	214.4	214.5	214.4	214.7	214.6	214.5	214.6	214.5
1.5°	214.2	214.5	214.3	214.3	214.4	214.5	214.7	214.5	214.4	214.5	214.4
2°	214.1	214.4	214.3	214.2	214.4	214.6	214.7	214.5	214.4	214.5	214.3
2.5°	214.0	214.3	214.2	214.2	214.4	214.4	214.6	214.5	214.4	214.5	214.3
3°	213.9	214.2	214.1	214.1	214.3	214.3	214.6	214.4	214.3	214.3	214.2
3.5°	213.9	214.1	213.9	214.0	214.2	214.1	214.5	214.2	214.1	214.3	214.2
4°	213.7	213.9	213.9	213.9	214.2	214.1	214.3	214.1	214.0	214.2	213.9
4.5°	213.5	213.7	213.6	213.6	214.0	213.9	214.3	214.0	214.0	214.1	213.9
5°	213.2	213.5	213.4	213.4	213.8	213.8	214.0	213.8	213.8	214.0	213.8
5.5°	212.9	213.2	213.3	213.4	213.5	213.7	213.8	213.7	213.6	213.8	213.6
6°	212.7	213.0	212.9	213.1	213.3	213.4	213.8	213.4	213.4	213.6	213.3
6.5°	212.4	212.7	212.7	212.8	213.2	213.2	213.4	213.3	213.2	213.5	213.1
7°	212.2	212.4	212.4	212.5	212.9	213.0	213.0	213.2	212.9	213.2	212.8
7.5°	211.8	212.1	212.0	212.2	212.7	212.7	212.8	212.8	212.8	212.8	212.6
8°	211.5	211.8	211.7	211.8	212.3	212.5	212.6	212.6	212.5	212.6	212.4
8.5°	211.2	211.5	211.5	211.5	212.1	212.2	212.3	212.2	212.2	212.2	212.0
9°	210.8	211.1	211.1	211.2	211.7	211.8	212.1	211.9	211.9	211.9	211.6
9.5°	210.5	210.7	210.6	210.9	211.4	211.5	211.7	211.6	211.6	211.7	211.5
10°	210.1	210.2	210.2	210.4	211.2	211.1	211.4	211.3	211.2	211.4	211.0
10.5°	209.6	209.8	209.9	210.1	210.5	210.8	211.0	210.9	210.8	211.0	210.7
11°	209.2	209.4	209.5	209.5	210.0	210.4	210.7	210.5	210.5	210.6	210.1
11.5°	208.8	208.8	209.0	209.1	209.7	210.0	210.2	210.1	210.0	210.2	209.9
12°	208.4	208.5	208.6	208.6	209.3	209.5	209.8	209.6	209.6	209.7	209.3
12.5°	207.9	207.9	208.0	208.2	208.6	208.9	209.1	209.2	209.2	209.3	208.9
13°	207.3	207.5	207.5	207.7	208.2	208.6	208.8	208.7	208.6	208.8	208.4
13.5°	206.6	206.9	207.0	207.2	207.8	208.1	208.4	208.3	208.2	208.3	207.9
14°	206.2	206.4	206.5	206.7	207.2	207.5	207.9	207.7	207.6	207.8	207.3
14.5°	205.7	205.7	205.9	206.1	206.6	207.0	207.4	207.2	207.2	207.3	206.9
15°	205.1	205.3	205.3	205.4	206.3	206.5	206.9	206.7	206.5	206.8	206.3
15.5°	204.3	204.6	204.7	204.9	205.5	205.8	206.3	206.2	205.9	206.2	205.8
16°	203.8	204.0	204.2	204.2	204.9	205.5	205.7	205.7	205.5	205.7	205.1
16.5°	203.1	203.2	203.5	203.7	204.2	204.8	205.1	205.1	204.9	205.1	204.6
17°	202.4	202.6	202.8	203.0	203.6	204.1	204.4	204.4	204.3	204.3	204.0
17.5°	201.5	202.0	202.2	202.4	203.0	203.4	203.8	203.8	203.8	203.8	203.3
18°	200.9	201.4	201.6	201.7	202.4	202.9	203.2	203.0	203.0	203.0	202.6
18.5°	200.1	200.6	200.8	201.1	201.6	202.2	202.5	202.5	202.4	202.4	202.0
19°	199.5	199.9	200.0	200.3	200.9	201.5	201.8	201.8	201.6	201.7	201.2
19.5°	198.5	199.1	199.3	199.7	200.3	200.8	201.0	201.0	200.9	201.0	200.6
20°	197.9	198.4	198.6	198.9	199.5	200.2	200.2	200.2	200.3	200.2	199.8
20.5°	197.0	197.5	197.8	198.2	198.7	199.3	199.6	199.6	199.7	199.5	199.1
21°	196.3	196.8	197.0	197.3	197.9	198.6	198.7	198.8	198.8	198.7	198.4

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
22.5°	194.1	194.3	194.5	194.9	195.7	196.2	196.6	196.5	196.4	196.6	196.1
23°	193.1	193.5	193.7	193.9	194.8	195.5	195.7	195.8	195.6	195.8	195.2
23.5°	192.2	192.6	192.8	193.1	193.9	194.5	194.9	194.8	194.7	194.9	194.3
24°	191.4	191.7	192.1	192.3	193.0	193.6	194.0	194.0	194.0	194.1	193.4
24.5°	190.5	190.7	191.1	191.4	192.2	192.8	193.2	193.2	193.1	193.1	192.6
25°	189.6	189.9	190.1	190.4	191.3	192.0	192.3	192.2	192.2	192.3	191.7
25.5°	188.5	188.9	189.3	189.7	190.4	191.0	191.4	191.4	191.3	191.4	190.9
26°	187.5	188.1	188.5	188.7	189.5	190.1	190.3	190.6	190.4	190.3	189.9
26.5°	186.7	187.1	187.5	187.8	188.6	189.2	189.5	189.7	189.5	189.5	189.1
27°	185.8	186.1	186.3	186.6	187.6	188.3	188.6	188.7	188.6	188.6	188.1
27.5°	184.6	185.0	185.2	185.8	186.6	187.2	187.6	187.8	187.7	187.6	187.1
28°	183.7	184.1	184.4	184.8	185.7	186.3	186.7	186.7	186.7	186.7	186.1
28.5°	182.8	183.0	183.4	183.8	184.7	185.2	185.7	185.8	185.8	185.7	185.2
29°	181.7	182.1	182.3	182.6	183.8	184.3	184.7	184.7	184.7	184.7	184.1
29.5°	180.6	181.1	181.2	181.7	182.7	183.2	183.7	183.7	183.8	183.7	183.2
30°	179.6	179.9	180.2	180.6	181.7	182.2	182.6	182.7	182.8	182.7	181.9
30.5°	178.4	178.8	179.1	179.6	180.6	181.1	181.5	181.7	181.7	181.5	180.9
31°	177.4	177.7	178.0	178.4	179.5	180.2	180.5	180.6	180.5	180.4	179.9
31.5°	176.2	176.7	176.8	177.3	178.3	179.0	179.3	179.5	179.5	179.3	178.9
32°	175.0	175.5	175.8	176.2	177.2	177.9	178.2	178.3	178.4	178.3	177.7
32.5°	173.8	174.3	174.6	175.1	176.2	176.8	177.2	177.2	177.3	177.1	176.6
33°	172.8	173.1	173.5	174.0	175.0	175.7	176.1	176.1	176.2	176.0	175.4
33.5°	171.6	172.0	172.3	172.8	173.8	174.3	175.0	174.9	175.0	174.8	174.2
34°	170.5	170.8	171.1	171.6	172.7	173.2	173.7	173.8	173.9	173.7	173.0
34.5°	169.3	169.6	169.9	170.4	171.5	172.1	172.5	172.7	172.7	172.5	172.0
35°	168.0	168.4	168.7	169.1	170.3	170.9	171.4	171.4	171.5	171.4	170.6
35.5°	166.8	167.2	167.5	168.1	169.0	169.8	170.2	170.2	170.3	170.1	169.5
36°	165.6	165.9	166.3	166.8	167.7	168.6	169.0	169.1	169.1	168.9	168.3
36.5°	164.4	164.7	165.1	165.6	166.6	167.3	167.8	167.9	168.0	167.8	167.1
37°	163.2	163.5	163.9	164.4	165.4	166.1	166.6	166.8	166.7	166.5	165.8
37.5°	161.9	162.2	162.7	163.2	164.2	165.0	165.2	165.6	165.5	165.3	164.8
38°	160.6	161.0	161.3	161.8	162.9	163.8	164.1	164.4	164.2	164.1	163.4
38.5°	159.3	159.6	160.1	160.6	161.7	162.4	162.9	163.0	163.1	162.8	162.2
39°	157.9	158.3	158.7	159.3	160.4	161.2	161.6	161.8	161.9	161.4	160.8
39.5°	156.6	156.8	157.3	158.0	159.2	159.8	160.3	160.4	160.6	160.2	159.6
40°	155.3	155.7	156.0	156.5	157.8	158.5	158.9	159.2	159.2	158.9	158.2
40.5°	153.8	154.2	154.7	155.3	156.5	157.2	157.5	157.9	157.9	157.6	156.9
41°	152.5	153.0	153.3	153.9	155.2	155.8	156.2	156.5	156.5	156.3	155.4
41.5°	151.2	151.6	152.0	152.6	153.8	154.5	154.8	155.2	155.1	154.9	154.1
42°	149.8	150.2	150.5	151.2	152.5	153.1	153.6	153.8	153.8	153.5	152.8
42.5°	148.3	148.8	149.2	149.9	151.0	151.6	152.3	152.4	152.4	152.2	151.4
43°	146.9	147.5	147.8	148.5	149.7	150.4	150.8	151.0	151.1	150.8	150.0
43.5°	145.6	146.0	146.3	147.0	148.3	148.9	149.4	149.7	149.7	149.4	148.7

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
45°	141.1	141.7	142.0	142.7	144.1	144.8	145.2	145.4	145.3	145.2	144.4
45.5°	139.6	140.2	140.6	141.3	142.7	143.2	143.8	144.0	143.9	143.8	143.1
46°	138.3	138.8	139.2	139.8	141.1	141.8	142.3	142.5	142.4	142.2	141.5
46.5°	136.8	137.3	137.7	138.3	139.7	140.3	140.7	141.1	141.1	140.8	140.1
47°	135.3	135.8	136.1	136.8	138.1	138.9	139.4	139.7	139.6	139.5	138.7
47.5°	133.8	134.2	134.6	135.4	136.6	137.4	137.8	138.2	138.2	137.9	137.2
48°	132.2	132.7	133.2	133.8	135.0	135.9	136.3	136.7	136.8	136.4	135.6
48.5°	130.7	131.2	131.6	132.2	133.4	134.4	134.9	135.1	135.2	134.9	134.2
49°	129.0	129.7	130.0	130.6	131.9	132.8	133.4	133.6	133.6	133.4	132.6
49.5°	127.6	128.1	128.5	129.2	130.4	131.3	131.9	132.1	132.1	131.9	131.1
50°	125.9	126.4	127.0	127.7	128.8	129.9	130.3	130.6	130.6	130.4	129.5
50.5°	124.3	124.9	125.3	126.1	127.3	128.2	128.7	129.0	129.0	128.8	128.0
51°	122.7	123.3	123.7	124.5	125.8	126.7	127.1	127.5	127.5	127.3	126.4
51.5°	121.2	121.6	122.2	122.8	124.3	125.0	125.6	125.8	125.8	125.7	124.8
52°	119.6	120.1	120.6	121.3	122.6	123.4	124.0	124.3	124.4	124.1	123.2
52.5°	118.0	118.4	119.0	119.7	120.9	121.9	122.5	122.6	122.8	122.4	121.6
53°	116.4	116.9	117.3	118.2	119.3	120.3	120.9	121.1	121.2	120.8	120.1
53.5°	114.9	115.3	115.8	116.3	117.8	118.7	119.1	119.4	119.6	119.2	118.5
54°	113.2	113.7	114.1	114.7	116.1	117.1	117.6	117.7	117.8	117.6	116.8
54.5°	111.5	111.9	112.5	113.2	114.7	115.5	116.0	116.1	116.3	116.0	115.3
55°	109.8	110.3	110.8	111.6	112.9	113.9	114.4	114.6	114.8	114.5	113.8
55.5°	108.1	108.5	109.2	110.0	111.4	112.3	112.8	113.0	113.1	112.8	112.1
56°	106.5	106.9	107.5	108.2	109.7	110.5	111.1	111.3	111.4	111.2	110.4
56.5°	104.8	105.2	105.7	106.5	107.9	108.9	109.4	109.8	109.8	109.5	108.7
57°	103.2	103.5	104.0	104.8	106.3	107.1	107.8	108.0	108.0	107.7	106.9
57.5°	101.3	101.8	102.3	103.2	104.7	105.4	106.1	106.3	106.4	106.1	105.2
58°	99.6	100.0	100.6	101.4	102.9	103.8	104.4	104.7	104.7	104.3	103.6
58.5°	97.8	98.3	98.8	99.7	101.2	102.2	102.7	103.1	103.0	102.7	102.0
59°	96.1	96.6	97.1	97.9	99.5	100.3	100.9	101.4	101.1	100.9	100.2
59.5°	94.2	94.8	95.4	96.3	97.6	98.5	99.2	99.6	99.5	99.2	98.4
60°	92.5	93.1	93.7	94.6	95.9	96.8	97.5	97.9	97.8	97.4	96.7
60.5°	90.9	91.2	91.9	92.8	94.1	95.1	95.7	96.4	96.1	95.7	95.0
61°	89.2	89.6	90.2	91.0	92.4	93.4	93.9	94.5	94.3	94.0	93.2
61.5°	87.3	87.8	88.4	89.2	90.6	91.6	92.2	92.8	92.6	92.2	91.4
62°	85.6	86.1	86.6	87.5	89.0	89.9	90.5	90.9	90.8	90.5	89.8
62.5°	83.7	84.1	84.8	85.6	87.2	88.2	88.8	89.3	89.1	88.7	88.0
63°	81.8	82.3	82.9	83.8	85.5	86.4	87.0	87.4	87.3	86.9	86.1
63.5°	80.0	80.5	81.2	82.0	83.6	84.5	85.2	85.7	85.6	85.1	84.4
64°	78.3	78.7	79.4	80.1	81.8	82.7	83.3	83.9	83.7	83.3	82.5
64.5°	76.4	76.9	77.5	78.4	80.1	80.9	81.5	82.0	81.9	81.5	80.8
65°	74.6	75.1	75.7	76.5	78.2	79.1	79.8	80.1	80.1	79.7	79.0
65.5°	72.7	73.2	73.9	74.7	76.4	77.4	77.9	78.4	78.3	77.9	77.2
66°	70.8	71.3	72.0	72.8	74.8	75.5	76.1	76.6	76.4	76.2	75.3

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
67.5°	65.3	66.0	66.4	67.3	69.1	70.1	70.6	71.1	71.1	70.5	69.7
68°	63.5	64.1	64.7	65.6	67.2	68.2	68.8	69.2	69.3	68.8	67.9
68.5°	61.6	62.2	62.9	63.7	65.5	66.3	67.0	67.3	67.4	66.9	66.1
69°	59.8	60.4	61.0	61.9	63.7	64.6	65.2	65.5	65.6	65.2	64.3
69.5°	57.9	58.4	59.1	60.0	61.8	62.6	63.3	63.7	63.7	63.3	62.5
70°	56.1	56.6	57.2	58.1	59.9	60.8	61.4	61.8	61.9	61.5	60.6
70.5°	54.1	54.7	55.4	56.2	58.0	59.0	59.6	60.0	60.0	59.6	58.7
71°	52.3	52.9	53.5	54.3	56.1	57.1	57.7	58.2	58.2	57.7	56.9
71.5°	50.5	51.0	51.5	52.4	54.2	55.2	55.8	56.2	56.3	55.9	55.0
72°	48.6	49.2	49.7	50.6	52.4	53.4	53.9	54.3	54.4	54.0	53.2
72.5°	46.8	47.2	47.8	48.7	50.5	51.6	52.1	52.4	52.4	52.1	51.2
73°	44.8	45.4	46.0	46.8	48.6	49.6	50.2	50.6	50.6	50.2	49.4
73.5°	43.0	43.6	44.1	44.9	46.8	47.8	48.3	48.7	48.8	48.4	47.5
74°	41.1	41.7	42.3	43.1	44.9	45.9	46.4	46.8	47.0	46.5	45.7
74.5°	39.4	39.9	40.6	41.3	43.1	44.1	44.6	45.0	45.0	44.6	43.8
75°	37.6	38.0	38.6	39.4	41.2	42.2	42.7	43.1	43.2	42.7	42.0
75.5°	35.7	36.2	36.8	37.6	39.4	40.5	40.9	41.2	41.3	41.0	40.2
76°	34.0	34.4	34.9	35.7	37.6	38.6	39.1	39.4	39.6	39.2	38.3
76.5°	32.1	32.5	33.1	33.8	35.8	36.8	37.2	37.6	37.6	37.4	36.5
77°	30.3	30.8	31.4	32.1	34.0	34.9	35.4	35.8	35.8	35.5	34.7
77.5°	28.7	29.0	29.6	30.3	32.2	33.1	33.6	34.0	34.0	33.7	32.9
78°	26.8	27.2	27.8	28.6	30.4	31.3	31.9	32.2	32.2	31.9	31.1
78.5°	25.1	25.5	26.2	26.8	28.6	29.5	30.1	30.4	30.5	30.2	29.4
79°	23.4	23.8	24.4	25.2	26.9	27.8	28.3	28.6	28.6	28.4	27.6
79.5°	21.7	22.1	22.7	23.4	25.2	26.1	26.5	26.9	26.9	26.6	25.8
80°	20.0	20.4	20.9	21.7	23.4	24.3	24.8	25.2	25.2	24.8	24.1
80.5°	18.5	18.8	19.4	20.0	21.8	22.6	23.1	23.4	23.5	23.2	22.5
81°	16.9	17.2	17.8	18.5	20.1	21.0	21.5	21.7	21.9	21.6	20.8
81.5°	15.5	15.8	16.4	16.9	18.5	19.3	19.8	20.1	20.1	19.9	19.2
82°	14.0	14.3	14.9	15.5	17.0	17.7	18.1	18.5	18.5	18.2	17.5
82.5°	12.5	12.8	13.4	14.1	15.6	16.2	16.6	16.9	16.9	16.7	16.0
83°	11.1	11.5	12.0	12.6	14.1	14.8	15.2	15.5	15.5	15.2	14.7
83.5°	9.8	10.1	10.6	11.2	12.6	13.4	13.8	14.0	14.0	13.8	13.2
84°	8.5	8.8	9.4	9.9	11.2	11.9	12.2	12.5	12.6	12.4	11.7
84.5°	7.3	7.5	8.1	8.6	9.8	10.5	10.9	11.1	11.2	11.0	10.4
85°	6.2	6.4	6.9	7.4	8.6	9.2	9.6	9.7	9.8	9.6	9.1
85.5°	5.1	5.4	5.9	6.3	7.3	7.9	8.2	8.5	8.5	8.3	7.8
86°	4.1	4.5	4.9	5.2	6.3	6.7	7.0	7.3	7.3	7.1	6.6
86.5°	3.2	3.5	4.0	4.3	5.1	5.6	5.9	6.0	6.1	5.9	5.6
87°	2.5	2.7	3.1	3.4	4.1	4.5	4.8	5.0	5.0	4.9	4.5
87.5°	1.8	2.1	2.4	2.6	3.3	3.6	3.8	4.0	4.0	3.9	3.5
88°	1.3	1.5	1.8	2.0	2.4	2.8	3.0	3.2	3.2	3.0	2.7
88.5°	0.9	1.0	1.2	1.4	1.6	1.9	2.1	2.2	2.3	2.2	1.9

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



TEST NUMBER: P997156
CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
0°	214.6	214.6	214.6	214.6	214.6	214.6
0.5°	214.5	214.7	214.5	214.5	214.5	214.4
1°	214.4	214.5	214.4	214.6	214.4	214.4
1.5°	214.2	214.5	214.4	214.5	214.3	214.2
2°	214.3	214.5	214.3	214.5	214.2	214.1
2.5°	214.2	214.4	214.3	214.4	214.1	214.0
3°	214.2	214.4	214.3	214.2	214.1	213.9
3.5°	214.2	214.3	214.1	214.1	213.8	213.9
4°	214.0	213.9	213.9	213.9	213.6	213.7
4.5°	213.8	213.9	213.7	213.5	213.3	213.5
5°	213.7	213.7	213.6	213.5	213.0	213.2
5.5°	213.5	213.3	213.2	213.2	212.9	212.9
6°	213.2	213.0	212.9	213.0	212.8	212.7
6.5°	212.9	212.8	212.7	212.8	212.5	212.4
7°	212.7	212.6	212.4	212.5	212.3	212.2
7.5°	212.3	212.4	212.1	212.1	211.9	211.8
8°	212.0	212.1	211.8	211.8	211.6	211.5
8.5°	211.7	211.8	211.4	211.5	211.2	211.2
9°	211.4	211.4	211.1	211.0	210.8	210.8
9.5°	211.1	211.0	210.7	210.7	210.5	210.5
10°	210.8	210.7	210.3	210.3	209.9	210.1
10.5°	210.4	210.4	209.9	209.9	209.4	209.6
11°	210.0	209.9	209.5	209.4	209.0	209.2
11.5°	209.7	209.5	209.0	209.0	208.5	208.8
12°	209.2	209.1	208.6	208.5	208.1	208.4
12.5°	208.6	208.6	208.2	207.9	207.6	207.9
13°	208.2	208.1	207.6	207.5	207.2	207.3
13.5°	207.7	207.5	207.0	207.0	206.7	206.6
14°	207.1	207.0	206.6	206.3	206.1	206.2
14.5°	206.6	206.5	206.0	205.8	205.7	205.7
15°	206.0	205.7	205.3	205.4	205.1	205.1
15.5°	205.4	205.2	204.8	204.6	204.3	204.3
16°	204.9	204.6	204.0	204.0	203.7	203.8
16.5°	204.3	204.0	203.5	203.3	203.0	203.1
17°	203.6	203.3	202.9	202.7	202.4	202.4
17.5°	203.0	202.6	202.1	202.1	201.6	201.5
18°	202.4	202.0	201.4	201.4	201.1	200.9
18.5°	201.8	201.3	200.8	200.7	200.3	200.1
19°	201.0	200.7	200.1	199.9	199.5	199.5
19.5°	200.2	199.8	199.3	199.2	198.8	198.5
20°	199.5	199.1	198.6	198.3	198.1	197.9
20.5°	198.7	198.3	197.9	197.4	197.3	197.0
21°	197.9	197.5	197.1	196.8	196.6	196.3

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
22.5°	195.6	195.0	194.7	194.3	193.9	194.1
23°	194.8	194.2	193.8	193.5	193.1	193.1
23.5°	193.9	193.4	193.0	192.4	192.1	192.2
24°	193.1	192.4	192.1	191.7	191.3	191.4
24.5°	192.1	191.5	191.2	190.7	190.5	190.5
25°	191.2	190.7	190.1	189.9	189.7	189.6
25.5°	190.4	189.8	189.3	189.0	188.7	188.5
26°	189.5	188.9	188.4	188.1	187.7	187.5
26.5°	188.5	188.0	187.4	187.1	186.7	186.7
27°	187.5	187.1	186.3	186.2	185.8	185.8
27.5°	186.6	186.0	185.5	185.2	184.7	184.6
28°	185.6	185.0	184.4	184.2	183.6	183.7
28.5°	184.6	183.9	183.4	183.0	182.6	182.8
29°	183.6	182.9	182.3	182.1	181.5	181.7
29.5°	182.5	181.9	181.3	181.0	180.4	180.6
30°	181.4	180.9	180.4	180.0	179.4	179.6
30.5°	180.3	179.8	179.3	178.9	178.3	178.4
31°	179.3	178.7	178.1	177.6	177.2	177.4
31.5°	178.2	177.6	177.1	176.6	176.0	176.2
32°	177.1	176.4	175.8	175.5	175.0	175.0
32.5°	176.1	175.3	174.7	174.2	173.8	173.8
33°	174.9	174.2	173.8	173.2	172.7	172.8
33.5°	173.8	173.0	172.5	171.9	171.6	171.6
34°	172.5	171.9	171.3	170.9	170.4	170.5
34.5°	171.4	170.6	170.1	169.6	169.0	169.3
35°	170.2	169.5	168.8	168.3	167.9	168.0
35.5°	169.1	168.2	167.7	167.1	166.6	166.8
36°	167.8	167.0	166.3	165.9	165.5	165.6
36.5°	166.5	165.7	165.1	164.6	164.3	164.4
37°	165.3	164.6	164.0	163.5	162.9	163.2
37.5°	164.1	163.3	162.8	162.2	161.7	161.9
38°	162.9	162.1	161.4	160.9	160.4	160.6
38.5°	161.6	160.8	160.2	159.6	159.1	159.3
39°	160.2	159.4	158.7	158.2	157.9	157.9
39.5°	159.0	158.2	157.4	156.8	156.6	156.6
40°	157.6	157.0	156.0	155.7	155.2	155.3
40.5°	156.3	155.6	154.6	154.2	153.7	153.8
41°	154.8	154.2	153.3	153.0	152.5	152.5
41.5°	153.6	152.8	152.0	151.5	151.1	151.2
42°	152.3	151.5	150.6	150.0	149.6	149.8
42.5°	150.9	150.0	149.2	148.8	148.2	148.3
43°	149.4	148.7	147.8	147.2	146.8	146.9
43.5°	148.0	147.2	146.3	145.7	145.4	145.6

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
45°	143.8	142.8	141.9	141.6	141.0	141.1
45.5°	142.3	141.3	140.6	140.1	139.6	139.6
46°	140.8	139.9	139.2	138.6	138.2	138.3
46.5°	139.4	138.4	137.6	137.2	136.7	136.8
47°	137.9	137.0	136.1	135.6	135.2	135.3
47.5°	136.4	135.6	134.7	134.1	133.7	133.8
48°	134.9	134.0	133.2	132.5	132.2	132.2
48.5°	133.4	132.5	131.6	131.0	130.6	130.7
49°	131.9	130.9	130.1	129.4	129.1	129.0
49.5°	130.3	129.4	128.6	127.9	127.6	127.6
50°	128.8	127.8	126.9	126.3	125.9	125.9
50.5°	127.3	126.3	125.4	124.7	124.4	124.3
51°	125.6	124.6	123.7	123.1	122.8	122.7
51.5°	124.1	123.2	122.2	121.7	121.2	121.2
52°	122.5	121.7	120.5	119.9	119.6	119.6
52.5°	120.9	120.0	118.9	118.5	117.9	118.0
53°	119.3	118.4	117.2	116.8	116.3	116.4
53.5°	117.7	116.6	115.6	115.2	114.8	114.9
54°	116.1	115.1	114.0	113.6	113.1	113.2
54.5°	114.5	113.5	112.5	111.9	111.5	111.5
55°	113.0	111.9	110.8	110.2	109.8	109.8
55.5°	111.2	110.0	109.1	108.6	108.2	108.1
56°	109.7	108.4	107.5	106.8	106.4	106.5
56.5°	107.9	106.7	105.8	105.2	104.9	104.8
57°	106.3	105.0	104.0	103.4	103.1	103.2
57.5°	104.6	103.3	102.3	101.7	101.4	101.3
58°	103.0	101.6	100.6	100.0	99.7	99.6
58.5°	101.2	99.8	98.8	98.3	97.9	97.8
59°	99.6	98.1	97.1	96.6	96.2	96.1
59.5°	97.7	96.3	95.2	94.7	94.3	94.2
60°	96.0	94.6	93.5	93.1	92.6	92.5
60.5°	94.3	92.7	91.8	91.2	90.8	90.9
61°	92.6	91.1	90.1	89.5	89.2	89.2
61.5°	90.9	89.2	88.3	87.8	87.4	87.3
62°	89.1	87.4	86.5	86.0	85.5	85.6
62.5°	87.4	85.5	84.6	84.1	83.7	83.7
63°	85.6	83.9	82.8	82.4	81.9	81.8
63.5°	83.8	81.9	81.0	80.4	80.1	80.0
64°	82.0	80.2	79.2	78.7	78.2	78.3
64.5°	80.1	78.3	77.4	76.9	76.4	76.4
65°	78.3	76.6	75.6	75.1	74.6	74.6
65.5°	76.4	74.6	73.7	73.1	72.7	72.7
66°	74.6	72.9	71.9	71.2	71.0	70.8

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997156

CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
67.5°	69.0	67.3	66.3	65.8	65.5	65.3
68°	67.1	65.5	64.5	63.9	63.6	63.5
68.5°	65.4	63.6	62.7	62.0	61.7	61.6
69°	63.5	61.8	60.8	60.2	60.0	59.8
69.5°	61.7	59.8	59.0	58.4	58.0	57.9
70°	59.8	58.0	57.1	56.5	56.2	56.1
70.5°	58.0	56.2	55.3	54.6	54.2	54.1
71°	56.2	54.4	53.4	52.8	52.4	52.3
71.5°	54.2	52.4	51.5	50.9	50.4	50.5
72°	52.3	50.6	49.6	49.0	48.6	48.6
72.5°	50.5	48.7	47.8	47.1	46.7	46.8
73°	48.6	46.8	45.9	45.3	44.8	44.8
73.5°	46.7	44.9	44.1	43.4	42.9	43.0
74°	44.8	43.2	42.2	41.6	41.2	41.1
74.5°	43.0	41.3	40.4	39.9	39.2	39.4
75°	41.2	39.3	38.6	37.9	37.6	37.6
75.5°	39.4	37.6	36.7	36.0	35.6	35.7
76°	37.6	35.8	34.9	34.2	33.9	34.0
76.5°	35.8	33.9	33.0	32.4	32.1	32.1
77°	34.0	32.2	31.3	30.6	30.2	30.3
77.5°	32.2	30.4	29.5	28.9	28.5	28.7
78°	30.3	28.7	27.7	27.1	26.7	26.8
78.5°	28.5	26.9	26.0	25.5	25.0	25.1
79°	26.8	25.2	24.2	23.6	23.3	23.4
79.5°	25.2	23.5	22.6	22.0	21.7	21.7
80°	23.5	21.8	20.9	20.4	20.0	20.0
80.5°	21.7	20.1	19.4	18.8	18.4	18.5
81°	20.1	18.5	17.7	17.1	16.8	16.9
81.5°	18.6	17.0	16.3	15.8	15.5	15.5
82°	17.0	15.6	14.8	14.2	13.9	14.0
82.5°	15.5	14.1	13.3	12.8	12.5	12.5
83°	14.1	12.7	11.8	11.4	11.1	11.1
83.5°	12.6	11.2	10.5	10.1	9.8	9.8
84°	11.2	9.9	9.3	8.8	8.5	8.5
84.5°	9.8	8.6	8.0	7.6	7.3	7.3
85°	8.6	7.4	6.9	6.4	6.2	6.2
85.5°	7.4	6.3	5.6	5.4	5.1	5.1
86°	6.2	5.2	4.7	4.4	4.1	4.1
86.5°	5.1	4.2	3.9	3.5	3.3	3.2
87°	4.1	3.4	2.9	2.7	2.5	2.5
87.5°	3.2	2.6	2.2	2.0	1.9	1.8
88°	2.4	1.9	1.6	1.4	1.3	1.3
88.5°	1.6	1.4	1.1	0.9	0.9	0.9

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



TEST NUMBER: P997156
CATALOG NUMBER: SMX4SLSFS010-650LM-2700K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
90°	0.0	0.0	0.0	0.0	0.0	0.0

Classified

Scaled Data Report

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - - 90°-270° - · - 135°-315°

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report





21.5°	195.4	196.0	196.2	196.4	197.3	197.8	198.0	198.2	198.0	197.9	197.6
22°	195.0	195.2	195.3	195.7	196.5	197.2	197.1	197.4	197.2	197.3	196.8



44°	144.1	144.6	144.9	145.5	146.8	147.6	148.0	148.3	148.2	148.0	147.2
44.5°	142.6	143.2	143.5	144.1	145.5	146.2	146.5	146.9	146.8	146.6	145.9

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



66.5°	69.0	69.5	70.1	71.0	72.7	73.6	74.3	74.8	74.7	74.2	73.5
67°	67.0	67.7	68.3	69.1	70.9	71.9	72.4	72.9	72.8	72.3	71.7



89°	0.5	0.6	0.8	0.9	1.1	1.3	1.4	1.6	1.6	1.5	1.3
89.5°	0.2	0.3	0.5	0.6	0.5	0.7	0.9	1.1	1.0	1.0	0.7

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



21.5°	197.1	196.6	196.2	196.2	195.6	195.4
22°	196.4	195.9	195.4	195.2	194.6	195.0

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



44°	146.6	145.7	144.9	144.3	144.1	144.1
44.5°	145.2	144.3	143.4	143.0	142.5	142.6

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



66.5°	72.8	70.9	70.0	69.3	69.1	69.0
67°	71.0	69.1	68.3	67.6	67.3	67.0

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



89°	1.1	0.9	0.7	0.6	0.5	0.5
89.5°	0.5	0.6	0.4	0.3	0.2	0.2

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)