

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO

Report Number: P997179

Luminaire Tested: **SMX4SLSFSD2W-800LM-4000K**

Issue Date: 3/11/2025



Test Information

Test Method: LM-41-14
Report Number: P997179
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (A2410456A001)
Test Lab:
Issue Date: 3/11/2025
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO
Catalog Number: SMX4SLSFSD2W-800LM-4000K
Description: 4IN SQAURE, 90CRI, DIMMING TO 10%, DAMP LOCATION
Light Source: SELECTABLE CCT 90CRI / 4000K CCT
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 854.8 lumens
Efficiency: N/A
Efficacy: 97.1 lumens/watt
Spacing Criteria (0/90/45): 1.25 / 1.25 / 1.37
Luminous Opening: Rectangular (W 0.33' x L: 0.33' x H: 0')
CIE Type: Direct

Input Watts (W): 8.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	109	104	100	96	106	102	98	95	98	95	92	94	91	89	90	88	86	84		
2	99	91	84	78	96	89	83	77	85	80	76	82	78	74	79	76	72	70		
3	90	80	72	65	88	78	71	65	75	69	63	72	67	62	70	65	61	59		
4	83	71	62	55	80	69	61	55	67	60	54	64	58	53	62	57	53	50		
5	76	63	54	48	74	62	54	47	60	52	47	58	51	46	56	50	46	44		
6	70	57	48	41	68	56	47	41	54	47	41	52	46	41	51	45	40	38		
7	65	52	43	37	63	51	42	36	49	42	36	48	41	36	46	40	36	34		
8	61	47	38	33	59	46	38	33	45	38	32	44	37	32	43	36	32	30		
9	57	43	35	29	55	43	35	29	41	34	29	40	34	29	39	33	29	27		
10	53	40	32	27	52	39	32	27	38	31	26	37	31	26	36	30	26	24		

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	30206	30206	30206	30206
5°	30232	30173	30202	30163
10°	30160	30070	30100	30070
15°	30034	29941	29952	29931
20°	29873	29768	29747	29757
25°	29653	29512	29490	29534
30°	29378	29241	29195	29241
35°	29056	28911	28851	28911
40°	28696	28541	28451	28515
45°	28278	28097	28013	28083
50°	27756	27556	27464	27540
55°	27090	26900	26797	26866
60°	26233	26035	25936	25976
65°	25025	24838	24721	24768
70°	23293	23120	22975	23004
75°	20661	20546	20393	20355
80°	16621	16564	16393	16279
85°	10547	10434	10660	10093

Classified

Scaled Data Report

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	28.9	3.4
10°-20°	82.6	9.7
20°-30°	124.8	14.6
30°-40°	150.0	17.5
40°-50°	155.1	18.1
50°-60°	139.5	16.3
60°-70°	104.9	12.3
70°-80°	56.8	6.6
80°-90°	12.0	1.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	236.4	27.7
0°-40°	386.4	45.2
0°-60°	681.0	79.7
0°-90°	854.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	854.8	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	306	306	306	306	306	
5°	305	304	304	304	305	29
15°	294	293	293	292	294	83
25°	272	271	270	271	272	125
35°	241	240	239	240	241	151
45°	202	201	200	201	202	156
55°	157	156	156	156	157	140
65°	107	106	106	106	107	106
75°	54	54	53	53	54	57
85°	9	9	9	9	9	12
90°	0	0	0	0	0	

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
0°	305.6	305.6	305.6	305.6	305.6	305.6	305.6	305.6	305.6	305.6	305.6
0.5°	306.2	305.9	305.7	305.5	305.3	305.4	305.7	305.7	305.9	305.9	305.8
1°	305.9	306.0	305.5	305.6	305.4	305.3	305.5	305.8	305.8	305.9	305.5
1.5°	306.0	305.7	305.7	305.4	305.2	305.2	305.6	305.5	306.0	305.6	305.5
2°	305.8	305.9	305.4	305.4	304.9	305.3	305.3	305.4	305.6	305.7	305.4
2.5°	305.7	305.5	305.3	304.8	305.0	305.0	305.2	305.2	305.7	305.6	305.0
3°	305.7	305.5	305.2	305.2	304.8	305.0	305.0	305.1	305.3	305.5	305.0
3.5°	305.7	305.5	304.9	304.8	304.6	304.6	304.9	305.0	305.3	305.2	304.9
4°	305.1	305.2	304.8	304.5	304.5	304.4	304.5	304.6	304.8	304.9	304.6
4.5°	304.9	304.9	304.6	304.3	304.0	304.2	304.5	304.4	304.8	304.7	304.4
5°	304.7	304.6	304.3	304.0	304.1	304.1	303.9	304.2	304.4	304.4	304.1
5.5°	304.6	304.4	304.0	303.8	303.5	303.5	304.0	303.6	304.0	304.1	303.7
6°	304.2	304.2	303.7	303.6	303.2	303.4	303.3	303.5	303.7	303.9	303.6
6.5°	303.9	303.6	303.2	303.0	302.8	302.8	303.2	303.0	303.5	303.4	303.1
7°	303.3	303.3	302.9	302.6	302.7	302.6	302.5	302.8	302.9	303.1	302.8
7.5°	303.2	302.9	302.4	302.1	302.2	302.0	302.3	302.2	302.6	302.5	302.4
8°	302.5	302.5	302.2	301.8	301.6	301.8	301.9	301.8	302.0	302.3	301.9
8.5°	302.3	301.9	301.4	301.1	301.3	300.9	301.1	301.2	301.6	301.5	301.5
9°	301.5	301.4	301.1	301.0	300.6	300.8	300.7	300.8	301.0	301.4	300.8
9.5°	301.2	301.0	300.5	300.1	300.3	300.1	300.4	300.1	300.6	300.5	300.4
10°	300.5	300.5	300.0	299.7	299.6	299.5	299.4	299.6	299.9	300.0	299.8
10.5°	300.1	299.7	299.4	298.9	299.0	298.9	299.3	298.8	299.4	299.5	299.4
11°	299.4	299.3	298.8	298.6	298.4	298.5	298.0	298.5	298.6	298.7	298.4
11.5°	299.0	298.6	298.1	297.9	297.8	297.6	297.8	297.7	298.2	298.2	298.1
12°	298.1	297.9	297.3	297.1	297.1	297.1	297.0	297.0	297.3	297.3	297.1
12.5°	297.3	297.3	296.9	296.5	296.3	296.3	296.3	296.3	296.7	296.7	296.6
13°	296.8	296.4	296.2	295.7	295.8	295.6	295.6	295.5	295.8	295.9	295.9
13.5°	296.1	295.7	295.3	294.8	295.0	294.7	295.0	294.8	295.2	295.4	295.2
14°	295.1	295.0	294.5	294.3	294.3	294.2	293.9	294.0	294.3	294.5	294.3
14.5°	294.7	294.1	293.9	293.2	293.4	293.2	293.5	293.2	293.5	293.6	293.4
15°	293.5	293.5	293.0	292.6	292.6	292.5	292.3	292.4	292.7	292.9	292.9
15.5°	292.7	292.4	292.0	291.5	291.5	291.5	291.7	291.6	291.7	291.8	291.9
16°	292.0	291.9	291.3	290.9	291.0	290.8	290.5	290.6	290.8	291.2	291.0
16.5°	291.1	290.7	290.2	289.8	289.7	289.7	289.8	289.7	290.1	290.2	290.1
17°	290.1	289.9	289.4	289.0	289.1	288.9	289.0	288.8	289.0	289.1	289.1
17.5°	289.2	289.0	288.4	287.8	288.0	287.8	287.9	287.6	288.1	288.2	288.2
18°	288.0	288.0	287.5	287.1	287.1	286.8	286.9	286.9	287.0	287.2	287.2
18.5°	287.3	286.8	286.3	285.8	286.0	285.9	286.0	285.6	286.0	286.3	286.2
19°	286.0	286.1	285.4	285.0	284.9	284.8	284.6	284.9	285.1	285.3	285.2
19.5°	285.1	284.7	284.3	283.7	284.0	283.8	283.9	283.5	283.8	284.0	284.2
20°	284.0	283.9	283.2	283.0	283.0	282.7	282.6	282.6	282.8	283.1	283.1
20.5°	283.0	282.6	282.0	281.6	281.5	281.5	281.4	281.3	281.7	282.0	282.0
21°	281.9	281.6	281.0	280.5	280.6	280.4	280.4	280.2	280.5	280.7	280.8

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
22.5°	278.4	277.9	277.4	277.0	276.9	276.9	276.7	276.6	277.0	277.1	277.2
23°	277.1	276.7	276.3	275.7	275.9	275.7	275.4	275.4	275.7	275.9	276.2
23.5°	275.9	275.5	275.0	274.5	274.5	274.2	274.3	274.2	274.4	274.7	274.7
24°	274.6	274.3	273.7	273.2	273.4	273.1	272.9	272.8	273.0	273.4	273.5
24.5°	273.3	273.0	272.5	271.7	272.0	271.5	271.6	271.7	272.0	272.0	272.3
25°	271.9	271.6	271.1	270.7	270.6	270.4	270.2	270.2	270.4	270.7	270.9
25.5°	270.7	270.2	269.8	269.0	269.2	268.9	269.1	268.9	269.1	269.4	269.5
26°	269.1	269.0	268.4	267.9	268.1	267.5	267.5	267.5	267.7	267.9	268.2
26.5°	268.0	267.6	267.0	266.3	266.4	266.2	266.3	266.1	266.3	266.5	266.8
27°	266.4	266.2	265.5	264.9	265.1	265.0	264.7	264.6	264.9	265.2	265.2
27.5°	265.1	264.6	264.0	263.6	263.6	263.2	263.4	263.2	263.4	263.7	264.0
28°	263.4	263.2	262.6	262.0	262.2	262.1	261.7	261.6	262.0	262.1	262.5
28.5°	262.1	261.7	261.0	260.6	260.7	260.3	260.4	260.2	260.5	260.7	261.0
29°	260.6	260.3	259.7	259.0	259.1	258.8	258.8	258.8	258.9	259.2	259.3
29.5°	259.1	258.7	258.1	257.5	257.6	257.4	257.3	257.2	257.4	257.7	258.1
30°	257.4	257.1	256.6	255.9	256.2	255.9	255.8	255.6	255.8	256.2	256.3
30.5°	256.1	255.5	255.0	254.4	254.5	254.1	254.3	253.9	254.2	254.5	254.8
31°	254.3	254.0	253.4	252.8	253.0	252.7	252.6	252.3	252.7	253.1	253.1
31.5°	253.0	252.3	251.8	251.1	251.3	251.0	251.0	250.9	251.0	251.3	251.6
32°	251.0	250.7	250.1	249.5	249.8	249.3	249.2	249.1	249.4	249.9	250.0
32.5°	249.5	249.2	248.5	247.9	248.0	247.7	247.7	247.6	247.7	248.0	248.3
33°	247.9	247.3	246.9	246.1	246.5	246.1	245.9	245.7	246.1	246.4	246.7
33.5°	246.2	245.8	245.2	244.5	244.7	244.3	244.3	244.2	244.4	244.6	244.9
34°	244.4	244.1	243.3	242.7	243.1	242.6	242.6	242.4	242.6	242.9	243.2
34.5°	242.8	242.3	241.8	241.0	241.1	240.9	240.8	240.7	240.9	241.3	241.5
35°	240.8	240.7	239.9	239.4	239.6	239.2	239.1	239.0	239.1	239.5	239.7
35.5°	239.3	238.9	238.3	237.5	237.8	237.3	237.4	237.1	237.3	237.5	238.1
36°	237.3	237.1	236.4	235.8	236.1	235.8	235.5	235.4	235.7	236.1	236.1
36.5°	235.7	235.2	234.6	233.9	234.1	233.7	233.8	233.5	233.8	234.0	234.5
37°	233.8	233.5	232.8	232.2	232.5	232.1	231.9	231.8	232.0	232.5	232.6
37.5°	232.0	231.5	231.0	230.3	230.4	230.1	230.1	229.9	230.0	230.4	230.8
38°	230.1	229.9	229.0	228.4	228.8	228.4	228.3	228.0	228.3	228.7	229.0
38.5°	228.3	227.9	227.2	226.5	226.8	226.4	226.2	226.2	226.3	226.6	226.9
39°	226.2	226.1	225.2	224.7	225.0	224.6	224.4	224.4	224.5	224.8	225.3
39.5°	224.6	224.0	223.5	222.7	223.0	222.6	222.5	222.3	222.6	222.9	223.2
40°	222.4	222.3	221.3	220.8	221.2	220.7	220.4	220.4	220.5	221.0	221.3
40.5°	220.6	220.1	219.6	218.8	219.1	218.7	218.5	218.4	218.7	219.0	219.4
41°	218.7	218.3	217.4	217.0	217.3	216.8	216.7	216.6	216.7	217.0	217.4
41.5°	216.7	216.2	215.6	214.7	215.1	214.7	214.6	214.5	214.7	215.0	215.4
42°	214.6	214.5	213.6	213.0	213.3	212.9	212.8	212.5	212.7	213.0	213.5
42.5°	212.7	212.3	211.5	210.8	211.3	210.7	210.6	210.5	210.7	211.0	211.3
43°	210.5	210.2	209.6	208.9	209.2	208.9	208.7	208.5	208.8	209.1	209.6
43.5°	208.7	208.2	207.4	206.7	207.2	206.8	206.6	206.4	206.5	207.0	207.4

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
45°	202.3	202.1	201.2	200.5	201.0	200.5	200.2	200.2	200.4	200.7	201.1
45.5°	200.3	199.7	199.1	198.4	198.8	198.3	198.1	198.2	198.1	198.7	199.0
46°	198.1	197.9	197.0	196.4	196.8	196.2	196.1	196.0	196.3	196.5	196.9
46.5°	196.0	195.5	194.8	194.0	194.5	194.2	193.9	193.8	194.0	194.4	194.7
47°	193.8	193.5	192.6	192.0	192.5	191.9	191.8	191.7	191.9	192.1	192.6
47.5°	191.7	191.2	190.7	189.8	190.4	189.8	189.5	189.5	189.6	190.0	190.3
48°	189.5	189.0	188.3	187.6	188.1	187.7	187.5	187.3	187.6	187.9	188.2
48.5°	187.3	186.9	186.2	185.4	185.9	185.4	185.2	185.2	185.3	185.6	186.0
49°	185.1	184.7	184.1	183.3	183.8	183.2	183.1	182.9	183.0	183.5	183.9
49.5°	182.8	182.4	181.6	181.0	181.4	180.9	180.8	180.8	180.8	181.1	181.6
50°	180.5	180.1	179.5	178.7	179.2	178.8	178.7	178.4	178.6	178.9	179.4
50.5°	178.4	178.0	177.2	176.4	176.9	176.4	176.3	176.3	176.3	176.7	177.1
51°	176.0	175.7	175.0	174.2	174.8	174.2	174.1	173.9	174.2	174.3	174.8
51.5°	173.8	173.3	172.5	171.8	172.3	172.0	171.7	171.8	171.8	172.2	172.6
52°	171.4	171.1	170.5	169.7	170.3	169.7	169.5	169.4	169.6	169.8	170.3
52.5°	169.2	168.7	168.0	167.2	167.7	167.4	167.0	167.1	167.1	167.6	168.0
53°	166.7	166.4	165.7	165.0	165.6	165.1	164.9	164.8	164.9	165.2	165.7
53.5°	164.4	164.0	163.3	162.5	163.1	162.7	162.4	162.4	162.5	162.8	163.3
54°	162.0	161.7	161.1	160.3	160.9	160.3	160.3	160.1	160.2	160.5	161.0
54.5°	159.7	159.3	158.5	157.7	158.4	157.9	157.7	157.7	157.7	158.1	158.6
55°	157.2	156.9	156.3	155.7	156.1	155.6	155.5	155.4	155.5	155.9	156.2
55.5°	155.0	154.5	153.8	153.0	153.6	153.2	153.1	152.9	153.0	153.5	153.8
56°	152.4	152.2	151.4	150.8	151.3	150.8	150.6	150.7	150.8	150.9	151.4
56.5°	150.1	149.7	149.0	148.2	148.8	148.5	148.2	148.1	148.2	148.7	149.1
57°	147.6	147.3	146.5	145.9	146.5	145.9	145.8	145.8	145.7	146.1	146.6
57.5°	145.1	144.8	144.1	143.4	144.0	143.6	143.3	143.2	143.4	143.8	144.2
58°	142.8	142.4	141.6	141.0	141.6	141.1	141.0	140.8	140.9	141.2	141.7
58.5°	140.2	139.8	139.2	138.5	139.0	138.6	138.5	138.4	138.5	138.8	139.4
59°	137.7	137.4	136.7	136.0	136.7	136.2	136.0	135.9	136.1	136.4	136.8
59.5°	135.2	134.9	134.2	133.5	134.1	133.7	133.5	133.4	133.4	133.9	134.4
60°	132.7	132.3	131.7	131.0	131.7	131.1	131.1	130.9	131.2	131.3	131.7
60.5°	130.1	129.8	129.2	128.5	129.2	128.7	128.5	128.4	128.5	128.9	129.3
61°	127.7	127.3	126.6	125.9	126.6	126.2	126.1	126.0	126.0	126.3	126.7
61.5°	125.1	124.9	124.1	123.4	124.0	123.8	123.5	123.4	123.5	123.9	124.3
62°	122.6	122.2	121.6	120.9	121.6	121.1	121.0	121.0	121.1	121.2	121.6
62.5°	120.0	119.6	119.0	118.3	119.0	118.6	118.4	118.3	118.3	118.8	119.3
63°	117.4	117.0	116.4	115.8	116.5	116.0	115.9	115.8	115.9	116.2	116.6
63.5°	114.8	114.5	113.8	113.1	113.8	113.5	113.3	113.1	113.2	113.6	114.1
64°	112.2	111.8	111.2	110.6	111.4	110.9	110.8	110.7	110.8	111.0	111.4
64.5°	109.6	109.3	108.6	108.0	108.7	108.3	108.1	108.0	108.1	108.5	109.0
65°	107.0	106.7	106.1	105.4	106.2	105.8	105.6	105.6	105.7	105.9	106.3
65.5°	104.4	104.1	103.4	102.9	103.6	103.2	103.0	102.9	103.0	103.4	103.8
66°	101.7	101.4	100.7	100.2	101.0	100.5	100.4	100.3	100.4	100.7	101.1

TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
67.5°	93.9	93.5	92.9	92.3	93.1	92.8	92.6	92.4	92.5	92.8	93.3
68°	91.2	90.9	90.2	89.8	90.5	90.1	90.0	89.9	90.0	90.2	90.6
68.5°	88.5	88.3	87.7	87.0	87.9	87.5	87.3	87.3	87.2	87.6	88.1
69°	85.9	85.6	84.9	84.5	85.2	84.8	84.8	84.7	84.7	84.9	85.4
69.5°	83.2	82.9	82.3	81.7	82.6	82.2	82.1	81.9	82.1	82.4	82.8
70°	80.6	80.2	79.6	79.2	80.0	79.6	79.4	79.4	79.5	79.6	80.1
70.5°	77.9	77.7	77.1	76.4	77.3	76.9	76.8	76.7	76.8	77.1	77.5
71°	75.3	75.0	74.4	73.9	74.7	74.3	74.3	74.2	74.2	74.5	74.9
71.5°	72.6	72.4	71.8	71.2	72.1	71.7	71.6	71.4	71.5	71.9	72.3
72°	69.9	69.7	69.1	68.7	69.5	69.1	69.1	69.0	69.0	69.2	69.6
72.5°	67.3	67.0	66.4	65.9	66.8	66.5	66.5	66.4	66.4	66.6	67.0
73°	64.7	64.4	63.8	63.3	64.2	63.9	63.9	63.8	63.8	64.0	64.3
73.5°	62.0	61.8	61.2	60.7	61.6	61.3	61.3	61.2	61.2	61.4	61.7
74°	59.4	59.1	58.6	58.1	58.9	58.7	58.7	58.5	58.6	58.8	59.0
74.5°	56.7	56.5	56.0	55.4	56.4	56.1	56.0	55.8	55.9	56.3	56.6
75°	54.1	53.9	53.4	53.0	53.8	53.5	53.5	53.3	53.4	53.6	53.9
75.5°	51.6	51.3	50.8	50.2	51.2	50.9	50.8	50.7	50.8	51.1	51.6
76°	48.9	48.7	48.2	47.7	48.6	48.4	48.3	48.2	48.2	48.5	48.8
76.5°	46.4	46.1	45.7	45.2	46.1	45.8	45.8	45.6	45.7	46.0	46.3
77°	43.8	43.6	43.2	42.7	43.6	43.3	43.3	43.2	43.2	43.4	43.7
77.5°	41.4	41.1	40.7	40.2	41.1	40.8	40.7	40.6	40.7	41.0	41.3
78°	38.8	38.6	38.2	37.8	38.7	38.4	38.3	38.3	38.3	38.5	38.8
78.5°	36.4	36.2	35.7	35.3	36.1	35.9	35.8	35.7	35.8	36.1	36.4
79°	34.0	33.7	33.3	32.9	33.8	33.5	33.5	33.4	33.4	33.6	34.0
79.5°	31.5	31.4	31.0	30.5	31.4	31.2	31.1	31.0	31.0	31.4	31.6
80°	29.2	29.0	28.6	28.3	29.1	28.9	28.8	28.8	28.8	29.0	29.2
80.5°	27.0	26.8	26.5	26.1	26.8	26.5	26.5	26.4	26.4	26.7	27.0
81°	24.8	24.7	24.3	24.0	24.6	24.3	24.3	24.2	24.3	24.4	24.7
81.5°	22.7	22.5	22.2	21.9	22.4	22.2	22.1	22.0	22.1	22.3	22.6
82°	20.5	20.3	20.0	19.7	20.3	20.1	20.0	20.0	20.0	20.2	20.4
82.5°	18.3	18.2	17.9	17.6	18.2	18.1	17.9	17.9	17.9	18.1	18.4
83°	16.4	16.2	15.9	15.6	16.2	16.0	16.0	15.9	16.0	16.1	16.4
83.5°	14.4	14.3	14.0	13.7	14.3	14.2	14.1	14.0	14.1	14.3	14.5
84°	12.6	12.5	12.2	11.9	12.5	12.4	12.4	12.3	12.3	12.5	12.7
84.5°	10.9	10.8	10.5	10.3	10.8	10.7	10.6	10.6	10.6	10.8	11.0
85°	9.3	9.2	8.9	8.7	9.2	9.4	9.3	9.2	9.4	9.2	9.3
85.5°	7.8	7.7	7.5	7.2	8.0	8.1	7.9	7.9	8.1	8.0	8.1
86°	6.4	6.3	6.1	5.9	6.7	6.8	6.6	6.5	6.8	6.7	6.9
86.5°	5.1	5.1	4.9	4.7	5.5	5.5	5.2	5.2	5.5	5.5	5.7
87°	4.0	4.0	3.8	3.7	4.3	4.3	3.9	3.9	4.3	4.3	4.4
87.5°	3.0	3.0	2.9	2.8	3.0	3.0	3.0	3.0	3.0	3.1	3.2
88°	2.4	2.4	2.3	2.2	2.3	2.2	2.2	2.2	2.3	2.4	2.4
88.5°	1.8	1.8	1.7	1.7	1.6	1.6	1.6	1.6	1.7	1.7	1.8

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



TEST NUMBER: P997179
CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
0°	305.6	305.6	305.6	305.6	305.6	305.6
0.5°	305.5	305.2	305.4	305.7	305.7	306.2
1°	305.5	305.3	305.6	305.6	305.7	305.9
1.5°	305.4	305.1	305.2	305.7	305.7	306.0
2°	305.3	305.1	305.3	305.2	305.7	305.8
2.5°	305.2	304.9	305.0	305.5	305.5	305.7
3°	305.2	304.9	305.1	305.0	305.5	305.7
3.5°	304.9	304.4	304.7	305.0	305.1	305.7
4°	304.7	304.5	304.7	304.8	305.1	305.1
4.5°	304.3	304.0	304.2	304.6	304.8	304.9
5°	304.3	304.0	304.2	304.2	304.7	304.7
5.5°	303.8	303.6	303.5	304.1	304.1	304.6
6°	303.5	303.1	303.6	303.5	304.0	304.2
6.5°	303.2	303.0	303.1	303.4	303.6	303.9
7°	302.9	302.5	302.7	303.0	303.2	303.3
7.5°	302.3	302.0	302.3	302.6	302.7	303.2
8°	302.1	301.7	302.1	302.0	302.4	302.5
8.5°	301.5	301.2	301.3	301.9	301.7	302.3
9°	301.1	300.7	301.0	301.0	301.7	301.5
9.5°	300.4	300.1	300.2	300.7	300.8	301.2
10°	300.1	299.6	300.1	300.0	300.4	300.5
10.5°	299.4	298.8	299.1	299.7	299.8	300.1
11°	298.7	298.6	298.7	298.7	299.1	299.4
11.5°	298.2	297.6	298.0	298.3	298.7	299.0
12°	297.6	297.1	297.4	297.5	297.7	298.1
12.5°	296.8	296.3	296.5	297.1	297.3	297.3
13°	296.1	295.8	296.0	296.3	296.5	296.8
13.5°	295.4	294.9	295.1	295.5	295.8	296.1
14°	294.6	294.2	294.5	294.8	295.2	295.1
14.5°	293.8	293.3	293.5	293.9	294.2	294.7
15°	293.2	292.5	292.8	293.0	293.5	293.5
15.5°	292.1	291.7	291.9	292.4	292.6	292.7
16°	291.2	290.7	291.1	291.2	291.9	292.0
16.5°	290.2	290.0	290.1	290.8	290.7	291.1
17°	289.5	289.0	289.3	289.5	290.0	290.1
17.5°	288.5	288.0	288.2	288.7	288.9	289.2
18°	287.3	287.0	287.4	287.8	287.9	288.0
18.5°	286.6	286.1	286.4	286.7	287.1	287.3
19°	285.3	285.2	285.4	285.5	286.1	286.0
19.5°	284.4	283.9	284.2	284.7	285.1	285.1
20°	283.3	282.9	283.4	283.5	283.9	284.0
20.5°	282.0	281.7	281.8	282.6	282.9	283.0
21°	281.1	280.6	281.1	281.2	281.6	281.9

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
22.5°	277.6	276.9	277.2	278.0	278.1	278.4
23°	276.2	275.9	276.4	276.5	277.1	277.1
23.5°	275.2	274.6	274.9	275.5	275.7	275.9
24°	273.8	273.4	273.7	274.2	274.5	274.6
24.5°	272.5	271.9	272.4	273.0	273.2	273.3
25°	271.2	270.8	271.0	271.5	271.9	271.9
25.5°	269.7	269.2	269.7	270.3	270.5	270.7
26°	268.4	268.0	268.5	268.7	269.2	269.1
26.5°	267.0	266.4	266.8	267.5	267.8	268.0
27°	265.6	265.1	265.6	266.0	266.4	266.4
27.5°	264.2	263.6	264.1	264.6	264.9	265.1
28°	262.7	262.2	262.6	263.1	263.4	263.4
28.5°	261.2	260.8	261.1	261.7	262.0	262.1
29°	259.8	259.2	259.7	260.1	260.7	260.6
29.5°	258.2	257.8	258.1	258.7	258.9	259.1
30°	256.7	256.2	256.6	257.0	257.7	257.4
30.5°	255.0	254.6	255.0	255.7	255.7	256.1
31°	253.7	253.1	253.5	253.9	254.7	254.3
31.5°	251.7	251.5	251.8	252.6	252.5	253.0
32°	250.5	249.6	250.3	250.7	251.0	251.0
32.5°	248.5	248.2	248.6	249.1	249.4	249.5
33°	247.1	246.5	246.9	247.5	247.9	247.9
33.5°	245.0	244.7	245.3	245.7	246.2	246.2
34°	243.8	243.2	243.6	244.0	244.5	244.4
34.5°	241.7	241.2	241.7	242.2	242.8	242.8
35°	240.2	239.6	240.1	240.6	241.0	240.8
35.5°	238.3	237.8	238.3	238.9	239.3	239.3
36°	236.7	236.1	236.4	237.0	237.5	237.3
36.5°	234.8	234.1	234.7	235.4	235.6	235.7
37°	233.0	232.4	233.0	233.4	233.8	233.8
37.5°	231.1	230.5	231.0	231.7	231.9	232.0
38°	229.4	228.8	229.3	229.7	230.3	230.1
38.5°	227.4	226.9	227.3	227.9	228.3	228.3
39°	225.7	224.8	225.5	226.0	226.5	226.2
39.5°	223.5	223.0	223.6	224.0	224.5	224.6
40°	221.8	221.0	221.6	222.2	222.6	222.4
40.5°	219.7	219.2	219.6	220.3	220.5	220.6
41°	218.0	217.2	217.7	218.2	218.7	218.7
41.5°	215.9	215.2	215.7	216.2	216.6	216.7
42°	213.9	213.2	213.7	214.2	214.7	214.6
42.5°	211.7	211.2	211.8	212.2	212.5	212.7
43°	209.9	209.3	209.8	210.2	210.7	210.5
43.5°	207.7	207.1	207.7	208.2	208.6	208.7

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
45°	201.6	200.9	201.4	202.0	202.4	202.3
45.5°	199.4	198.8	199.4	199.7	200.2	200.3
46°	197.3	196.8	197.2	197.8	198.2	198.1
46.5°	195.1	194.4	195.1	195.4	196.0	196.0
47°	193.2	192.4	192.9	193.5	193.8	193.8
47.5°	190.8	190.3	190.8	191.3	191.6	191.7
48°	188.8	188.0	188.6	189.1	189.5	189.5
48.5°	186.4	185.8	186.3	186.9	187.3	187.3
49°	184.3	183.7	184.2	184.7	185.1	185.1
49.5°	181.9	181.5	181.9	182.4	182.8	182.8
50°	180.0	179.1	179.8	180.2	180.6	180.5
50.5°	177.6	177.0	177.4	177.8	178.2	178.4
51°	175.3	174.5	175.1	175.6	175.9	176.0
51.5°	173.1	172.3	172.9	173.3	173.7	173.8
52°	170.7	170.1	170.6	171.1	171.4	171.4
52.5°	168.5	167.8	168.3	168.7	169.2	169.2
53°	166.1	165.3	166.0	166.4	166.7	166.7
53.5°	163.8	163.1	163.6	164.0	164.5	164.4
54°	161.3	160.7	161.1	161.7	162.0	162.0
54.5°	159.0	158.3	158.9	159.3	159.8	159.7
55°	156.7	155.9	156.4	157.0	157.3	157.2
55.5°	154.4	153.6	154.1	154.5	154.8	155.0
56°	151.9	151.1	151.6	152.1	152.6	152.4
56.5°	149.5	148.7	149.3	149.6	150.0	150.1
57°	147.1	146.3	146.8	147.3	147.7	147.6
57.5°	144.6	143.9	144.3	144.8	145.0	145.1
58°	142.2	141.3	141.8	142.3	142.8	142.8
58.5°	139.8	139.0	139.4	139.9	140.2	140.2
59°	137.3	136.4	136.9	137.4	137.7	137.7
59.5°	134.7	133.9	134.5	134.8	135.3	135.2
60°	132.3	131.4	131.9	132.4	132.8	132.7
60.5°	129.8	129.0	129.4	129.8	130.2	130.1
61°	127.2	126.3	126.8	127.3	127.6	127.7
61.5°	124.6	123.9	124.5	124.8	125.2	125.1
62°	122.2	121.3	121.8	122.2	122.6	122.6
62.5°	119.6	118.8	119.3	119.6	120.0	120.0
63°	117.1	116.2	116.6	117.2	117.5	117.4
63.5°	114.5	113.7	114.2	114.4	114.9	114.8
64°	111.9	111.0	111.5	111.9	112.2	112.2
64.5°	109.3	108.5	109.0	109.3	109.7	109.6
65°	106.8	105.9	106.3	106.7	107.1	107.0
65.5°	104.2	103.3	103.8	104.1	104.4	104.4
66°	101.6	100.7	101.1	101.4	101.8	101.7

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
67.5°	93.8	92.8	93.3	93.6	93.9	93.9
68°	91.1	90.2	90.6	90.9	91.2	91.2
68.5°	88.4	87.5	88.0	88.2	88.6	88.5
69°	85.9	84.8	85.3	85.5	85.8	85.9
69.5°	83.2	82.3	82.6	83.0	83.2	83.2
70°	80.5	79.6	80.0	80.3	80.5	80.6
70.5°	77.9	76.9	77.4	77.6	78.0	77.9
71°	75.4	74.4	74.7	74.9	75.2	75.3
71.5°	72.7	71.6	72.1	72.3	72.6	72.6
72°	70.1	69.0	69.4	69.8	69.9	69.9
72.5°	67.5	66.4	66.8	67.0	67.4	67.3
73°	64.9	63.7	64.1	64.4	64.6	64.7
73.5°	62.2	61.1	61.5	61.7	62.0	62.0
74°	59.6	58.5	58.9	59.1	59.3	59.4
74.5°	57.0	55.9	56.3	56.5	56.8	56.7
75°	54.4	53.3	53.7	53.9	54.2	54.1
75.5°	51.8	50.8	51.1	51.3	51.6	51.6
76°	49.2	48.1	48.5	48.7	49.0	48.9
76.5°	46.6	45.6	46.0	46.2	46.4	46.4
77°	44.1	43.1	43.4	43.7	43.9	43.8
77.5°	41.6	40.6	40.9	41.1	41.4	41.4
78°	39.2	38.2	38.4	38.6	38.9	38.8
78.5°	36.7	35.7	36.1	36.2	36.4	36.4
79°	34.3	33.3	33.6	33.8	34.0	34.0
79.5°	31.9	30.9	31.2	31.4	31.6	31.5
80°	29.5	28.6	28.8	29.0	29.2	29.2
80.5°	27.2	26.5	26.7	26.8	27.1	27.0
81°	25.0	24.3	24.5	24.7	24.9	24.8
81.5°	22.8	22.2	22.4	22.5	22.7	22.7
82°	20.6	20.0	20.2	20.3	20.6	20.5
82.5°	18.6	17.9	18.1	18.2	18.4	18.3
83°	16.6	15.9	16.1	16.2	16.3	16.4
83.5°	14.7	14.0	14.2	14.3	14.4	14.4
84°	12.8	12.2	12.4	12.4	12.6	12.6
84.5°	11.1	10.5	10.7	10.7	10.9	10.9
85°	9.5	8.9	9.0	9.1	9.3	9.3
85.5°	8.2	7.4	7.6	7.6	7.8	7.8
86°	7.0	6.1	6.2	6.2	6.4	6.4
86.5°	5.7	4.9	4.9	5.0	5.1	5.1
87°	4.5	3.8	3.9	4.0	4.0	4.0
87.5°	3.2	2.9	3.0	3.0	3.1	3.0
88°	2.4	2.3	2.4	2.4	2.5	2.4
88.5°	1.7	1.7	1.8	1.8	1.8	1.8

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



TEST NUMBER: P997179

CATALOG NUMBER: SMX4SLSFSD2W-800LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
90°	0.0	0.0	0.0	0.0	0.0	0.0

Classified

Scaled Data Report

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - - 90°-270° - · - 135°-315°

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report





21.5°	280.8	280.4	279.7	279.3	279.3	279.1	279.2	279.0	279.3	279.6	279.8
22°	279.5	279.2	278.7	278.1	278.5	278.0	278.0	277.9	278.1	278.5	278.6



44°	206.3	206.3	205.5	204.8	205.2	204.8	204.4	204.5	204.6	204.9	205.2
44.5°	204.4	204.0	203.3	202.6	203.0	202.5	202.5	202.2	202.4	202.8	203.3



66.5°	99.1	98.9	98.2	97.5	98.3	98.0	97.7	97.7	97.7	98.1	98.5
67°	96.5	96.2	95.6	95.0	95.7	95.3	95.2	95.1	95.1	95.5	95.9



89°	1.2	1.2	1.2	1.1	1.1	1.1	1.1	1.1	1.2	1.2	1.2
89.5°	0.6	0.6	0.6	0.6	0.7	0.7	0.7	0.8	0.8	0.9	0.8

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



21.5°	279.9	279.2	279.7	280.2	280.5	280.8
22°	278.7	278.4	278.8	278.9	279.5	279.5

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



44°	205.9	205.0	205.5	206.1	206.6	206.3
44.5°	203.6	203.0	203.5	204.0	204.5	204.4

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



66.5°	98.9	98.1	98.6	98.8	99.2	99.1
67°	96.3	95.4	95.8	96.1	96.5	96.5

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



89°	1.2	1.2	1.2	1.2	1.2	1.2
89.5°	0.8	0.6	0.6	0.6	0.6	0.6

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)