

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: HALO

Report Number: P997214

Luminaire Tested: **SMX6SLSFSD2W-1200LM-4000K**

Issue Date: 3/11/2025



Test Information

Test Method: LM-41-14
Report Number: P997214
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (A2410656A001)
Test Lab:
Issue Date: 3/11/2025
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: HALO
Catalog Number: SMX6SLSFSD2W-1200LM-4000K
Description: 6IN SQAURE, 90CRI, DIMMING TO 10%, DAMP LOCATION
Light Source: SELECTABLE CCT 90CRI / 4000K CCT
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1388.1 lumens
Efficiency: N/A
Efficacy: 102.1 lumens/watt
Spacing Criteria (0/90/45): 1.26 / 1.27 / 1.38
Luminous Opening: Rectangular (W 0.5' x L: 0.5' x H: 0')
CIE Type: Direct

Input Watts (W): 13.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

Luminous Intensity Polar Plot



Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					0
RW	70	50	30	10	70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																				
0	119	119	119	119	116	116	116	116		111	111	111		106	106	106		102	102	102
1	109	104	100	96	106	102	98	94		97	94	91		93	91	88		90	88	86
2	99	90	84	78	96	89	82	77		85	80	75		82	77	73		79	75	72
3	90	79	71	64	87	78	70	64		75	68	63		72	66	62		69	65	61
4	82	70	61	54	80	69	60	54		66	59	53		64	58	53		62	56	52
5	76	63	53	47	73	61	53	47		59	52	46		57	51	45		55	50	45
6	70	56	47	41	68	55	47	41		53	46	40		52	45	40		50	44	39
7	65	51	42	36	63	50	42	36		49	41	36		47	40	35		46	40	35
8	60	46	38	32	59	46	38	32		44	37	32		43	36	31		42	36	31
9	56	43	34	29	55	42	34	29		41	34	29		40	33	28		39	33	28
10	53	39	31	26	51	39	31	26		38	31	26		37	30	26		36	30	26

AVERAGE LUMINANCE (cd/sqm):

	0°	90°	180°	270°
0°	20641	20641	20641	20641
5°	20638	20629	20638	20629
10°	20566	20645	20566	20645
15°	20549	20580	20549	20580
20°	20486	20499	20486	20499
25°	20376	20423	20376	20423
30°	20240	20299	20240	20299
35°	20131	20152	20131	20152
40°	19953	20003	19953	20003
45°	19777	19795	19777	19795
50°	19525	19559	19525	19559
55°	19202	19239	19202	19239
60°	18738	18764	18738	18764
65°	18073	18124	18073	18124
70°	17070	17083	17070	17083
75°	15471	15488	15471	15488
80°	13017	13067	13017	13067
85°	8942	9238	8942	9238



TEST NUMBER: P997214
CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	45.4	3.3
10°-20°	130.1	9.4
20°-30°	197.8	14.2
30°-40°	239.6	17.3
40°-50°	250.4	18.0
50°-60°	228.3	16.4
60°-70°	175.1	12.6
70°-80°	98.4	7.1
80°-90°	22.9	1.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	373.3	26.9
0°-40°	612.9	44.2
0°-60°	1091.6	78.6
0°-90°	1388.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1388.1	100.0

CANDELA DISTRIBUTION:

	0°	90°	180°	270°	360°	Flux
0°	479	479	479	479	479	
5°	478	477	478	477	478	45
15°	461	462	461	462	461	130
25°	429	430	429	430	429	198
35°	383	383	383	383	383	239
45°	325	325	325	325	325	250
55°	256	256	256	256	256	228
65°	177	178	177	178	177	175
75°	93	93	93	93	93	98
85°	18	19	18	19	18	23
90°	0	0	0	0	0	

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
0°	479.4	479.4	479.4	479.4	479.4	479.4	479.4	479.4	479.4	479.4	479.4
0.5°	479.4	479.2	479.0	479.8	480.2	479.8	479.0	479.2	479.4	479.2	479.0
1°	479.1	479.1	479.3	479.8	480.2	479.8	479.3	479.1	479.1	479.1	479.3
1.5°	479.6	478.8	479.3	479.6	480.2	479.6	479.3	478.8	479.6	478.8	479.3
2°	479.6	478.7	479.1	479.8	480.2	479.8	479.1	478.7	479.6	478.7	479.1
2.5°	479.0	478.6	478.8	479.5	479.2	479.5	478.8	478.6	479.0	478.6	478.8
3°	478.9	478.1	478.7	479.4	478.9	479.4	478.7	478.1	478.9	478.1	478.7
3.5°	478.7	477.9	478.6	479.0	478.6	479.0	478.6	477.9	478.7	477.9	478.6
4°	478.2	477.9	478.3	478.5	478.9	478.5	478.3	477.9	478.2	477.9	478.3
4.5°	478.0	477.2	477.9	477.9	478.2	477.9	477.9	477.2	478.0	477.2	477.9
5°	477.5	476.6	477.7	477.4	477.3	477.4	477.7	476.6	477.5	476.6	477.7
5.5°	477.7	476.6	476.9	477.0	477.7	477.0	476.9	476.6	477.7	476.6	476.9
6°	476.3	475.9	476.4	476.9	477.6	476.9	476.4	475.9	476.3	475.9	476.4
6.5°	476.0	475.5	475.8	476.0	476.5	476.0	475.8	475.5	476.0	475.5	475.8
7°	475.5	475.0	475.2	475.7	476.5	475.7	475.2	475.0	475.5	475.0	475.2
7.5°	474.9	474.4	475.0	474.7	475.2	474.7	475.0	474.4	474.9	474.4	475.0
8°	474.4	473.3	474.5	474.3	475.3	474.3	474.5	473.3	474.4	473.3	474.5
8.5°	473.4	473.1	473.4	473.6	474.2	473.6	473.4	473.1	473.4	473.1	473.4
9°	471.6	472.3	472.5	473.2	473.5	473.2	472.5	472.3	471.6	472.3	472.5
9.5°	471.3	471.8	471.7	472.8	472.5	472.8	471.7	471.8	471.3	471.8	471.7
10°	470.4	471.1	471.0	471.9	472.2	471.9	471.0	471.1	470.4	471.1	471.0
10.5°	469.7	469.9	470.4	470.8	471.1	470.8	470.4	469.9	469.7	469.9	470.4
11°	469.1	468.9	469.6	470.3	469.5	470.3	469.6	468.9	469.1	468.9	469.6
11.5°	468.3	468.1	468.9	468.7	469.1	468.7	468.9	468.1	468.3	468.1	468.9
12°	467.5	466.8	467.4	468.2	468.7	468.2	467.4	466.8	467.5	466.8	467.4
12.5°	466.4	466.2	466.7	467.2	467.2	467.2	466.7	466.2	466.4	466.2	466.7
13°	465.7	465.0	465.5	465.8	466.2	465.8	465.5	465.0	465.7	465.0	465.5
13.5°	464.6	463.9	464.9	464.5	464.7	464.5	464.9	463.9	464.6	463.9	464.9
14°	463.1	463.1	463.5	463.6	464.4	463.6	463.5	463.1	463.1	463.1	463.5
14.5°	462.3	461.9	462.5	462.5	463.1	462.5	462.5	461.9	462.3	461.9	462.5
15°	461.0	460.8	461.5	461.3	461.7	461.3	461.5	460.8	461.0	460.8	461.5
15.5°	459.8	459.4	459.6	460.1	460.7	460.1	459.6	459.4	459.8	459.4	459.6
16°	458.2	458.3	458.6	459.0	458.6	459.0	458.6	458.3	458.2	458.3	458.6
16.5°	457.2	456.8	457.3	457.6	457.9	457.6	457.3	456.8	457.2	456.8	457.3
17°	456.0	455.5	456.1	456.6	455.9	456.6	456.1	455.5	456.0	455.5	456.1
17.5°	454.4	453.9	454.5	454.6	454.9	454.6	454.5	453.9	454.4	453.9	454.5
18°	452.5	452.4	453.0	453.4	453.5	453.4	453.0	452.4	452.5	452.4	453.0
18.5°	451.5	451.5	451.4	451.8	452.5	451.8	451.4	451.5	451.5	451.5	451.4
19°	450.1	449.9	450.4	450.4	451.2	450.4	450.4	449.9	450.1	449.9	450.4
19.5°	448.4	447.7	448.9	448.6	448.6	448.6	448.9	447.7	448.4	447.7	448.9
20°	447.1	446.8	447.0	447.3	447.4	447.3	447.0	446.8	447.1	446.8	447.0
20.5°	445.4	444.5	445.2	445.4	446.0	445.4	445.2	444.5	445.4	444.5	445.2
21°	443.3	443.3	443.3	444.0	444.5	444.0	443.3	443.3	443.3	443.3	443.3

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
22.5°	438.8	437.5	437.7	439.2	438.9	439.2	437.7	437.5	438.8	437.5	437.7
23°	436.9	436.0	436.4	437.5	437.2	437.5	436.4	436.0	436.9	436.0	436.4
23.5°	434.9	434.1	434.6	435.5	435.3	435.5	434.6	434.1	434.9	434.1	434.6
24°	433.5	432.3	432.9	433.3	433.8	433.3	432.9	432.3	433.5	432.3	432.9
24.5°	431.2	430.6	430.8	431.1	431.6	431.1	430.8	430.6	431.2	430.6	430.8
25°	428.9	428.9	429.2	429.4	429.9	429.4	429.2	428.9	428.9	428.9	429.2
25.5°	427.2	426.8	427.4	427.6	427.5	427.6	427.4	426.8	427.2	426.8	427.4
26°	424.9	424.8	425.2	425.3	425.7	425.3	425.2	424.8	424.9	424.8	425.2
26.5°	423.3	422.6	423.2	423.3	423.4	423.3	423.2	422.6	423.3	422.6	423.2
27°	421.1	420.6	420.7	421.3	421.7	421.3	420.7	420.6	421.1	420.6	420.7
27.5°	419.1	418.4	418.7	419.2	419.6	419.2	418.7	418.4	419.1	418.4	418.7
28°	416.9	416.4	416.9	417.2	417.6	417.2	416.9	416.4	416.9	416.4	416.9
28.5°	414.8	414.0	414.8	414.9	415.5	414.9	414.8	414.0	414.8	414.0	414.8
29°	412.0	411.8	412.2	412.4	413.0	412.4	412.2	411.8	412.0	411.8	412.2
29.5°	409.9	409.6	410.2	410.2	410.7	410.2	410.2	409.6	409.9	409.6	410.2
30°	407.1	407.5	407.7	407.9	408.3	407.9	407.7	407.5	407.1	407.5	407.7
30.5°	405.3	404.8	405.4	405.7	406.6	405.7	405.4	404.8	405.3	404.8	405.4
31°	402.9	402.4	403.0	403.3	404.0	403.3	403.0	402.4	402.9	402.4	403.0
31.5°	400.6	399.9	400.6	400.9	401.6	400.9	400.6	399.9	400.6	399.9	400.6
32°	397.8	397.5	398.0	398.4	398.6	398.4	398.0	397.5	397.8	397.5	398.0
32.5°	395.7	394.9	396.0	396.0	396.3	396.0	396.0	394.9	395.7	394.9	396.0
33°	393.0	393.0	393.3	393.7	393.7	393.7	393.3	393.0	393.0	393.0	393.3
33.5°	390.9	390.0	391.0	391.1	390.9	391.1	391.0	390.0	390.9	390.0	391.0
34°	388.3	388.3	387.8	388.5	388.4	388.5	387.8	388.3	388.3	388.3	387.8
34.5°	385.2	385.3	385.6	385.9	386.2	385.9	385.6	385.3	385.2	385.3	385.6
35°	383.0	382.8	382.6	383.2	383.4	383.2	382.6	382.8	383.0	382.8	382.6
35.5°	379.9	380.3	380.1	380.9	380.4	380.9	380.1	380.3	379.9	380.3	380.1
36°	377.8	377.4	377.5	378.3	377.6	378.3	377.5	377.4	377.8	377.4	377.5
36.5°	374.3	374.3	374.9	375.3	375.0	375.3	374.9	374.3	374.3	374.3	374.9
37°	372.6	371.7	372.0	372.3	372.7	372.3	372.0	371.7	372.6	371.7	372.0
37.5°	368.6	368.9	369.7	370.2	370.1	370.2	369.7	368.9	368.6	368.9	369.7
38°	366.2	366.5	366.6	367.2	367.1	367.2	366.6	366.5	366.2	366.5	366.6
38.5°	363.2	363.3	363.6	364.5	364.3	364.5	363.6	363.3	363.2	363.3	363.6
39°	360.6	360.9	361.2	361.3	361.8	361.3	361.2	360.9	360.6	360.9	361.2
39.5°	357.8	357.8	358.5	358.5	358.5	358.5	358.5	357.8	357.8	357.8	358.5
40°	355.0	354.8	355.2	355.7	355.9	355.7	355.2	354.8	355.0	354.8	355.2
40.5°	352.1	351.7	352.2	352.9	352.9	352.9	352.2	351.7	352.1	351.7	352.2
41°	349.4	349.2	349.3	349.6	349.9	349.6	349.3	349.2	349.4	349.2	349.3
41.5°	346.2	345.8	346.4	346.7	347.0	346.7	346.4	345.8	346.2	345.8	346.4
42°	343.3	342.8	343.4	343.9	343.3	343.9	343.4	342.8	343.3	342.8	343.4
42.5°	340.4	339.8	340.4	341.0	340.5	341.0	340.4	339.8	340.4	339.8	340.4
43°	337.2	337.2	337.3	337.7	337.7	337.7	337.3	337.2	337.2	337.2	337.3
43.5°	334.2	333.8	334.0	334.5	334.6	334.5	334.0	333.8	334.2	333.8	334.0

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
45°	324.8	324.3	324.6	325.2	325.1	325.2	324.6	324.3	324.8	324.3	324.6
45.5°	321.5	320.8	321.3	321.8	321.8	321.8	321.3	320.8	321.5	320.8	321.3
46°	318.1	317.8	318.2	318.6	318.6	318.6	318.2	317.8	318.1	317.8	318.2
46.5°	314.8	314.4	314.6	315.0	315.3	315.0	314.6	314.4	314.8	314.4	314.6
47°	311.7	311.3	311.7	311.9	312.0	311.9	311.7	311.3	311.7	311.3	311.7
47.5°	308.5	307.9	308.4	308.8	308.9	308.8	308.4	307.9	308.5	307.9	308.4
48°	305.0	304.6	305.0	305.5	305.7	305.5	305.0	304.6	305.0	304.6	305.0
48.5°	301.8	301.4	301.7	301.8	302.1	301.8	301.7	301.4	301.8	301.4	301.7
49°	298.7	298.1	298.3	298.9	298.6	298.9	298.3	298.1	298.7	298.1	298.3
49.5°	295.0	294.6	294.8	295.1	295.6	295.1	294.8	294.6	295.0	294.6	294.8
50°	291.5	291.1	291.1	291.9	292.0	291.9	291.1	291.1	291.5	291.1	291.1
50.5°	288.1	287.6	287.6	288.3	288.5	288.3	287.6	287.6	288.1	287.6	287.6
51°	284.6	284.1	284.0	284.8	284.9	284.8	284.0	284.1	284.6	284.1	284.0
51.5°	281.0	280.7	280.8	281.2	281.6	281.2	280.8	280.7	281.0	280.7	280.8
52°	277.3	277.1	277.0	277.6	278.0	277.6	277.0	277.1	277.3	277.1	277.0
52.5°	273.5	273.4	273.7	274.1	274.3	274.1	273.7	273.4	273.5	273.4	273.7
53°	270.2	269.9	270.2	270.4	270.6	270.4	270.2	269.9	270.2	269.9	270.2
53.5°	266.9	266.3	266.8	266.5	267.1	266.5	266.8	266.3	266.9	266.3	266.8
54°	263.2	262.7	262.9	263.3	263.5	263.3	262.9	262.7	263.2	262.7	262.9
54.5°	259.5	259.0	259.2	259.7	259.8	259.7	259.2	259.0	259.5	259.0	259.2
55°	255.8	255.4	255.5	256.0	256.3	256.0	255.5	255.4	255.8	255.4	255.5
55.5°	252.3	251.7	251.8	252.1	252.6	252.1	251.8	251.7	252.3	251.7	251.8
56°	248.4	247.8	248.1	248.3	248.6	248.3	248.1	247.8	248.4	247.8	248.1
56.5°	244.6	244.1	244.4	244.6	244.7	244.6	244.4	244.1	244.6	244.1	244.4
57°	240.6	240.2	240.5	240.9	241.1	240.9	240.5	240.2	240.6	240.2	240.5
57.5°	236.8	236.4	236.7	237.2	237.3	237.2	236.7	236.4	236.8	236.4	236.7
58°	233.1	232.6	233.0	233.3	233.4	233.3	233.0	232.6	233.1	232.6	233.0
58.5°	229.3	228.9	229.2	229.4	229.5	229.4	229.2	228.9	229.3	228.9	229.2
59°	225.6	225.1	225.0	225.4	225.8	225.4	225.0	225.1	225.6	225.1	225.0
59.5°	221.5	221.2	221.1	221.5	221.8	221.5	221.1	221.2	221.5	221.2	221.1
60°	217.6	217.2	217.2	217.7	217.9	217.7	217.2	217.2	217.6	217.2	217.2
60.5°	213.7	213.3	213.3	213.7	214.0	213.7	213.3	213.3	213.7	213.3	213.3
61°	209.5	209.4	209.3	209.8	210.0	209.8	209.3	209.4	209.5	209.4	209.3
61.5°	205.5	205.3	205.5	205.8	205.9	205.8	205.5	205.3	205.5	205.3	205.5
62°	201.4	201.4	201.4	201.8	202.0	201.8	201.4	201.4	201.4	201.4	201.4
62.5°	197.4	197.4	197.5	197.9	197.9	197.9	197.5	197.4	197.4	197.4	197.5
63°	193.5	193.4	193.5	194.0	194.0	194.0	193.5	193.4	193.5	193.4	193.5
63.5°	189.4	189.4	189.6	189.7	190.1	189.7	189.6	189.4	189.4	189.4	189.6
64°	185.4	185.2	185.5	185.6	186.2	185.6	185.5	185.2	185.4	185.2	185.5
64.5°	181.3	181.2	181.4	181.5	182.0	181.5	181.4	181.2	181.3	181.2	181.4
65°	177.4	177.1	177.2	177.4	177.9	177.4	177.2	177.1	177.4	177.1	177.2
65.5°	173.1	172.9	173.1	173.3	173.5	173.3	173.1	172.9	173.1	172.9	173.1
66°	168.9	168.7	168.8	169.3	169.4	169.3	168.8	168.7	168.9	168.7	168.8

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
67.5°	156.7	156.2	156.3	156.6	156.8	156.6	156.3	156.2	156.7	156.2	156.3
68°	152.5	152.1	152.2	152.4	152.7	152.4	152.2	152.1	152.5	152.1	152.2
68.5°	148.2	148.0	148.2	148.4	148.4	148.4	148.2	148.0	148.2	148.0	148.2
69°	144.0	143.7	143.6	144.0	144.1	144.0	143.6	143.7	144.0	143.7	143.6
69.5°	139.7	139.5	139.5	139.9	139.9	139.9	139.5	139.5	139.7	139.5	139.5
70°	135.6	135.4	135.5	135.6	135.7	135.6	135.5	135.4	135.6	135.4	135.5
70.5°	131.2	130.9	131.1	131.5	131.4	131.5	131.1	130.9	131.2	130.9	131.1
71°	127.1	126.8	126.9	127.2	127.2	127.2	126.9	126.8	127.1	126.8	126.9
71.5°	122.7	122.5	122.7	122.9	122.8	122.9	122.7	122.5	122.7	122.5	122.7
72°	118.3	118.2	118.2	118.6	118.6	118.6	118.2	118.2	118.3	118.2	118.2
72.5°	114.2	114.0	114.1	114.5	114.3	114.5	114.1	114.0	114.2	114.0	114.1
73°	109.7	109.8	109.8	110.2	110.1	110.2	109.8	109.8	109.7	109.8	109.8
73.5°	105.7	105.5	105.5	105.8	105.8	105.8	105.5	105.5	105.7	105.5	105.5
74°	101.6	101.5	101.5	101.5	101.7	101.5	101.5	101.5	101.6	101.5	101.5
74.5°	97.3	97.3	97.2	97.4	97.4	97.4	97.2	97.3	97.3	97.3	97.2
75°	93.0	93.0	93.0	93.2	93.1	93.2	93.0	93.0	93.0	93.0	93.0
75.5°	88.8	88.7	88.8	89.0	89.0	89.0	88.8	88.7	88.8	88.7	88.8
76°	84.7	84.5	84.6	84.6	84.7	84.6	84.6	84.5	84.7	84.5	84.6
76.5°	80.4	80.3	80.4	80.6	80.5	80.6	80.4	80.3	80.4	80.3	80.4
77°	76.2	76.3	76.4	76.5	76.6	76.5	76.4	76.3	76.2	76.3	76.4
77.5°	72.3	72.2	72.3	72.5	72.5	72.5	72.3	72.2	72.3	72.2	72.3
78°	68.3	68.2	68.3	68.5	68.6	68.5	68.3	68.2	68.3	68.2	68.3
78.5°	64.4	64.3	64.2	64.6	64.6	64.6	64.2	64.3	64.4	64.3	64.2
79°	60.5	60.4	60.4	60.5	60.6	60.5	60.4	60.4	60.5	60.4	60.4
79.5°	56.5	56.4	56.4	56.6	56.6	56.6	56.4	56.4	56.5	56.4	56.4
80°	52.5	52.4	52.5	52.7	52.7	52.7	52.5	52.4	52.5	52.4	52.5
80.5°	48.6	48.6	48.6	48.9	48.8	48.9	48.6	48.6	48.6	48.6	48.6
81°	44.9	44.8	44.9	45.0	45.0	45.0	44.9	44.8	44.9	44.8	44.9
81.5°	41.1	41.0	41.1	41.3	41.3	41.3	41.1	41.0	41.1	41.0	41.1
82°	37.3	37.3	37.4	37.6	37.7	37.6	37.4	37.3	37.3	37.3	37.4
82.5°	33.8	33.7	34.0	34.2	34.3	34.2	34.0	33.7	33.8	33.7	34.0
83°	30.4	30.4	30.5	30.8	30.9	30.8	30.5	30.4	30.4	30.4	30.5
83.5°	27.1	27.1	27.2	27.5	27.6	27.5	27.2	27.1	27.1	27.1	27.2
84°	24.0	24.0	24.1	24.3	24.4	24.3	24.1	24.0	24.0	24.0	24.1
84.5°	21.0	21.0	21.1	21.3	21.5	21.3	21.1	21.0	21.0	21.0	21.1
85°	18.1	18.1	18.1	18.5	18.7	18.5	18.1	18.1	18.1	18.1	18.1
85.5°	15.3	15.3	15.5	15.7	16.0	15.7	15.5	15.3	15.3	15.3	15.5
86°	12.7	12.8	13.0	13.2	13.5	13.2	13.0	12.8	12.7	12.8	13.0
86.5°	10.3	10.4	10.6	10.8	11.2	10.8	10.6	10.4	10.3	10.4	10.6
87°	8.2	8.3	8.5	8.7	9.0	8.7	8.5	8.3	8.2	8.3	8.5
87.5°	6.3	6.4	6.6	6.8	7.2	6.8	6.6	6.4	6.3	6.4	6.6
88°	4.6	4.6	4.9	5.1	5.5	5.1	4.9	4.6	4.6	4.6	4.9
88.5°	3.1	3.2	3.4	3.7	4.1	3.7	3.4	3.2	3.1	3.2	3.4

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



TEST NUMBER: P997214
CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°	180°	202.5°	225°
90°	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
0°	479.4	479.4	479.4	479.4	479.4	479.4
0.5°	479.8	480.2	479.8	479.0	479.2	479.4
1°	479.8	480.2	479.8	479.3	479.1	479.1
1.5°	479.6	480.2	479.6	479.3	478.8	479.6
2°	479.8	480.2	479.8	479.1	478.7	479.6
2.5°	479.5	479.2	479.5	478.8	478.6	479.0
3°	479.4	478.9	479.4	478.7	478.1	478.9
3.5°	479.0	478.6	479.0	478.6	477.9	478.7
4°	478.5	478.9	478.5	478.3	477.9	478.2
4.5°	477.9	478.2	477.9	477.9	477.2	478.0
5°	477.4	477.3	477.4	477.7	476.6	477.5
5.5°	477.0	477.7	477.0	476.9	476.6	477.7
6°	476.9	477.6	476.9	476.4	475.9	476.3
6.5°	476.0	476.5	476.0	475.8	475.5	476.0
7°	475.7	476.5	475.7	475.2	475.0	475.5
7.5°	474.7	475.2	474.7	475.0	474.4	474.9
8°	474.3	475.3	474.3	474.5	473.3	474.4
8.5°	473.6	474.2	473.6	473.4	473.1	473.4
9°	473.2	473.5	473.2	472.5	472.3	471.6
9.5°	472.8	472.5	472.8	471.7	471.8	471.3
10°	471.9	472.2	471.9	471.0	471.1	470.4
10.5°	470.8	471.1	470.8	470.4	469.9	469.7
11°	470.3	469.5	470.3	469.6	468.9	469.1
11.5°	468.7	469.1	468.7	468.9	468.1	468.3
12°	468.2	468.7	468.2	467.4	466.8	467.5
12.5°	467.2	467.2	467.2	466.7	466.2	466.4
13°	465.8	466.2	465.8	465.5	465.0	465.7
13.5°	464.5	464.7	464.5	464.9	463.9	464.6
14°	463.6	464.4	463.6	463.5	463.1	463.1
14.5°	462.5	463.1	462.5	462.5	461.9	462.3
15°	461.3	461.7	461.3	461.5	460.8	461.0
15.5°	460.1	460.7	460.1	459.6	459.4	459.8
16°	459.0	458.6	459.0	458.6	458.3	458.2
16.5°	457.6	457.9	457.6	457.3	456.8	457.2
17°	456.6	455.9	456.6	456.1	455.5	456.0
17.5°	454.6	454.9	454.6	454.5	453.9	454.4
18°	453.4	453.5	453.4	453.0	452.4	452.5
18.5°	451.8	452.5	451.8	451.4	451.5	451.5
19°	450.4	451.2	450.4	450.4	449.9	450.1
19.5°	448.6	448.6	448.6	448.9	447.7	448.4
20°	447.3	447.4	447.3	447.0	446.8	447.1
20.5°	445.4	446.0	445.4	445.2	444.5	445.4
21°	444.0	444.5	444.0	443.3	443.3	443.3

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
22.5°	439.2	438.9	439.2	437.7	437.5	438.8
23°	437.5	437.2	437.5	436.4	436.0	436.9
23.5°	435.5	435.3	435.5	434.6	434.1	434.9
24°	433.3	433.8	433.3	432.9	432.3	433.5
24.5°	431.1	431.6	431.1	430.8	430.6	431.2
25°	429.4	429.9	429.4	429.2	428.9	428.9
25.5°	427.6	427.5	427.6	427.4	426.8	427.2
26°	425.3	425.7	425.3	425.2	424.8	424.9
26.5°	423.3	423.4	423.3	423.2	422.6	423.3
27°	421.3	421.7	421.3	420.7	420.6	421.1
27.5°	419.2	419.6	419.2	418.7	418.4	419.1
28°	417.2	417.6	417.2	416.9	416.4	416.9
28.5°	414.9	415.5	414.9	414.8	414.0	414.8
29°	412.4	413.0	412.4	412.2	411.8	412.0
29.5°	410.2	410.7	410.2	410.2	409.6	409.9
30°	407.9	408.3	407.9	407.7	407.5	407.1
30.5°	405.7	406.6	405.7	405.4	404.8	405.3
31°	403.3	404.0	403.3	403.0	402.4	402.9
31.5°	400.9	401.6	400.9	400.6	399.9	400.6
32°	398.4	398.6	398.4	398.0	397.5	397.8
32.5°	396.0	396.3	396.0	396.0	394.9	395.7
33°	393.7	393.7	393.7	393.3	393.0	393.0
33.5°	391.1	390.9	391.1	391.0	390.0	390.9
34°	388.5	388.4	388.5	387.8	388.3	388.3
34.5°	385.9	386.2	385.9	385.6	385.3	385.2
35°	383.2	383.4	383.2	382.6	382.8	383.0
35.5°	380.9	380.4	380.9	380.1	380.3	379.9
36°	378.3	377.6	378.3	377.5	377.4	377.8
36.5°	375.3	375.0	375.3	374.9	374.3	374.3
37°	372.3	372.7	372.3	372.0	371.7	372.6
37.5°	370.2	370.1	370.2	369.7	368.9	368.6
38°	367.2	367.1	367.2	366.6	366.5	366.2
38.5°	364.5	364.3	364.5	363.6	363.3	363.2
39°	361.3	361.8	361.3	361.2	360.9	360.6
39.5°	358.5	358.5	358.5	358.5	357.8	357.8
40°	355.7	355.9	355.7	355.2	354.8	355.0
40.5°	352.9	352.9	352.9	352.2	351.7	352.1
41°	349.6	349.9	349.6	349.3	349.2	349.4
41.5°	346.7	347.0	346.7	346.4	345.8	346.2
42°	343.9	343.3	343.9	343.4	342.8	343.3
42.5°	341.0	340.5	341.0	340.4	339.8	340.4
43°	337.7	337.7	337.7	337.3	337.2	337.2
43.5°	334.5	334.6	334.5	334.0	333.8	334.2

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
45°	325.2	325.1	325.2	324.6	324.3	324.8
45.5°	321.8	321.8	321.8	321.3	320.8	321.5
46°	318.6	318.6	318.6	318.2	317.8	318.1
46.5°	315.0	315.3	315.0	314.6	314.4	314.8
47°	311.9	312.0	311.9	311.7	311.3	311.7
47.5°	308.8	308.9	308.8	308.4	307.9	308.5
48°	305.5	305.7	305.5	305.0	304.6	305.0
48.5°	301.8	302.1	301.8	301.7	301.4	301.8
49°	298.9	298.6	298.9	298.3	298.1	298.7
49.5°	295.1	295.6	295.1	294.8	294.6	295.0
50°	291.9	292.0	291.9	291.1	291.1	291.5
50.5°	288.3	288.5	288.3	287.6	287.6	288.1
51°	284.8	284.9	284.8	284.0	284.1	284.6
51.5°	281.2	281.6	281.2	280.8	280.7	281.0
52°	277.6	278.0	277.6	277.0	277.1	277.3
52.5°	274.1	274.3	274.1	273.7	273.4	273.5
53°	270.4	270.6	270.4	270.2	269.9	270.2
53.5°	266.5	267.1	266.5	266.8	266.3	266.9
54°	263.3	263.5	263.3	262.9	262.7	263.2
54.5°	259.7	259.8	259.7	259.2	259.0	259.5
55°	256.0	256.3	256.0	255.5	255.4	255.8
55.5°	252.1	252.6	252.1	251.8	251.7	252.3
56°	248.3	248.6	248.3	248.1	247.8	248.4
56.5°	244.6	244.7	244.6	244.4	244.1	244.6
57°	240.9	241.1	240.9	240.5	240.2	240.6
57.5°	237.2	237.3	237.2	236.7	236.4	236.8
58°	233.3	233.4	233.3	233.0	232.6	233.1
58.5°	229.4	229.5	229.4	229.2	228.9	229.3
59°	225.4	225.8	225.4	225.0	225.1	225.6
59.5°	221.5	221.8	221.5	221.1	221.2	221.5
60°	217.7	217.9	217.7	217.2	217.2	217.6
60.5°	213.7	214.0	213.7	213.3	213.3	213.7
61°	209.8	210.0	209.8	209.3	209.4	209.5
61.5°	205.8	205.9	205.8	205.5	205.3	205.5
62°	201.8	202.0	201.8	201.4	201.4	201.4
62.5°	197.9	197.9	197.9	197.5	197.4	197.4
63°	194.0	194.0	194.0	193.5	193.4	193.5
63.5°	189.7	190.1	189.7	189.6	189.4	189.4
64°	185.6	186.2	185.6	185.5	185.2	185.4
64.5°	181.5	182.0	181.5	181.4	181.2	181.3
65°	177.4	177.9	177.4	177.2	177.1	177.4
65.5°	173.3	173.5	173.3	173.1	172.9	173.1
66°	169.3	169.4	169.3	168.8	168.7	168.9

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



TEST NUMBER: P997214

CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
67.5°	156.6	156.8	156.6	156.3	156.2	156.7
68°	152.4	152.7	152.4	152.2	152.1	152.5
68.5°	148.4	148.4	148.4	148.2	148.0	148.2
69°	144.0	144.1	144.0	143.6	143.7	144.0
69.5°	139.9	139.9	139.9	139.5	139.5	139.7
70°	135.6	135.7	135.6	135.5	135.4	135.6
70.5°	131.5	131.4	131.5	131.1	130.9	131.2
71°	127.2	127.2	127.2	126.9	126.8	127.1
71.5°	122.9	122.8	122.9	122.7	122.5	122.7
72°	118.6	118.6	118.6	118.2	118.2	118.3
72.5°	114.5	114.3	114.5	114.1	114.0	114.2
73°	110.2	110.1	110.2	109.8	109.8	109.7
73.5°	105.8	105.8	105.8	105.5	105.5	105.7
74°	101.5	101.7	101.5	101.5	101.5	101.6
74.5°	97.4	97.4	97.4	97.2	97.3	97.3
75°	93.2	93.1	93.2	93.0	93.0	93.0
75.5°	89.0	89.0	89.0	88.8	88.7	88.8
76°	84.6	84.7	84.6	84.6	84.5	84.7
76.5°	80.6	80.5	80.6	80.4	80.3	80.4
77°	76.5	76.6	76.5	76.4	76.3	76.2
77.5°	72.5	72.5	72.5	72.3	72.2	72.3
78°	68.5	68.6	68.5	68.3	68.2	68.3
78.5°	64.6	64.6	64.6	64.2	64.3	64.4
79°	60.5	60.6	60.5	60.4	60.4	60.5
79.5°	56.6	56.6	56.6	56.4	56.4	56.5
80°	52.7	52.7	52.7	52.5	52.4	52.5
80.5°	48.9	48.8	48.9	48.6	48.6	48.6
81°	45.0	45.0	45.0	44.9	44.8	44.9
81.5°	41.3	41.3	41.3	41.1	41.0	41.1
82°	37.6	37.7	37.6	37.4	37.3	37.3
82.5°	34.2	34.3	34.2	34.0	33.7	33.8
83°	30.8	30.9	30.8	30.5	30.4	30.4
83.5°	27.5	27.6	27.5	27.2	27.1	27.1
84°	24.3	24.4	24.3	24.1	24.0	24.0
84.5°	21.3	21.5	21.3	21.1	21.0	21.0
85°	18.5	18.7	18.5	18.1	18.1	18.1
85.5°	15.7	16.0	15.7	15.5	15.3	15.3
86°	13.2	13.5	13.2	13.0	12.8	12.7
86.5°	10.8	11.2	10.8	10.6	10.4	10.3
87°	8.7	9.0	8.7	8.5	8.3	8.2
87.5°	6.8	7.2	6.8	6.6	6.4	6.3
88°	5.1	5.5	5.1	4.9	4.6	4.6
88.5°	3.7	4.1	3.7	3.4	3.2	3.1

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



TEST NUMBER: P997214
CATALOG NUMBER: SMX6SLSFSD2W-1200LM-4000K

CANDELA DISTRIBUTION (continued):

	247.5°	270°	292.5°	315°	337.5°	360°
90°	0.0	0.0	0.0	0.0	0.0	0.0

Classified

Scaled Data Report

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269



Report Generated By 670245859 / DESKTOP-T8S5UU9

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - - 90°-270° - · - 135°-315°

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report





21.5°	442.3	441.3	441.3	442.0	442.4	442.0	441.3	441.3	442.3	441.3	441.3
22°	440.5	439.4	440.2	440.9	440.3	440.9	440.2	439.4	440.5	439.4	440.2



44°	331.3	330.6	331.0	331.6	331.4	331.6	331.0	330.6	331.3	330.6	331.0
44.5°	327.7	327.3	327.7	328.3	328.4	328.3	327.7	327.3	327.7	327.3	327.7



66.5°	164.9	164.5	164.6	165.1	165.1	164.6	164.5	164.9	164.5	164.6
67°	160.8	160.3	160.5	160.7	160.7	160.5	160.3	160.8	160.3	160.5

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



89°	1.9	2.0	2.3	2.5	2.9	2.5	2.3	2.0	1.9	2.0	2.3
89.5°	1.0	1.1	1.4	1.7	2.0	1.7	1.4	1.1	1.0	1.1	1.4

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



21.5°	442.0	442.4	442.0	441.3	441.3	442.3
22°	440.9	440.3	440.9	440.2	439.4	440.5

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



44°	331.6	331.4	331.6	331.0	330.6	331.3
44.5°	328.3	328.4	328.3	327.7	327.3	327.7

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



66.5°	165.1	165.1	165.1	164.6	164.5	164.9
67°	160.7	161.1	160.7	160.5	160.3	160.8

Classified
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



89°	2.5	2.9	2.5	2.3	2.0	1.9
89.5°	1.7	2.0	1.7	1.4	1.1	1.0

Classified

Cooper Lighting Solutions Photometric Lab

1121 Highway 74 South

Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)