

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1245503

Luminaire Tested: P3RT17R129027DE010 E3PHUSR1MMS

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1245503
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3RT17R129027DE010 E3PHUSR1MMS
Description: 3in Adjustable LED luminaire with, R12 optic, 2700K CCT AND, 90CRI , E3PHUSR1MMS TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1312.0 lumens
Efficiency: N/A
Efficacy: 57.3 lumens/watt
Spacing Criteria (0/90/45): 0.22 / 0.22 / 0.22
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 22.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1245503
CATALOG NUMBER: P3RT17R129027DE010 E3PHUSR1MMS

Luminous Intensity Polar Plot





TEST NUMBER: P1245503
 CATALOG NUMBER: P3RT17R129027DE010 E3PHUSR1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | | 0 | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 |
| RCR | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | 100 | 100 |
| 1 | 116 | 114 | 113 | 111 | 114 | 112 | 111 | 109 | 108 | 107 | 106 | 104 | 104 | 103 | 101 | 101 | 100 | 98 | 98 | 98 |
| 2 | 113 | 110 | 108 | 106 | 111 | 108 | 106 | 104 | 105 | 104 | 102 | 103 | 101 | 100 | 100 | 99 | 98 | 97 | 97 | 97 |
| 3 | 110 | 107 | 104 | 102 | 109 | 105 | 103 | 101 | 103 | 101 | 99 | 101 | 99 | 98 | 99 | 98 | 96 | 95 | 95 | 95 |
| 4 | 108 | 104 | 101 | 98 | 107 | 103 | 100 | 98 | 101 | 99 | 97 | 99 | 97 | 96 | 98 | 96 | 95 | 94 | 94 | 94 |
| 5 | 106 | 102 | 98 | 96 | 105 | 101 | 98 | 96 | 99 | 97 | 95 | 98 | 96 | 94 | 97 | 95 | 93 | 92 | 92 | 92 |
| 6 | 104 | 99 | 96 | 94 | 103 | 99 | 96 | 94 | 98 | 95 | 93 | 96 | 94 | 93 | 95 | 93 | 92 | 91 | 91 | 91 |
| 7 | 102 | 98 | 94 | 92 | 101 | 97 | 94 | 92 | 96 | 93 | 92 | 95 | 93 | 91 | 94 | 92 | 91 | 90 | 90 | 90 |
| 8 | 101 | 96 | 93 | 91 | 100 | 95 | 93 | 90 | 95 | 92 | 90 | 94 | 92 | 90 | 93 | 91 | 90 | 89 | 89 | 89 |
| 9 | 99 | 94 | 91 | 89 | 98 | 94 | 91 | 89 | 93 | 91 | 89 | 93 | 90 | 89 | 92 | 90 | 88 | 88 | 88 | 88 |
| 10 | 98 | 93 | 90 | 88 | 97 | 93 | 90 | 88 | 92 | 90 | 88 | 91 | 89 | 88 | 91 | 89 | 87 | 87 | 87 | 87 |

AVERAGE LUMINANCE (cd/sqm):

| | |
|-----|---------|
| | 0° |
| 0° | 4238454 |
| 5° | 2738580 |
| 10° | 772687 |
| 15° | 218480 |
| 20° | 91358 |
| 25° | 40454 |
| 30° | 20661 |
| 35° | 10922 |
| 40° | 4666 |
| 45° | 1271 |
| 50° | 1399 |
| 55° | 0 |
| 60° | 0 |
| 65° | 0 |
| 70° | 0 |
| 75° | 0 |
| 80° | 0 |
| 85° | 0 |

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 50°
 Luminance: 1399 cd/sqm



TEST NUMBER: P1245503

CATALOG NUMBER: P3RT17R129027DE010 E3PHUSR1MMS

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 876.6 | 66.8 |
| 10°-20° | 318.0 | 24.2 |
| 20°-30° | 85.2 | 6.5 |
| 30°-40° | 26.8 | 2.0 |
| 40°-50° | 5.0 | 0.4 |
| 50°-60° | 0.4 | 0.0 |
| 60°-70° | 0.0 | 0.0 |
| 70°-80° | 0.0 | 0.0 |
| 80°-90° | 0.0 | 0.0 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 1279.8 | 97.5 |
| 0°-40° | 1306.6 | 99.6 |
| 0°-60° | 1312.0 | 100.0 |
| 0°-90° | 1312.0 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 1312.0 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|-------|------|
| 0° | 19329 | |
| 5° | 12441 | 877 |
| 15° | 962 | 318 |
| 25° | 167 | 85 |
| 35° | 41 | 27 |
| 45° | 4 | 5 |
| 55° | 0 | 0 |
| 65° | 0 | 0 |
| 75° | 0 | 0 |
| 85° | 0 | 0 |
| 90° | 0 | |



TEST NUMBER: P1245503
CATALOG NUMBER: P3RT17R129027DE010 E3PHUSR1MMS

CANDELA DISTRIBUTION (FULL):

| 0° | |
|-------|---------|
| 0° | 19328.9 |
| 1° | 19002.6 |
| 2° | 18085.1 |
| 3° | 16515.2 |
| 4° | 14566.0 |
| 5° | 12441.4 |
| 6° | 10227.2 |
| 7° | 8245.4 |
| 8° | 6345.1 |
| 9° | 4722.1 |
| 10° | 3470.2 |
| 11° | 2556.8 |
| 12° | 1924.7 |
| 13° | 1492.5 |
| 14° | 1182.6 |
| 15° | 962.4 |
| 17.5° | 611.7 |
| 20° | 391.5 |
| 22.5° | 252.8 |
| 25° | 167.2 |
| 27.5° | 114.2 |
| 30° | 81.6 |
| 32.5° | 57.1 |
| 35° | 40.8 |
| 37.5° | 28.5 |
| 40° | 16.3 |
| 42.5° | 8.2 |
| 45° | 4.1 |
| 47.5° | 4.1 |
| 50° | 4.1 |
| 52.5° | 0.0 |
| 55° | 0.0 |
| 57.5° | 0.0 |
| 60° | 0.0 |
| 62.5° | 0.0 |
| 65° | 0.0 |
| 67.5° | 0.0 |
| 70° | 0.0 |
| 72.5° | 0.0 |
| 75° | 0.0 |
| 77.5° | 0.0 |
| 80° | 0.0 |
| 82.5° | 0.0 |
| 85° | 0.0 |
| 87.5° | 0.0 |



TEST NUMBER: P1245503
CATALOG NUMBER: P3RT17R129027DE010 E3PHUSR1MMS

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0

(END OF REPORT)