

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1303660

Luminaire Tested: P3RT05R129040DE010 E3CBUS1MMS

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1303660
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3RT05R129040DE010 E3CBUS1MMS
Description: 3in Adjustable LED luminaire with, R12 optic, 4000K CCT AND, 90CRI , E3CBUS1MMS TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 662.0 lumens
Efficiency: N/A
Efficacy: 87.1 lumens/watt
Spacing Criteria (0/90/45): 0.22 / 0.22 / 0.22
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1303660

CATALOG NUMBER: P3RT05R129040DE010 E3CBUS1MMS

Luminous Intensity Polar Plot



TEST NUMBER: P1303660

CATALOG NUMBER: P3RT05R129040DE010 E3CBUS1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100
1	116	114	113	111	114	112	111	109	108	107	106	104	104	103	101	101	100	98	98	98
2	113	110	108	106	111	108	106	104	105	104	102	103	101	100	100	99	98	97	97	97
3	110	107	104	102	109	105	103	101	103	101	99	101	99	98	99	98	96	95	95	95
4	108	104	101	98	107	103	100	98	101	99	97	99	97	96	98	96	95	94	94	94
5	106	102	98	96	105	101	98	96	99	97	95	98	96	94	96	95	93	92	92	92
6	104	99	96	94	103	99	96	94	98	95	93	96	94	93	95	93	92	91	91	91
7	102	98	94	92	101	97	94	92	96	93	92	95	93	91	94	92	91	90	90	90
8	101	96	93	91	100	95	93	90	95	92	90	94	92	90	93	91	90	89	89	89
9	99	94	91	89	98	94	91	89	93	91	89	93	90	89	92	90	88	88	88	88
10	98	93	90	88	97	93	90	88	92	90	88	91	89	88	91	89	87	87	87	87

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	2138601
5°	1381815
10°	389884
15°	110239
20°	46087
25°	20421
30°	10432
35°	5514
40°	2347
45°	651
50°	716
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 50°

Luminance: 716 cd/sqm

TEST NUMBER: P1303660

CATALOG NUMBER: P3RT05R129040DE010 E3CBUS1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	442.3	66.8
10°-20°	160.5	24.2
20°-30°	43.0	6.5
30°-40°	13.5	2.0
40°-50°	2.5	0.4
50°-60°	0.2	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	645.7	97.5
0°-40°	659.3	99.6
0°-60°	662.0	100.0
0°-90°	662.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	662.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	9753	
5°	6278	442
15°	486	160
25°	84	43
35°	21	14
45°	2	3
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	

TEST NUMBER: P1303660

CATALOG NUMBER: P3RT05R129040DE010 E3CBUS1MMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	9752.8
1°	9588.2
2°	9125.3
3°	8333.1
4°	7349.6
5°	6277.6
6°	5160.4
7°	4160.4
8°	3201.6
9°	2382.7
10°	1751.0
11°	1290.1
12°	971.2
13°	753.1
14°	596.7
15°	485.6
17.5°	308.6
20°	197.5
22.5°	127.6
25°	84.4
27.5°	57.6
30°	41.2
32.5°	28.8
35°	20.6
37.5°	14.4
40°	8.2
42.5°	4.1
45°	2.1
47.5°	2.1
50°	2.1
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0



TEST NUMBER: P1303660

CATALOG NUMBER: P3RT05R129040DE010 E3CBUS1MMS

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0

(END OF REPORT)