

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1303824

Luminaire Tested: P3RT09R409050DE010 E3CBUS1MW

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1303824
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2510-583-90)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3RT09R409050DE010 E3CBUS1MW
Description: 3in Adjustable LED luminaire with, R40 optic, 5000K CCT AND, 90CRI , E3CBUS1MW TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1174.0 lumens
Efficiency: N/A
Efficacy: 105.8 lumens/watt
Spacing Criteria (0/90/45): 0.64 / 0.64 / 0.55
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1303824

CATALOG NUMBER: P3RT09R409050DE010 E3CBUS1MW

Luminous Intensity Polar Plot



TEST NUMBER: P1303824

CATALOG NUMBER: P3RT09R409050DE010 E3CBUS1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		0
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		100
1	115	113	111	109	113	111	109	107	107	105	104		103	102	101		96
2	111	107	104	102	109	106	103	101	103	100	98		100	98	96		93
3	107	103	99	96	106	101	98	95	99	96	94		97	94	92		90
4	104	98	94	91	102	97	94	91	95	92	90		94	91	89		87
5	101	95	90	87	99	94	90	87	92	89	86		91	88	86		84
6	98	91	87	84	96	90	86	84	89	86	83		88	85	83		81
7	95	88	84	81	94	87	83	80	86	83	80		85	82	80		78
8	92	85	81	78	91	85	80	78	84	80	77		83	79	77		76
9	89	82	78	75	88	82	78	75	81	77	75		80	77	75		73
10	87	80	76	73	86	79	75	73	79	75	73		78	75	72		71

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	721806
5°	715032
10°	672310
15°	553965
20°	306767
25°	88965
30°	21953
35°	7897
40°	1975
45°	0
50°	0
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 0 cd/sqm

TEST NUMBER: P1303824

CATALOG NUMBER: P3RT09R409050DE010 E3CBUS1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	303.0	25.8
10°-20°	638.7	54.4
20°-30°	210.2	17.9
30°-40°	21.2	1.8
40°-50°	0.9	0.1
50°-60°	0.0	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1151.9	98.1
0°-40°	1173.1	99.9
0°-60°	1174.0	100.0
0°-90°	1174.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1174.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3292	
5°	3248	303
15°	2440	639
25°	368	210
35°	30	21
45°	0	1
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	

TEST NUMBER: P1303824

CATALOG NUMBER: P3RT09R409050DE010 E3CBUS1MW

CANDELA DISTRIBUTION (FULL):

0°	
0°	3291.7
2.5°	3286.5
5°	3248.4
7.5°	3168.6
10°	3019.4
12.5°	2788.8
15°	2440.2
17.5°	1959.8
20°	1314.6
22.5°	709.3
25°	367.7
27.5°	175.2
30°	86.7
32.5°	48.6
35°	29.5
37.5°	15.6
40°	6.9
42.5°	1.7
45°	0.0
47.5°	0.0
50°	0.0
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)