

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1303830

Luminaire Tested: P3RT10R129050DE010 E3BUS1B

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1303830
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3RT10R129050DE010 E3BUS1B
Description: 3in Adjustable LED luminaire with, R12 optic, 5000K CCT AND, 90CRI , E3BUS1B TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 960.0 lumens
Efficiency: N/A
Efficacy: 82.1 lumens/watt
Spacing Criteria (0/90/45): 0.22 / 0.22 / 0.22
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11.7
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1303830

CATALOG NUMBER: P3RT10R129050DE010 E3BUS1B

Luminous Intensity Polar Plot



TEST NUMBER: P1303830

CATALOG NUMBER: P3RT10R129050DE010 E3BUS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	116	114	113	111	114	112	111	109	108	107	106		104	104	103		101
2	113	110	108	106	111	108	106	104	105	104	102		103	101	100		100
3	110	107	104	102	109	105	103	101	103	101	99		101	99	98		99
4	108	104	101	98	107	103	100	98	101	99	97		99	97	96		98
5	106	102	98	96	105	101	98	96	99	97	95		98	96	94		97
6	104	99	96	94	103	99	96	94	98	95	93		96	94	93		95
7	102	98	94	92	101	97	94	92	96	93	92		95	93	91		94
8	101	96	93	91	100	95	93	90	95	92	90		94	92	90		93
9	99	94	91	89	98	94	91	89	93	91	89		93	90	89		92
10	98	93	90	88	97	93	90	88	92	90	88		91	89	88		91

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	3101309
5°	2003847
10°	565387
15°	159865
20°	66832
25°	29590
30°	15116
35°	7977
40°	3406
45°	930
50°	1023
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 50°

Luminance: 1023 cd/sqm

TEST NUMBER: P1303830

CATALOG NUMBER: P3RT10R129050DE010 E3BUS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	641.4	66.8
10°-20°	232.7	24.2
20°-30°	62.3	6.5
30°-40°	19.6	2.0
40°-50°	3.7	0.4
50°-60°	0.3	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	936.4	97.5
0°-40°	956.0	99.6
0°-60°	960.0	100.0
0°-90°	960.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	960.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14143	
5°	9104	641
15°	704	233
25°	122	62
35°	30	20
45°	3	4
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	

TEST NUMBER: P1303830

CATALOG NUMBER: P3RT10R129050DE010 E3BUS1B

CANDELA DISTRIBUTION (FULL):

0°	
0°	14143.1
1°	13904.4
2°	13233.0
3°	12084.3
4°	10658.0
5°	9103.5
6°	7483.3
7°	6033.2
8°	4642.7
9°	3455.2
10°	2539.2
11°	1870.8
12°	1408.3
13°	1092.1
14°	865.3
15°	704.2
17.5°	447.6
20°	286.4
22.5°	185.0
25°	122.3
27.5°	83.5
30°	59.7
32.5°	41.8
35°	29.8
37.5°	20.9
40°	11.9
42.5°	6.0
45°	3.0
47.5°	3.0
50°	3.0
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0



TEST NUMBER: P1303830
CATALOG NUMBER: P3RT10R129050DE010 E3BUS1B

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0

(END OF REPORT)