

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1245677

Luminaire Tested: P3AS02R259024DE010 E3PHLP1MW

Issue Date: 1/29/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1245677  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2509-551-7)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/29/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS02R259024DE010 E3PHLP1MW  
Description: 3in Adjustable LED luminaire with, R25 optic, 2400K CCT AND, 90CRI , E3PHLP1MW TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 124.0 lumens  
Efficiency: N/A  
Efficacy: 34.5 lumens/watt  
Spacing Criteria (0/90/45): 0.59 / 0.59 / 0.65  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct

Input Watts (W): 3.6  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1245677

CATALOG NUMBER: P3AS02R259024DE010 E3PHLP1MW

### Luminous Intensity Polar Plot



TEST NUMBER: P1245677

CATALOG NUMBER: P3AS02R259024DE010 E3PHLP1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |  | 20  |     |     |  | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |  | 30  |     |     |  | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 |
| 1   | 112 | 108 | 105 | 102 | 109 | 106 | 103 | 101 | 102 | 100 | 97  |  | 98  | 96  | 95  |  | 95  |
| 2   | 105 | 99  | 94  | 90  | 103 | 97  | 93  | 89  | 94  | 90  | 87  |  | 91  | 88  | 85  |  | 88  |
| 3   | 99  | 91  | 85  | 80  | 97  | 90  | 84  | 80  | 87  | 82  | 78  |  | 84  | 80  | 77  |  | 82  |
| 4   | 93  | 84  | 78  | 73  | 91  | 83  | 77  | 73  | 81  | 76  | 72  |  | 79  | 74  | 71  |  | 77  |
| 5   | 88  | 79  | 72  | 67  | 86  | 78  | 71  | 67  | 76  | 70  | 66  |  | 74  | 69  | 66  |  | 72  |
| 6   | 84  | 74  | 67  | 62  | 82  | 73  | 66  | 62  | 71  | 66  | 61  |  | 70  | 65  | 61  |  | 68  |
| 7   | 79  | 69  | 63  | 58  | 78  | 68  | 62  | 58  | 67  | 61  | 57  |  | 66  | 61  | 57  |  | 65  |
| 8   | 76  | 65  | 59  | 54  | 74  | 65  | 58  | 54  | 63  | 58  | 54  |  | 62  | 57  | 54  |  | 61  |
| 9   | 72  | 62  | 55  | 51  | 71  | 61  | 55  | 51  | 60  | 55  | 51  |  | 59  | 54  | 51  |  | 58  |
| 10  | 69  | 59  | 52  | 48  | 68  | 58  | 52  | 48  | 57  | 52  | 48  |  | 56  | 51  | 48  |  | 56  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |       |
|-----|-------|
|     | 0°    |
| 0°  | 41663 |
| 5°  | 39357 |
| 10° | 33466 |
| 15° | 26493 |
| 20° | 20138 |
| 25° | 15025 |
| 30° | 10938 |
| 35° | 7736  |
| 40° | 5238  |
| 45° | 3659  |
| 50° | 3070  |
| 55° | 2982  |
| 60° | 3114  |
| 65° | 3217  |
| 70° | 3206  |
| 75° | 3389  |
| 80° | 3915  |
| 85° | 4026  |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
Vertical Angle: 82.5°  
Luminance: 4200 cd/sqm

TEST NUMBER: P1245677

CATALOG NUMBER: P3AS02R259024DE010 E3PHLP1MW

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 16.1   | 13.0      |
| 10°-20°   | 32.3   | 26.0      |
| 20°-30°   | 28.6   | 23.1      |
| 30°-40°   | 18.2   | 14.7      |
| 40°-50°   | 9.6    | 7.8       |
| 50°-60°   | 7.1    | 5.7       |
| 60°-70°   | 6.0    | 4.9       |
| 70°-80°   | 4.3    | 3.4       |
| 80°-90°   | 1.7    | 1.4       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 77.1   | 62.1      |
| 0°-40°    | 95.3   | 76.8      |
| 0°-60°    | 112.0  | 90.3      |
| 0°-90°    | 124.0  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 124.0  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°  | Flux |
|-----|-----|------|
| 0°  | 190 |      |
| 5°  | 179 | 16   |
| 15° | 117 | 32   |
| 25° | 62  | 29   |
| 35° | 29  | 18   |
| 45° | 12  | 10   |
| 55° | 8   | 7    |
| 65° | 6   | 6    |
| 75° | 4   | 4    |
| 85° | 2   | 2    |
| 90° | 0   |      |

TEST NUMBER: P1245677

CATALOG NUMBER: P3AS02R259024DE010 E3PHLP1MW

**CANDELA DISTRIBUTION (FULL):**

| 0°    |       |
|-------|-------|
| 0°    | 190.0 |
| 2.5°  | 187.2 |
| 5°    | 178.8 |
| 7.5°  | 165.8 |
| 10°   | 150.3 |
| 12.5° | 133.5 |
| 15°   | 116.7 |
| 17.5° | 100.6 |
| 20°   | 86.3  |
| 22.5° | 73.3  |
| 25°   | 62.1  |
| 27.5° | 52.2  |
| 30°   | 43.2  |
| 32.5° | 35.4  |
| 35°   | 28.9  |
| 37.5° | 23.0  |
| 40°   | 18.3  |
| 42.5° | 14.6  |
| 45°   | 11.8  |
| 47.5° | 10.2  |
| 50°   | 9.0   |
| 52.5° | 8.4   |
| 55°   | 7.8   |
| 57.5° | 7.5   |
| 60°   | 7.1   |
| 62.5° | 6.5   |
| 65°   | 6.2   |
| 67.5° | 5.6   |
| 70°   | 5.0   |
| 72.5° | 4.7   |
| 75°   | 4.0   |
| 77.5° | 3.4   |
| 80°   | 3.1   |
| 82.5° | 2.5   |
| 85°   | 1.6   |
| 87.5° | 0.6   |
| 90°   | 0.0   |

(END OF REPORT)