

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1245822

Luminaire Tested: P3AS02R559024DE010 E3CB1MMS

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1245822
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-36)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS02R559024DE010 E3CB1MMS
Description: 3in Adjustable LED luminaire with, R55 optic, 2400K CCT AND, 90CRI , E3CB1MMS TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 286.0 lumens
Efficiency: N/A
Efficacy: 79.4 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.82
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 3.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1245822

CATALOG NUMBER: P3AS02R559024DE010 E3CB1MMS

Luminous Intensity Polar Plot



TEST NUMBER: P1245822

CATALOG NUMBER: P3AS02R559024DE010 E3CB1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20
RC	80					70					50					30					10
RW	70	50	30	10		70	50	30	10		50	30	10		50	30	10		50	30	10
RCR																					
0	119	119	119	119		116	116	116	116		111	111	111		106	106	106		102	102	102
1	114	111	109	107		112	109	107	105		105	104	102		101	100	99		98	97	96
2	109	104	101	98		107	103	99	96		100	97	94		97	94	92		94	92	90
3	104	98	94	90		102	97	93	89		94	91	88		92	89	86		90	87	85
4	99	92	87	84		98	91	87	83		89	85	82		87	84	81		86	83	80
5	95	87	82	78		93	86	81	78		85	80	77		83	79	76		82	78	76
6	91	83	77	73		89	82	77	73		80	76	72		79	75	72		78	74	72
7	87	78	73	69		85	78	72	69		76	72	68		75	71	68		74	70	68
8	83	74	69	65		82	74	69	65		73	68	65		72	67	64		71	67	64
9	79	71	65	61		78	70	65	61		69	64	61		68	64	61		68	64	61
10	76	67	62	58		75	67	62	58		66	61	58		65	61	58		65	61	58

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	79314
5°	78582
10°	81740
15°	80613
20°	74323
25°	60487
30°	36740
35°	12715
40°	3635
45°	1737
50°	716
55°	344
60°	395
65°	311
70°	256
75°	339
80°	253
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 1737 cd/sqm

TEST NUMBER: P1245822

CATALOG NUMBER: P3AS02R559024DE010 E3CB1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	34.5	12.1
10°-20°	98.7	34.5
20°-30°	110.0	38.5
30°-40°	36.0	12.6
40°-50°	4.8	1.7
50°-60°	1.0	0.4
60°-70°	0.6	0.2
70°-80°	0.3	0.1
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	243.2	85.0
0°-40°	279.2	97.6
0°-60°	285.0	99.7
0°-90°	286.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	286.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	362	
5°	357	35
15°	355	99
25°	250	110
35°	48	36
45°	6	5
55°	1	1
65°	1	1
75°	0	0
85°	0	0
90°	0	

TEST NUMBER: P1245822

CATALOG NUMBER: P3AS02R559024DE010 E3CB1MMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	361.7
2.5°	359.2
5°	357.0
7.5°	362.2
10°	367.1
12.5°	364.5
15°	355.1
17.5°	340.0
20°	318.5
22.5°	288.9
25°	250.0
27.5°	200.5
30°	145.1
32.5°	89.0
35°	47.5
37.5°	24.1
40°	12.7
42.5°	8.2
45°	5.6
47.5°	3.9
50°	2.1
52.5°	1.3
55°	0.9
57.5°	0.9
60°	0.9
62.5°	0.6
65°	0.6
67.5°	0.4
70°	0.4
72.5°	0.4
75°	0.4
77.5°	0.2
80°	0.2
82.5°	0.2
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)