

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1246041

Luminaire Tested: P3AS05R209024DE010 E3D1WMH

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1246041
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-8)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS05R209024DE010 E3D1WMH
Description: 3in Adjustable LED luminaire with, R20 optic, 2400K CCT AND, 90CRI , E3D1WMH TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 554.0 lumens
Efficiency: N/A
Efficacy: 76.9 lumens/watt
Spacing Criteria (0/90/45): 0.35 / 0.35 / 0.34
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1246041
CATALOG NUMBER: P3AS05R209024DE010 E3D1WMH

Luminous Intensity Polar Plot





TEST NUMBER: P1246041
 CATALOG NUMBER: P3AS05R209024DE010 E3D1WMH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|-----|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | | | 0 | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | 100 | 99 | 100 |
| 1 | 115 | 114 | 112 | 110 | 113 | 111 | 110 | 108 | 107 | 106 | 105 | 104 | 103 | 102 | 100 | 100 | 99 | 99 | 98 | 96 | 97 |
| 2 | 112 | 109 | 106 | 104 | 110 | 107 | 105 | 103 | 104 | 102 | 101 | 101 | 100 | 98 | 99 | 98 | 96 | 97 | 95 | 94 | 95 |
| 3 | 109 | 105 | 102 | 99 | 107 | 104 | 101 | 98 | 101 | 99 | 97 | 99 | 97 | 95 | 97 | 95 | 94 | 97 | 95 | 94 | 93 |
| 4 | 106 | 101 | 98 | 95 | 105 | 100 | 97 | 95 | 99 | 96 | 94 | 97 | 95 | 93 | 95 | 93 | 92 | 95 | 93 | 92 | 91 |
| 5 | 104 | 98 | 95 | 92 | 102 | 98 | 94 | 92 | 96 | 93 | 91 | 95 | 92 | 90 | 93 | 91 | 90 | 93 | 91 | 90 | 89 |
| 6 | 101 | 96 | 92 | 89 | 100 | 95 | 92 | 89 | 94 | 91 | 89 | 93 | 90 | 88 | 92 | 89 | 88 | 92 | 89 | 88 | 87 |
| 7 | 99 | 93 | 90 | 87 | 98 | 93 | 89 | 87 | 92 | 89 | 86 | 91 | 88 | 86 | 90 | 87 | 86 | 90 | 87 | 86 | 85 |
| 8 | 97 | 91 | 87 | 85 | 96 | 91 | 87 | 85 | 90 | 87 | 85 | 89 | 86 | 84 | 88 | 86 | 84 | 88 | 86 | 84 | 83 |
| 9 | 95 | 89 | 85 | 83 | 94 | 89 | 85 | 83 | 88 | 85 | 83 | 87 | 84 | 83 | 87 | 84 | 82 | 87 | 84 | 82 | 81 |
| 10 | 93 | 87 | 84 | 81 | 92 | 87 | 83 | 81 | 86 | 83 | 81 | 86 | 83 | 81 | 85 | 83 | 81 | 85 | 83 | 81 | 80 |

AVERAGE LUMINANCE (cd/sqm):

| | |
|-----|--------|
| | 0° |
| 0° | 840371 |
| 5° | 707548 |
| 10° | 441942 |
| 15° | 165222 |
| 20° | 56705 |
| 25° | 23638 |
| 30° | 11141 |
| 35° | 4979 |
| 40° | 2347 |
| 45° | 1209 |
| 50° | 443 |
| 55° | 76 |
| 60° | 88 |
| 65° | 104 |
| 70° | 0 |
| 75° | 0 |
| 80° | 0 |
| 85° | 0 |

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 1209 cd/sqm



TEST NUMBER: P1246041
 CATALOG NUMBER: P3AS05R209024DE010 E3D1WMH

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 267.3 | 48.3 |
| 10°-20° | 220.2 | 39.7 |
| 20°-30° | 50.0 | 9.0 |
| 30°-40° | 12.7 | 2.3 |
| 40°-50° | 3.2 | 0.6 |
| 50°-60° | 0.4 | 0.1 |
| 60°-70° | 0.1 | 0.0 |
| 70°-80° | 0.0 | 0.0 |
| 80°-90° | 0.0 | 0.0 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 537.5 | 97.0 |
| 0°-40° | 550.3 | 99.3 |
| 0°-60° | 553.8 | 100.0 |
| 0°-90° | 554.0 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 554.0 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|------|------|
| 0° | 3832 | |
| 5° | 3214 | 267 |
| 15° | 728 | 220 |
| 25° | 98 | 50 |
| 35° | 19 | 13 |
| 45° | 4 | 3 |
| 55° | 0 | 0 |
| 65° | 0 | 0 |
| 75° | 0 | 0 |
| 85° | 0 | 0 |
| 90° | 0 | |



TEST NUMBER: P1246041

CATALOG NUMBER: P3AS05R209024DE010 E3D1WMH

CANDELA DISTRIBUTION (FULL):

| 0° | |
|-------|--------|
| 0° | 3832.4 |
| 1° | 3799.9 |
| 2° | 3704.2 |
| 3° | 3566.8 |
| 4° | 3398.3 |
| 5° | 3214.4 |
| 6° | 3009.5 |
| 7° | 2783.4 |
| 8° | 2519.6 |
| 9° | 2258.1 |
| 10° | 1984.8 |
| 11° | 1693.9 |
| 12° | 1403.4 |
| 13° | 1157.3 |
| 14° | 922.1 |
| 15° | 727.8 |
| 16° | 574.4 |
| 17° | 453.1 |
| 18° | 364.1 |
| 19° | 296.1 |
| 20° | 243.0 |
| 21° | 203.2 |
| 22° | 169.6 |
| 23° | 141.0 |
| 24° | 117.6 |
| 25° | 97.7 |
| 27.5° | 63.9 |
| 30° | 44.0 |
| 32.5° | 27.1 |
| 35° | 18.6 |
| 37.5° | 11.9 |
| 40° | 8.2 |
| 42.5° | 5.6 |
| 45° | 3.9 |
| 47.5° | 2.6 |
| 50° | 1.3 |
| 52.5° | 0.6 |
| 55° | 0.2 |
| 57.5° | 0.2 |
| 60° | 0.2 |
| 62.5° | 0.2 |
| 65° | 0.2 |
| 67.5° | 0.0 |
| 70° | 0.0 |
| 72.5° | 0.0 |



TEST NUMBER: P1246041
CATALOG NUMBER: P3AS05R209024DE010 E3D1WMH

CANDELA DISTRIBUTION (continued):

| | 0° |
|-------|-----|
| 75° | 0.0 |
| 77.5° | 0.0 |
| 80° | 0.0 |
| 82.5° | 0.0 |
| 85° | 0.0 |
| 87.5° | 0.0 |
| 90° | 0.0 |

(END OF REPORT)