

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1253453

Luminaire Tested: P3AS02R259035DE010 E3DLD1LI

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1253453
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-10)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS02R259035DE010 E3DLD1LI
Description: 3in Adjustable LED luminaire with, R25 optic, 3500K CCT AND, 90CRI , E3DLD1LI TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 201.1 lumens
Efficiency: N/A
Efficacy: 55.9 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.85
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 3.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1253453

CATALOG NUMBER: P3AS02R259035DE010 E3DLD1LI

Luminous Intensity Polar Plot





TEST NUMBER: P1253453

CATALOG NUMBER: P3AS02R259035DE010 E3DLD1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	98	96		96
2	106	100	96	92	104	99	94	91	95	92	89		92	89	87		89
3	100	92	87	82	98	91	86	82	88	84	80		86	82	79		83
4	94	85	79	74	92	84	78	74	82	77	73		80	76	72		78
5	89	79	73	68	87	78	72	68	76	71	67		75	70	66		73
6	84	74	67	62	82	73	67	62	71	66	62		70	65	61		69
7	79	69	62	58	78	68	62	58	67	61	57		66	61	57		65
8	75	65	58	54	74	64	58	53	63	57	53		62	57	53		61
9	71	61	54	50	70	60	54	50	59	54	50		58	53	49		57
10	68	57	51	47	67	57	51	47	56	50	47		55	50	46		54

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	47781
5°	46621
10°	43219
15°	38479
20°	33066
25°	28115
30°	23143
35°	18042
40°	12967
45°	8218
50°	4878
55°	3364
60°	3070
65°	2854
70°	2565
75°	2372
80°	2273
85°	2013

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 8218 cd/sqm

TEST NUMBER: P1253453

CATALOG NUMBER: P3AS02R259035DE010 E3DLD1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	19.6	9.8
10°-20°	47.1	23.4
20°-30°	53.2	26.4
30°-40°	42.1	20.9
40°-50°	21.2	10.6
50°-60°	8.5	4.2
60°-70°	5.5	2.7
70°-80°	3.0	1.5
80°-90°	0.9	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	119.9	59.6
0°-40°	161.9	80.5
0°-60°	191.7	95.3
0°-90°	201.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	201.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	218	
5°	212	20
15°	170	47
25°	116	53
35°	67	42
45°	26	21
55°	9	9
65°	6	5
75°	3	3
85°	1	1
90°	0	

TEST NUMBER: P1253453

CATALOG NUMBER: P3AS02R259035DE010 E3DLD1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	217.9
1°	217.9
2°	217.1
3°	215.8
4°	214.1
5°	211.8
6°	209.1
7°	205.8
8°	202.3
9°	198.3
10°	194.1
11°	189.3
12°	184.8
13°	179.5
14°	174.5
15°	169.5
17.5°	155.5
20°	141.7
22.5°	128.7
25°	116.2
27.5°	103.9
30°	91.4
32.5°	79.6
35°	67.4
37.5°	56.1
40°	45.3
42.5°	35.3
45°	26.5
47.5°	19.8
50°	14.3
52.5°	10.8
55°	8.8
57.5°	8.0
60°	7.0
62.5°	6.3
65°	5.5
67.5°	4.8
70°	4.0
72.5°	3.5
75°	2.8
77.5°	2.3
80°	1.8
82.5°	1.3
85°	0.8
87.5°	0.3



TEST NUMBER: P1253453

CATALOG NUMBER: P3AS02R259035DE010 E3DLD1LI

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0

(END OF REPORT)