

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1256244

Luminaire Tested: P3AS02R409040DE010 E3DL1GPH

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1256244
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-23)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS02R409040DE010 E3DL1GPH
Description: 3in Adjustable LED luminaire with, R40 optic, 4000K CCT AND, 90CRI , E3DL1GPH TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 150.0 lumens
Efficiency: N/A
Efficacy: 41.7 lumens/watt
Spacing Criteria (0/90/45): 0.65 / 0.65 / 0.63
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 3.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1256244

CATALOG NUMBER: P3AS02R409040DE010 E3DL1GPH

Luminous Intensity Polar Plot



TEST NUMBER: P1256244

CATALOG NUMBER: P3AS02R409040DE010 E3DL1GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	109	107	112	109	107	105	105	104	102		102	100	99		98
2	109	105	101	98	107	103	100	97	100	97	95		97	95	93		94
3	104	99	94	91	102	97	93	90	95	91	88		92	89	87		90
4	100	93	88	85	98	92	88	84	90	86	83		88	85	82		86
5	96	88	83	79	94	88	83	79	86	82	78		84	81	78		83
6	92	84	79	75	91	83	78	75	82	78	74		81	77	74		79
7	88	80	75	71	87	79	74	71	78	74	71		77	73	70		76
8	85	76	71	68	84	76	71	67	75	70	67		74	70	67		73
9	82	73	68	64	81	73	68	64	72	67	64		71	67	64		70
10	78	70	65	62	78	70	65	61	69	64	61		68	64	61		67

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	66376
5°	64451
10°	58471
15°	48309
20°	34840
25°	21558
30°	11673
35°	6023
40°	3292
45°	1830
50°	921
55°	688
60°	614
65°	623
70°	577
75°	508
80°	505
85°	252

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 1830 cd/sqm

TEST NUMBER: P1256244

CATALOG NUMBER: P3AS02R409040DE010 E3DL1GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	27.0	18.0
10°-20°	57.9	38.6
20°-30°	41.4	27.6
30°-40°	15.2	10.2
40°-50°	4.8	3.2
50°-60°	1.7	1.1
60°-70°	1.2	0.8
70°-80°	0.7	0.4
80°-90°	0.2	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	126.3	84.2
0°-40°	141.5	94.4
0°-60°	148.0	98.7
0°-90°	150.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	150.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	303	
5°	293	27
15°	213	58
25°	89	41
35°	22	15
45°	6	5
55°	2	2
65°	1	1
75°	1	1
85°	0	0
90°	0	

TEST NUMBER: P1256244

CATALOG NUMBER: P3AS02R409040DE010 E3DL1GPH

CANDELA DISTRIBUTION (FULL):

0°	
0°	302.7
2.5°	300.4
5°	292.8
7.5°	280.2
10°	262.6
12.5°	240.4
15°	212.8
17.5°	181.9
20°	149.3
22.5°	117.3
25°	89.1
27.5°	65.4
30°	46.1
32.5°	32.3
35°	22.5
37.5°	16.0
40°	11.5
42.5°	8.2
45°	5.9
47.5°	4.0
50°	2.7
52.5°	1.9
55°	1.8
57.5°	1.7
60°	1.4
62.5°	1.3
65°	1.2
67.5°	1.0
70°	0.9
72.5°	0.8
75°	0.6
77.5°	0.5
80°	0.4
82.5°	0.3
85°	0.1
87.5°	0.1
90°	0.0

(END OF REPORT)