

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1257034

Luminaire Tested: P3AS09R409040DE010 E3DLD1H

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1257034
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-22)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS09R409040DE010 E3DLD1H
Description: 3in Adjustable LED luminaire with, R40 optic, 4000K CCT AND, 90CRI , E3DLD1H TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 703.0 lumens
Efficiency: N/A
Efficacy: 63.3 lumens/watt
Spacing Criteria (0/90/45): 0.83 / 0.83 / 0.88
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1257034

CATALOG NUMBER: P3AS09R409040DE010 E3DLD1H

Luminous Intensity Polar Plot



TEST NUMBER: P1257034

CATALOG NUMBER: P3AS09R409040DE010 E3DLD1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	98	96		96
2	106	100	96	92	104	98	94	91	95	92	89		92	89	87		89
3	100	92	87	82	98	91	86	81	88	84	80		86	82	79		83
4	94	85	79	74	92	84	78	74	82	77	73		80	75	72		78
5	89	79	73	68	87	78	72	67	76	71	67		75	70	66		73
6	84	74	67	62	82	73	67	62	71	66	61		70	65	61		68
7	79	69	62	57	78	68	62	57	67	61	57		65	60	57		64
8	75	64	58	53	74	64	57	53	63	57	53		62	56	53		61
9	71	60	54	50	70	60	54	50	59	53	49		58	53	49		57
10	67	57	51	46	66	56	50	46	56	50	46		55	50	46		54

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	157816
5°	154941
10°	146067
15°	132668
20°	116537
25°	99514
30°	82443
35°	63577
40°	45256
45°	30484
50°	16648
55°	11737
60°	11052
65°	10222
70°	9104
75°	8642
80°	6945
85°	6038

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 30484 cd/sqm

TEST NUMBER: P1257034

CATALOG NUMBER: P3AS09R409040DE010 E3DLD1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	65.7	9.3
10°-20°	162.8	23.2
20°-30°	188.2	26.8
30°-40°	148.3	21.1
40°-50°	76.1	10.8
50°-60°	29.1	4.1
60°-70°	19.3	2.7
70°-80°	10.5	1.5
80°-90°	3.1	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	416.6	59.3
0°-40°	564.9	80.4
0°-60°	670.2	95.3
0°-90°	703.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	703.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	720	
5°	704	66
15°	584	163
25°	411	188
35°	238	148
45°	98	76
55°	31	29
65°	20	19
75°	10	10
85°	2	3
90°	0	

TEST NUMBER: P1257034

CATALOG NUMBER: P3AS09R409040DE010 E3DLD1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	719.7
2.5°	715.7
5°	703.9
7.5°	683.5
10°	656.0
12.5°	623.7
15°	584.4
17.5°	543.5
20°	499.4
22.5°	454.6
25°	411.3
27.5°	368.1
30°	325.6
32.5°	282.4
35°	237.5
37.5°	195.8
40°	158.1
42.5°	125.8
45°	98.3
47.5°	71.6
50°	48.8
52.5°	35.4
55°	30.7
57.5°	27.5
60°	25.2
62.5°	22.0
65°	19.7
67.5°	16.5
70°	14.2
72.5°	11.8
75°	10.2
77.5°	7.9
80°	5.5
82.5°	4.7
85°	2.4
87.5°	1.6
90°	0.0

(END OF REPORT)