

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1257424

Luminaire Tested: P3AS13R409040DE010 E3CB1MMS

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1257424
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-24)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS13R409040DE010 E3CB1MMS
Description: 3in Adjustable LED luminaire with, R40 optic, 4000K CCT AND, 90CRI , E3CB1MMS TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1468.9 lumens
Efficiency: N/A
Efficacy: 100.6 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.59
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 14.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1257424

CATALOG NUMBER: P3AS13R409040DE010 E3CB1MMS

Luminous Intensity Polar Plot



TEST NUMBER: P1257424

CATALOG NUMBER: P3AS13R409040DE010 E3CB1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	115	112	110	109	112	110	109	107	106	105	104		103	102	101		99
2	111	107	104	101	109	105	102	100	102	100	98		99	97	96		96
3	107	102	98	95	105	100	97	94	98	95	93		96	93	91		94
4	103	97	93	90	102	96	92	89	94	91	88		92	90	87		91
5	100	93	89	86	98	92	88	85	91	87	85		89	86	84		88
6	96	90	85	82	95	89	85	82	88	84	81		86	83	81		85
7	93	86	82	79	92	86	81	78	85	81	78		83	80	78		82
8	90	83	79	76	89	83	78	75	82	78	75		81	77	75		80
9	87	80	76	73	87	80	76	73	79	75	72		78	75	72		77
10	85	77	73	70	84	77	73	70	76	73	70		76	72	70		75

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	773469
5°	769754
10°	744653
15°	658823
20°	429837
25°	152259
30°	32283
35°	10627
40°	3893
45°	1302
50°	1058
55°	1185
60°	921
65°	1090
70°	641
75°	847
80°	1263
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 82.5°

Luminance: 1680 cd/sqm

TEST NUMBER: P1257424

CATALOG NUMBER: P3AS13R409040DE010 E3CB1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	329.0	22.4
10°-20°	766.3	52.2
20°-30°	332.5	22.6
30°-40°	30.6	2.1
40°-50°	4.3	0.3
50°-60°	2.7	0.2
60°-70°	1.9	0.1
70°-80°	1.1	0.1
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1427.8	97.2
0°-40°	1458.5	99.3
0°-60°	1465.5	99.8
0°-90°	1468.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1468.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3527	
5°	3497	329
15°	2902	766
25°	629	333
35°	40	31
45°	4	4
55°	3	3
65°	2	2
75°	1	1
85°	0	0
90°	0	

TEST NUMBER: P1257424

CATALOG NUMBER: P3AS13R409040DE010 E3CB1MMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	3527.3
2.5°	3523.1
5°	3497.0
7.5°	3441.6
10°	3344.3
12.5°	3180.2
15°	2902.1
17.5°	2441.1
20°	1842.0
22.5°	1196.0
25°	629.3
27.5°	270.8
30°	127.5
32.5°	69.0
35°	39.7
37.5°	24.0
40°	13.6
42.5°	7.3
45°	4.2
47.5°	3.1
50°	3.1
52.5°	3.1
55°	3.1
57.5°	3.1
60°	2.1
62.5°	2.1
65°	2.1
67.5°	2.1
70°	1.0
72.5°	1.0
75°	1.0
77.5°	1.0
80°	1.0
82.5°	1.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)