

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1258181

Luminaire Tested: P3AS20R459040D010 E3DL1H

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1258181
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-27)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS20R459040D010 E3DL1H
Description: 3in Adjustable LED luminaire with, R45 optic, 4000K CCT AND, 90CRI , E3DL1H TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2033.0 lumens
Efficiency: N/A
Efficacy: 70.6 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.69
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 28.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1258181

CATALOG NUMBER: P3AS20R459040D010 E3DL1H

Luminous Intensity Polar Plot



TEST NUMBER: P1258181

CATALOG NUMBER: P3AS20R459040D010 E3DL1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	109	107	111	109	107	105	105	103	102		101	100	99		98
2	109	104	100	97	106	102	99	96	99	96	94		96	94	92		93
3	104	98	93	89	102	96	92	88	94	90	87		91	88	86		89
4	99	92	87	83	97	91	86	82	89	85	81		87	83	80		85
5	94	87	81	77	93	86	81	77	84	80	76		82	79	76		81
6	90	82	77	73	89	81	76	72	80	75	72		78	74	71		77
7	86	78	72	68	85	77	72	68	76	71	68		75	71	67		74
8	83	74	68	65	82	73	68	64	72	68	64		71	67	64		70
9	79	70	65	61	78	70	65	61	69	64	61		68	64	61		67
10	76	67	62	58	75	67	62	58	66	61	58		65	61	58		65

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	763470
5°	745563
10°	685358
15°	580730
20°	450559
25°	314970
30°	198410
35°	116794
40°	66095
45°	32127
50°	11155
55°	9022
60°	8771
65°	8509
70°	8142
75°	7710
80°	6945
85°	4529

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 32127 cd/sqm

TEST NUMBER: P1258181

CATALOG NUMBER: P3AS20R459040D010 E3DL1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	313.5	15.4
10°-20°	702.5	34.6
20°-30°	596.5	29.3
30°-40°	284.6	14.0
40°-50°	85.7	4.2
50°-60°	21.7	1.1
60°-70°	16.2	0.8
70°-80°	9.6	0.5
80°-90°	2.7	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1612.5	79.3
0°-40°	1897.1	93.3
0°-60°	2004.5	98.6
0°-90°	2033.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2033.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3482	
5°	3387	314
15°	2558	702
25°	1302	597
35°	436	285
45°	104	86
55°	24	22
65°	16	16
75°	9	10
85°	2	3
90°	0	

TEST NUMBER: P1258181

CATALOG NUMBER: P3AS20R459040D010 E3DL1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	3481.7
2.5°	3459.8
5°	3387.1
7.5°	3261.7
10°	3078.0
12.5°	2834.4
15°	2558.1
17.5°	2250.8
20°	1930.8
22.5°	1605.4
25°	1301.8
27.5°	1025.4
30°	783.6
32.5°	589.1
35°	436.3
37.5°	321.8
40°	230.9
42.5°	160.0
45°	103.6
47.5°	58.2
50°	32.7
52.5°	25.5
55°	23.6
57.5°	21.8
60°	20.0
62.5°	18.2
65°	16.4
67.5°	14.5
70°	12.7
72.5°	10.9
75°	9.1
77.5°	7.3
80°	5.5
82.5°	3.6
85°	1.8
87.5°	1.8
90°	0.0

(END OF REPORT)