

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1258819

Luminaire Tested: P3AS02R259050DE010 E3DLD1LI

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1258819
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-10)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS02R259050DE010 E3DLD1LI
Description: 3in Adjustable LED luminaire with, R25 optic, 5000K CCT AND, 90CRI , E3DLD1LI TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 214.0 lumens
Efficiency: N/A
Efficacy: 59.5 lumens/watt
Spacing Criteria (0/90/45): 0.78 / 0.78 / 0.85
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 3.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1258819

CATALOG NUMBER: P3AS02R259050DE010 E3DLD1LI

Luminous Intensity Polar Plot



TEST NUMBER: P1258819

CATALOG NUMBER: P3AS02R259050DE010 E3DLD1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	105	102	103	101	99		99	98	96		96
2	106	100	96	92	104	99	94	91	95	92	89		92	89	87		89
3	100	92	87	82	98	91	86	82	88	84	80		86	82	79		83
4	94	85	79	74	92	84	78	74	82	77	73		80	76	72		78
5	89	79	73	68	87	78	72	68	76	71	67		75	70	66		73
6	84	74	67	62	82	73	67	62	71	66	62		70	65	61		69
7	79	69	62	58	78	68	62	58	67	61	57		66	61	57		65
8	75	65	58	54	74	64	58	53	63	57	53		62	57	53		61
9	71	61	54	50	70	60	54	50	59	54	50		58	53	50		57
10	68	57	51	47	67	57	51	47	56	50	47		55	50	46		54

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	50851
5°	49637
10°	46002
15°	40976
20°	35213
25°	29929
30°	24637
35°	19194
40°	13826
45°	8776
50°	5185
55°	3555
60°	3289
65°	3061
70°	2757
75°	2457
80°	2399
85°	2013

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8776 cd/sqm

TEST NUMBER: P1258819

CATALOG NUMBER: P3AS02R259050DE010 E3DLD1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	20.9	9.8
10°-20°	50.1	23.4
20°-30°	56.6	26.4
30°-40°	44.8	20.9
40°-50°	22.6	10.6
50°-60°	9.1	4.2
60°-70°	5.8	2.7
70°-80°	3.2	1.5
80°-90°	0.9	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	127.6	59.6
0°-40°	172.4	80.5
0°-60°	204.1	95.4
0°-90°	214.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	214.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	232	
5°	226	21
15°	180	50
25°	124	57
35°	72	45
45°	28	23
55°	9	9
65°	6	6
75°	3	3
85°	1	1
90°	0	

TEST NUMBER: P1258819

CATALOG NUMBER: P3AS02R259050DE010 E3DLD1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	231.9
1°	231.9
2°	231.1
3°	229.8
4°	227.9
5°	225.5
6°	222.6
7°	219.1
8°	215.4
9°	211.1
10°	206.6
11°	201.5
12°	196.8
13°	191.2
14°	185.8
15°	180.5
17.5°	165.6
20°	150.9
22.5°	137.0
25°	123.7
27.5°	110.6
30°	97.3
32.5°	84.8
35°	71.7
37.5°	59.7
40°	48.3
42.5°	37.6
45°	28.3
47.5°	21.1
50°	15.2
52.5°	11.5
55°	9.3
57.5°	8.5
60°	7.5
62.5°	6.7
65°	5.9
67.5°	5.1
70°	4.3
72.5°	3.7
75°	2.9
77.5°	2.4
80°	1.9
82.5°	1.3
85°	0.8
87.5°	0.3



TEST NUMBER: P1258819

CATALOG NUMBER: P3AS02R259050DE010 E3DLD1LI

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0

(END OF REPORT)