

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1258825

Luminaire Tested: P3AS02R259050DE010 E3DLP1LI

Issue Date: 1/30/2026

**Test Information**


Test Method: LM-79-2019  
Report Number: P1258825  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-9)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS02R259050DE010 E3DLP1LI  
Description: 3in Adjustable LED luminaire with, R25 optic, 5000K CCT AND, 90CRI , E3DLP1LI TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 171.0 lumens  
Efficiency: N/A  
Efficacy: 47.5 lumens/watt  
Spacing Criteria (0/90/45): 0.62 / 0.62 / 0.68  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 3.6  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1258825  
CATALOG NUMBER: P3AS02R259050DE010 E3DLP1LI

### Luminous Intensity Polar Plot





TEST NUMBER: P1258825  
 CATALOG NUMBER: P3AS02R259050DE010 E3DLP1LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				20
RC	80				70				50				30				10				0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	113	110	108	105	111	108	106	104	104	102	101	100	99	98	97	96	95	93	93	93	93
2	107	102	98	95	105	101	97	94	97	94	92	94	92	90	92	90	88	86	86	86	86
3	102	95	90	86	100	94	89	86	91	87	84	89	86	83	87	84	82	80	80	80	80
4	97	89	84	79	95	88	83	79	86	81	78	84	80	77	82	79	76	75	75	75	75
5	92	84	78	74	91	83	77	73	81	76	73	79	75	72	78	74	71	70	70	70	70
6	88	79	73	69	86	78	72	68	77	72	68	75	71	67	74	70	67	66	66	66	66
7	84	74	68	64	82	74	68	64	72	67	64	71	67	63	70	66	63	62	62	62	62
8	80	70	65	60	79	70	64	60	69	64	60	68	63	60	67	63	60	58	58	58	58
9	76	67	61	57	75	66	61	57	65	60	57	65	60	57	64	59	56	55	55	55	55
10	73	64	58	54	72	63	58	54	62	57	54	62	57	54	61	57	54	52	52	52	52

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	62078
5°	59564
10°	52170
15°	41930
20°	32226
25°	24389
30°	17623
35°	11698
40°	7099
45°	4124
50°	2627
55°	2141
60°	1886
65°	1660
70°	1346
75°	1356
80°	1010
85°	1258

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 4124 cd/sqm



TEST NUMBER: P1258825  
 CATALOG NUMBER: P3AS02R259050DE010 E3DLP1LI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	24.6	14.4
10°-20°	51.1	29.9
20°-30°	46.2	27.0
30°-40°	27.7	16.2
40°-50°	11.0	6.4
50°-60°	5.1	3.0
60°-70°	3.1	1.8
70°-80°	1.6	1.0
80°-90°	0.5	0.3
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	121.9	71.3
0°-40°	149.7	87.5
0°-60°	165.8	96.9
0°-90°	171.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	171.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	283	
5°	271	25
15°	185	51
25°	101	46
35°	44	28
45°	13	11
55°	6	5
65°	3	3
75°	2	2
85°	0	0
90°	0	



TEST NUMBER: P1258825  
CATALOG NUMBER: P3AS02R259050DE010 E3DLP1LI

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	283.1
1°	283.1
2°	281.8
3°	278.9
4°	275.1
5°	270.6
6°	264.7
7°	258.1
8°	250.3
9°	242.6
10°	234.3
11°	224.7
12°	214.9
13°	205.0
14°	195.1
15°	184.7
17.5°	160.2
20°	138.1
22.5°	118.1
25°	100.8
27.5°	84.5
30°	69.6
32.5°	56.0
35°	43.7
37.5°	33.3
40°	24.8
42.5°	18.1
45°	13.3
47.5°	10.1
50°	7.7
52.5°	6.4
55°	5.6
57.5°	4.8
60°	4.3
62.5°	3.5
65°	3.2
67.5°	2.7
70°	2.1
72.5°	1.9
75°	1.6
77.5°	1.3
80°	0.8
82.5°	0.5
85°	0.5
87.5°	0.3



TEST NUMBER: P1258825  
CATALOG NUMBER: P3AS02R259050DE010 E3DLP1LI

CANDELA DISTRIBUTION (continued):

0°  
90° | 0.0

(END OF REPORT)