

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1259586

Luminaire Tested: P3AS09R359050DE010 E3CB1MMS

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1259586
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-20)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS09R359050DE010 E3CB1MMS
Description: 3in Adjustable LED luminaire with, R35 optic, 5000K CCT AND, 90CRI , E3CB1MMS TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1015.0 lumens
Efficiency: N/A
Efficacy: 91.4 lumens/watt
Spacing Criteria (0/90/45): 0.58 / 0.58 / 0.52
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11.1
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1259586

CATALOG NUMBER: P3AS09R359050DE010 E3CB1MMS

Luminous Intensity Polar Plot



TEST NUMBER: P1259586

CATALOG NUMBER: P3AS09R359050DE010 E3CB1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	115	113	111	109	112	110	109	107	106	105	104		103	102	101		99
2	111	107	104	101	109	105	103	100	102	100	98		99	98	96		97
3	107	102	98	95	105	101	97	95	98	96	93		96	94	92		94
4	104	98	94	91	102	97	93	90	95	92	89		93	90	88		91
5	100	94	90	87	99	93	89	86	92	88	86		90	87	85		89
6	97	91	86	83	96	90	86	83	89	85	82		87	84	82		86
7	94	87	83	80	93	87	83	80	86	82	79		85	81	79		84
8	91	84	80	77	90	84	80	77	83	79	77		82	79	76		81
9	89	82	77	74	88	81	77	74	80	77	74		80	76	74		79
10	86	79	75	72	85	79	75	72	78	74	72		77	74	72		77

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	661855
5°	648358
10°	603173
15°	442227
20°	226446
25°	81610
30°	31777
35°	11136
40°	4580
45°	1240
50°	1092
55°	1223
60°	1053
65°	830
70°	1026
75°	1356
80°	1010
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 75°

Luminance: 1356 cd/sqm

TEST NUMBER: P1259586

CATALOG NUMBER: P3AS09R359050DE010 E3CB1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	274.6	27.1
10°-20°	515.2	50.8
20°-30°	182.4	18.0
30°-40°	31.9	3.1
40°-50°	4.7	0.5
50°-60°	2.6	0.3
60°-70°	1.9	0.2
70°-80°	1.4	0.1
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	972.2	95.8
0°-40°	1004.2	98.9
0°-60°	1011.4	99.6
0°-90°	1015.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1015.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3018	
5°	2946	275
15°	1948	515
25°	337	182
35°	42	32
45°	4	5
55°	3	3
65°	2	2
75°	2	1
85°	0	0
90°	0	

TEST NUMBER: P1259586

CATALOG NUMBER: P3AS09R359050DE010 E3CB1MMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	3018.3
1°	3017.5
2°	3007.9
3°	2989.5
4°	2972.7
5°	2945.5
6°	2917.5
7°	2886.4
8°	2848.0
9°	2788.1
10°	2708.9
11°	2599.4
12°	2467.5
13°	2310.9
14°	2138.2
15°	1948.0
17.5°	1450.8
20°	970.4
22.5°	585.1
25°	337.3
27.5°	201.4
30°	125.5
32.5°	72.7
35°	41.6
37.5°	26.4
40°	16.0
42.5°	8.0
45°	4.0
47.5°	3.2
50°	3.2
52.5°	3.2
55°	3.2
57.5°	2.4
60°	2.4
62.5°	2.4
65°	1.6
67.5°	1.6
70°	1.6
72.5°	1.6
75°	1.6
77.5°	0.8
80°	0.8
82.5°	0.8
85°	0.0
87.5°	0.0



TEST NUMBER: P1259586

CATALOG NUMBER: P3AS09R359050DE010 E3CB1MMS

CANDELA DISTRIBUTION (continued):



(END OF REPORT)