

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1260807

Luminaire Tested: P3AS20R509050D010 E3DL1H

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1260807
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-31)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS20R509050D010 E3DL1H
Description: 3in Adjustable LED luminaire with, R50 optic, 5000K CCT AND, 90CRI , E3DL1H TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2077.0 lumens
Efficiency: N/A
Efficacy: 72.1 lumens/watt
Spacing Criteria (0/90/45): 0.77 / 0.77 / 0.75
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 28.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1260807

CATALOG NUMBER: P3AS20R509050D010 E3DL1H

Luminous Intensity Polar Plot



TEST NUMBER: P1260807

CATALOG NUMBER: P3AS20R509050D010 E3DL1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	114	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	94		
2	108	103	99	96	106	102	98	95	98	95	93	95	93	91	93	91	89	87		
3	103	97	92	88	101	95	91	87	93	89	86	90	87	84	88	85	83	82		
4	98	91	85	81	96	90	85	81	87	83	80	85	82	79	84	80	78	76		
5	93	85	80	75	92	84	79	75	83	78	74	81	77	74	79	76	73	72		
6	89	80	75	71	88	80	74	70	78	73	70	77	73	69	75	72	69	67		
7	85	76	70	66	84	75	70	66	74	69	66	73	69	65	72	68	65	64		
8	81	72	66	62	80	71	66	62	70	65	62	69	65	62	68	64	61	60		
9	78	68	63	59	76	68	62	59	67	62	59	66	62	58	65	61	58	57		
10	74	65	59	56	73	65	59	56	64	59	55	63	58	55	62	58	55	54		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	661285
5°	647962
10°	606914
15°	543318
20°	457233
25°	348964
30°	226794
35°	134462
40°	77717
45°	38950
50°	14498
55°	11278
60°	10525
65°	9599
70°	9489
75°	9404
80°	9345
85°	9309

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 38950 cd/sqm

TEST NUMBER: P1260807

CATALOG NUMBER: P3AS20R509050D010 E3DL1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	273.9	13.2
10°-20°	661.9	31.9
20°-30°	649.3	31.3
30°-40°	327.1	15.7
40°-50°	103.4	5.0
50°-60°	26.8	1.3
60°-70°	19.0	0.9
70°-80°	11.7	0.6
80°-90°	4.0	0.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1585.1	76.3
0°-40°	1912.2	92.1
0°-60°	2042.4	98.3
0°-90°	2077.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2077.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3016	
5°	2944	274
15°	2393	662
25°	1442	649
35°	502	327
45°	126	103
55°	30	27
65°	18	19
75°	11	12
85°	4	4
90°	0	

TEST NUMBER: P1260807

CATALOG NUMBER: P3AS20R509050D010 E3DL1H

CANDELA DISTRIBUTION (FULL):

	0°
0°	3015.7
2.5°	2997.2
5°	2943.7
7.5°	2847.6
10°	2725.7
12.5°	2568.8
15°	2393.3
17.5°	2190.2
20°	1959.4
22.5°	1710.1
25°	1442.3
27.5°	1157.9
30°	895.7
32.5°	674.0
35°	502.3
37.5°	371.2
40°	271.5
42.5°	192.1
45°	125.6
47.5°	72.0
50°	42.5
52.5°	31.4
55°	29.5
57.5°	25.9
60°	24.0
62.5°	22.2
65°	18.5
67.5°	16.6
70°	14.8
72.5°	12.9
75°	11.1
77.5°	9.2
80°	7.4
82.5°	5.5
85°	3.7
87.5°	1.8
90°	0.0

(END OF REPORT)