

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1261123

Luminaire Tested: P3AS24R459050D010 E3DL1H

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1261123
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-27)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS24R459050D010 E3DL1H
Description: 3in Adjustable LED luminaire with, R45 optic, 5000K CCT AND, 90CRI , E3DL1H TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 2307.0 lumens
Efficiency: N/A
Efficacy: 80.1 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.69
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 28.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1261123

CATALOG NUMBER: P3AS24R459050D010 E3DL1H

Luminous Intensity Polar Plot



TEST NUMBER: P1261123

CATALOG NUMBER: P3AS24R459050D010 E3DL1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	109	107	111	109	107	105	105	103	102		101	100	99		98
2	109	104	100	97	106	102	99	96	99	96	94		96	94	92		93
3	104	98	93	89	102	96	92	88	94	90	87		91	88	86		89
4	99	92	87	83	97	91	86	82	89	85	81		87	83	80		85
5	94	87	81	77	93	86	81	77	84	80	76		82	79	76		81
6	90	82	76	73	89	81	76	72	80	75	72		78	74	71		77
7	86	78	72	68	85	77	72	68	76	71	68		75	71	67		74
8	83	74	68	65	82	73	68	64	72	68	64		71	67	64		70
9	79	70	65	61	78	70	65	61	69	64	61		68	64	61		67
10	76	67	62	58	75	67	62	58	66	61	58		65	61	58		65

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	866356
5°	846047
10°	777741
15°	658982
20°	511301
25°	357408
30°	225149
35°	132561
40°	74998
45°	36469
50°	12656
55°	10246
60°	9955
65°	9651
70°	9232
75°	8727
80°	7829
85°	5284

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 36469 cd/sqm

TEST NUMBER: P1261123

CATALOG NUMBER: P3AS24R459050D010 E3DL1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	355.8	15.4
10°-20°	797.1	34.6
20°-30°	676.9	29.3
30°-40°	322.9	14.0
40°-50°	97.3	4.2
50°-60°	24.7	1.1
60°-70°	18.4	0.8
70°-80°	10.9	0.5
80°-90°	3.1	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1829.8	79.3
0°-40°	2152.8	93.3
0°-60°	2274.7	98.6
0°-90°	2307.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2307.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3951	
5°	3844	356
15°	2903	797
25°	1477	677
35°	495	323
45°	118	97
55°	27	25
65°	19	18
75°	10	11
85°	2	3
90°	0	

TEST NUMBER: P1261123

CATALOG NUMBER: P3AS24R459050D010 E3DL1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	3950.9
2.5°	3926.2
5°	3843.6
7.5°	3701.3
10°	3492.9
12.5°	3216.4
15°	2902.8
17.5°	2554.2
20°	2191.1
22.5°	1821.8
25°	1477.2
27.5°	1163.6
30°	889.2
32.5°	668.5
35°	495.2
37.5°	365.2
40°	262.0
42.5°	181.6
45°	117.6
47.5°	66.0
50°	37.1
52.5°	28.9
55°	26.8
57.5°	24.8
60°	22.7
62.5°	20.6
65°	18.6
67.5°	16.5
70°	14.4
72.5°	12.4
75°	10.3
77.5°	8.3
80°	6.2
82.5°	4.1
85°	2.1
87.5°	2.1
90°	0.0

(END OF REPORT)