

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1262699

Luminaire Tested: P3AS13R309727DE010 E3PH1MW

Issue Date: 1/29/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1262699  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2509-551-4)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/29/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS13R309727DE010 E3PH1MW  
Description: 3in Adjustable LED luminaire with, R30 optic, 2700K CCT AND, 97CRI , E3PH1MW TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 838.0 lumens  
Efficiency: N/A  
Efficacy: 57.4 lumens/watt  
Spacing Criteria (0/90/45): 0.33 / 0.33 / 0.34  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct

Input Watts (W): 14.6  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1262699

CATALOG NUMBER: P3AS13R309727DE010 E3PH1MW

### Luminous Intensity Polar Plot



TEST NUMBER: P1262699

CATALOG NUMBER: P3AS13R309727DE010 E3PH1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RF  | 20  |     |     |     | 20  |     |     |     |     | 20  |     |     |     |     | 20  |     |     |     |     | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     |     | 50  |     |     |     |     | 30  |     |     |     |     | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  | 50  | 30  | 10  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | 100 | 100 |
| 1   | 115 | 113 | 112 | 110 | 113 | 111 | 110 | 108 | 107 | 106 | 105 | 104 | 103 | 102 | 100 | 100 | 99  | 97  | 97  | 97  |
| 2   | 112 | 109 | 106 | 104 | 110 | 107 | 105 | 103 | 104 | 102 | 100 | 101 | 100 | 98  | 99  | 97  | 96  | 95  | 95  | 95  |
| 3   | 109 | 105 | 102 | 99  | 107 | 104 | 101 | 98  | 101 | 99  | 97  | 99  | 97  | 95  | 97  | 95  | 94  | 93  | 93  | 93  |
| 4   | 106 | 101 | 98  | 95  | 105 | 100 | 97  | 95  | 98  | 96  | 94  | 97  | 94  | 92  | 95  | 93  | 91  | 90  | 90  | 90  |
| 5   | 104 | 98  | 95  | 92  | 102 | 97  | 94  | 91  | 96  | 93  | 91  | 94  | 92  | 90  | 93  | 91  | 89  | 88  | 88  | 88  |
| 6   | 101 | 95  | 92  | 89  | 100 | 95  | 91  | 89  | 94  | 91  | 88  | 92  | 90  | 88  | 91  | 89  | 87  | 86  | 86  | 86  |
| 7   | 99  | 93  | 89  | 87  | 98  | 92  | 89  | 86  | 91  | 88  | 86  | 90  | 88  | 86  | 89  | 87  | 85  | 84  | 84  | 84  |
| 8   | 96  | 91  | 87  | 84  | 96  | 90  | 87  | 84  | 89  | 86  | 84  | 88  | 86  | 84  | 88  | 85  | 83  | 83  | 83  | 83  |
| 9   | 94  | 89  | 85  | 82  | 94  | 88  | 85  | 82  | 87  | 84  | 82  | 87  | 84  | 82  | 86  | 84  | 82  | 81  | 81  | 81  |
| 10  | 92  | 87  | 83  | 81  | 92  | 86  | 83  | 81  | 86  | 82  | 80  | 85  | 82  | 80  | 84  | 82  | 80  | 79  | 79  | 79  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |         |
|-----|---------|
|     | 0°      |
| 0°  | 1192777 |
| 5°  | 1041908 |
| 10° | 571577  |
| 15° | 262975  |
| 20° | 141739  |
| 25° | 48027   |
| 30° | 6254    |
| 35° | 937     |
| 40° | 344     |
| 45° | 0       |
| 50° | 0       |
| 55° | 0       |
| 60° | 0       |
| 65° | 0       |
| 70° | 0       |
| 75° | 0       |
| 80° | 0       |
| 85° | 0       |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
Vertical Angle: 45°  
Luminance: 0 cd/sqm

TEST NUMBER: P1262699

CATALOG NUMBER: P3AS13R309727DE010 E3PH1MW

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 379.2  | 45.3      |
| 10°-20°   | 347.6  | 41.5      |
| 20°-30°   | 106.9  | 12.8      |
| 30°-40°   | 4.0    | 0.5       |
| 40°-50°   | 0.3    | 0.0       |
| 50°-60°   | 0.0    | 0.0       |
| 60°-70°   | 0.0    | 0.0       |
| 70°-80°   | 0.0    | 0.0       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| <hr/>     |        |           |
| 0°-30°    | 833.6  | 99.5      |
| 0°-40°    | 837.7  | 100.0     |
| 0°-60°    | 838.0  | 100.0     |
| 0°-90°    | 838.0  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 838.0  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 5440 |      |
| 5°  | 4733 | 379  |
| 15° | 1158 | 348  |
| 25° | 198  | 107  |
| 35° | 4    | 4    |
| 45° | 0    | 0    |
| 55° | 0    | 0    |
| 65° | 0    | 0    |
| 75° | 0    | 0    |
| 85° | 0    | 0    |
| 90° | 0    |      |

TEST NUMBER: P1262699

CATALOG NUMBER: P3AS13R309727DE010 E3PH1MW

**CANDELA DISTRIBUTION (FULL):**

| 0°    |        |
|-------|--------|
| 0°    | 5439.5 |
| 2.5°  | 5312.6 |
| 5°    | 4733.4 |
| 7.5°  | 3713.7 |
| 10°   | 2567.0 |
| 12.5° | 1737.6 |
| 15°   | 1158.4 |
| 17.5° | 811.8  |
| 20°   | 607.4  |
| 22.5° | 408.8  |
| 25°   | 198.5  |
| 27.5° | 72.8   |
| 30°   | 24.7   |
| 32.5° | 8.2    |
| 35°   | 3.5    |
| 37.5° | 2.3    |
| 40°   | 1.2    |
| 42.5° | 1.2    |
| 45°   | 0.0    |
| 47.5° | 0.0    |
| 50°   | 0.0    |
| 52.5° | 0.0    |
| 55°   | 0.0    |
| 57.5° | 0.0    |
| 60°   | 0.0    |
| 62.5° | 0.0    |
| 65°   | 0.0    |
| 67.5° | 0.0    |
| 70°   | 0.0    |
| 72.5° | 0.0    |
| 75°   | 0.0    |
| 77.5° | 0.0    |
| 80°   | 0.0    |
| 82.5° | 0.0    |
| 85°   | 0.0    |
| 87.5° | 0.0    |
| 90°   | 0.0    |

(END OF REPORT)