

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1269117

Luminaire Tested: P3AS05R459740DE010 E3DL1MW

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1269117
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-27)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS05R459740DE010 E3DL1MW
Description: 3in Adjustable LED luminaire with, R45 optic, 4000K CCT AND, 97CRI , E3DL1MW TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 542.0 lumens
Efficiency: N/A
Efficacy: 75.3 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.69
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1269117

CATALOG NUMBER: P3AS05R459740DE010 E3DL1MW

Luminous Intensity Polar Plot



TEST NUMBER: P1269117

CATALOG NUMBER: P3AS05R459740DE010 E3DL1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	109	107	111	109	107	105	105	103	102		101	100	99		98
2	109	104	100	97	106	102	99	96	99	96	94		96	94	92		93
3	104	98	93	89	102	96	92	88	94	90	87		91	88	86		89
4	99	92	87	83	97	91	86	82	89	85	81		87	83	80		85
5	94	87	81	77	93	86	81	77	84	80	76		82	79	76		81
6	90	82	76	73	89	81	76	72	80	75	72		78	74	71		77
7	86	78	72	68	85	77	72	68	76	71	68		75	71	67		74
8	83	74	68	65	82	73	68	64	72	68	64		71	67	64		70
9	79	70	65	61	78	70	65	61	69	64	61		68	64	61		67
10	76	67	62	58	75	67	62	58	66	61	58		65	61	58		65

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	203536
5°	198767
10°	182718
15°	154825
20°	120130
25°	83981
30°	52894
35°	31133
40°	17633
45°	8559
50°	2968
55°	2409
60°	2324
65°	2283
70°	2180
75°	2033
80°	1894
85°	1258

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 8559 cd/sqm

TEST NUMBER: P1269117

CATALOG NUMBER: P3AS05R459740DE010 E3DL1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	83.6	15.4
10°-20°	187.3	34.6
20°-30°	159.0	29.3
30°-40°	75.9	14.0
40°-50°	22.9	4.2
50°-60°	5.8	1.1
60°-70°	4.3	0.8
70°-80°	2.5	0.5
80°-90°	0.7	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	429.9	79.3
0°-40°	505.8	93.3
0°-60°	534.4	98.6
0°-90°	542.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	542.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	928	
5°	903	84
15°	682	187
25°	347	159
35°	116	76
45°	28	23
55°	6	6
65°	4	4
75°	2	3
85°	0	1
90°	0	

TEST NUMBER: P1269117

CATALOG NUMBER: P3AS05R459740DE010 E3DL1MW

CANDELA DISTRIBUTION (FULL):

0°	
0°	928.2
2.5°	922.4
5°	903.0
7.5°	869.6
10°	820.6
12.5°	755.7
15°	682.0
17.5°	600.1
20°	514.8
22.5°	428.0
25°	347.1
27.5°	273.4
30°	208.9
32.5°	157.0
35°	116.3
37.5°	85.8
40°	61.6
42.5°	42.7
45°	27.6
47.5°	15.5
50°	8.7
52.5°	6.8
55°	6.3
57.5°	5.8
60°	5.3
62.5°	4.8
65°	4.4
67.5°	3.9
70°	3.4
72.5°	2.9
75°	2.4
77.5°	1.9
80°	1.5
82.5°	1.0
85°	0.5
87.5°	0.5
90°	0.0

(END OF REPORT)