

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1269259

Luminaire Tested: P3AS05R709740DE010 E3DL1GPH

Issue Date: 1/30/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1269259  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-47)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS05R709740DE010 E3DL1GPH  
Description: 3in Adjustable LED luminaire with, R70 optic, 4000K CCT AND, 97CRI , E3DL1GPH TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 239.0 lumens  
Efficiency: N/A  
Efficacy: 33.2 lumens/watt  
Spacing Criteria (0/90/45): 0.97 / 0.97 / 0.98  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct

Input Watts (W): 7.2  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1269259

CATALOG NUMBER: P3AS05R709740DE010 E3DL1GPH

### Luminous Intensity Polar Plot



TEST NUMBER: P1269259

CATALOG NUMBER: P3AS05R709740DE010 E3DL1GPH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |  | 20  |     |     |  | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |  | 30  |     |     |  | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 |
| 1   | 113 | 110 | 107 | 104 | 110 | 107 | 105 | 103 | 103 | 101 | 100 |  | 100 | 98  | 97  |  | 96  |
| 2   | 106 | 101 | 96  | 93  | 104 | 99  | 95  | 92  | 96  | 93  | 90  |  | 93  | 90  | 88  |  | 90  |
| 3   | 100 | 93  | 88  | 83  | 98  | 92  | 87  | 82  | 89  | 85  | 81  |  | 86  | 83  | 80  |  | 84  |
| 4   | 94  | 86  | 80  | 75  | 93  | 85  | 79  | 75  | 83  | 78  | 74  |  | 81  | 76  | 73  |  | 79  |
| 5   | 89  | 80  | 73  | 69  | 87  | 79  | 73  | 68  | 77  | 72  | 68  |  | 75  | 71  | 67  |  | 74  |
| 6   | 84  | 74  | 68  | 63  | 82  | 73  | 67  | 63  | 72  | 66  | 62  |  | 70  | 65  | 62  |  | 69  |
| 7   | 79  | 69  | 62  | 58  | 78  | 68  | 62  | 58  | 67  | 61  | 57  |  | 66  | 61  | 57  |  | 65  |
| 8   | 75  | 65  | 58  | 53  | 74  | 64  | 58  | 53  | 63  | 57  | 53  |  | 62  | 57  | 53  |  | 61  |
| 9   | 71  | 60  | 54  | 50  | 70  | 60  | 54  | 50  | 59  | 53  | 49  |  | 58  | 53  | 49  |  | 57  |
| 10  | 67  | 57  | 50  | 46  | 66  | 56  | 50  | 46  | 55  | 50  | 46  |  | 55  | 49  | 46  |  | 54  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |       |
|-----|-------|
|     | 0°    |
| 0°  | 46268 |
| 5°  | 45719 |
| 10° | 44399 |
| 15° | 42520 |
| 20° | 39833 |
| 25° | 36171 |
| 30° | 31245 |
| 35° | 24895 |
| 40° | 18148 |
| 45° | 11908 |
| 50° | 5595  |
| 55° | 1720  |
| 60° | 1667  |
| 65° | 1608  |
| 70° | 1539  |
| 75° | 1610  |
| 80° | 1515  |
| 85° | 1258  |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 11908 cd/sqm

TEST NUMBER: P1269259

CATALOG NUMBER: P3AS05R709740DE010 E3DL1GPH

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 19.6   | 8.2       |
| 10°-20°   | 52.4   | 21.9      |
| 20°-30°   | 68.1   | 28.5      |
| 30°-40°   | 57.8   | 24.2      |
| 40°-50°   | 29.8   | 12.5      |
| 50°-60°   | 5.7    | 2.4       |
| 60°-70°   | 3.1    | 1.3       |
| 70°-80°   | 1.9    | 0.8       |
| 80°-90°   | 0.5    | 0.2       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| <hr/>     |        |           |
| 0°-30°    | 140.1  | 58.6      |
| 0°-40°    | 197.9  | 82.8      |
| 0°-60°    | 233.4  | 97.7      |
| 0°-90°    | 239.0  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 239.0  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°  | Flux |
|-----|-----|------|
| 0°  | 211 |      |
| 5°  | 208 | 20   |
| 15° | 187 | 52   |
| 25° | 150 | 68   |
| 35° | 93  | 58   |
| 45° | 38  | 30   |
| 55° | 4   | 6    |
| 65° | 3   | 3    |
| 75° | 2   | 2    |
| 85° | 0   | 1    |
| 90° | 0   |      |

TEST NUMBER: P1269259

CATALOG NUMBER: P3AS05R709740DE010 E3DL1GPH

**CANDELA DISTRIBUTION (FULL):**

| 0°    |       |
|-------|-------|
| 0°    | 211.0 |
| 2.5°  | 210.3 |
| 5°    | 207.7 |
| 7.5°  | 203.9 |
| 10°   | 199.4 |
| 12.5° | 193.7 |
| 15°   | 187.3 |
| 17.5° | 179.4 |
| 20°   | 170.7 |
| 22.5° | 160.7 |
| 25°   | 149.5 |
| 27.5° | 136.9 |
| 30°   | 123.4 |
| 32.5° | 108.5 |
| 35°   | 93.0  |
| 37.5° | 77.8  |
| 40°   | 63.4  |
| 42.5° | 49.8  |
| 45°   | 38.4  |
| 47.5° | 28.2  |
| 50°   | 16.4  |
| 52.5° | 7.1   |
| 55°   | 4.5   |
| 57.5° | 4.3   |
| 60°   | 3.8   |
| 62.5° | 3.6   |
| 65°   | 3.1   |
| 67.5° | 2.8   |
| 70°   | 2.4   |
| 72.5° | 2.1   |
| 75°   | 1.9   |
| 77.5° | 1.4   |
| 80°   | 1.2   |
| 82.5° | 0.7   |
| 85°   | 0.5   |
| 87.5° | 0.2   |
| 90°   | 0.0   |

(END OF REPORT)