

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1269909

Luminaire Tested: P3AS13R459740DE010 E3DLD1GPH

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1269909
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-26)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS13R459740DE010 E3DLD1GPH
Description: 3in Adjustable LED luminaire with, R45 optic, 4000K CCT AND, 97CRI , E3DLD1GPH TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 400.0 lumens
Efficiency: N/A
Efficacy: 27.4 lumens/watt
Spacing Criteria (0/90/45): 0.84 / 0.84 / 0.92
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 14.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1269909

CATALOG NUMBER: P3AS13R459740DE010 E3DLD1GPH

Luminous Intensity Polar Plot





TEST NUMBER: P1269909

CATALOG NUMBER: P3AS13R459740DE010 E3DLD1GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	112	109	106	104	110	107	104	102	103	101	99		99	97	96		96
2	106	100	95	91	103	98	94	90	95	91	88		92	89	86		89
3	99	92	86	82	97	90	85	81	88	83	80		85	81	78		83
4	94	85	78	74	92	84	78	73	81	76	72		79	75	71		77
5	88	79	72	67	86	78	71	67	76	70	66		74	69	65		72
6	83	73	66	61	81	72	66	61	71	65	61		69	64	60		68
7	78	68	61	57	77	67	61	56	66	60	56		65	60	56		64
8	74	64	57	52	73	63	57	52	62	56	52		61	56	52		60
9	70	60	53	49	69	59	53	49	58	52	48		57	52	48		56
10	67	56	50	45	66	56	49	45	55	49	45		54	49	45		53

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	84818
5°	83315
10°	78823
15°	71896
20°	63566
25°	55213
30°	47400
35°	39485
40°	29427
45°	18017
50°	8324
55°	6537
60°	6271
65°	5759
70°	5321
75°	5083
80°	4672
85°	3522

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 18017 cd/sqm

TEST NUMBER: P1269909

CATALOG NUMBER: P3AS13R459740DE010 E3DLD1GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	35.4	8.8
10°-20°	88.2	22.0
20°-30°	104.8	26.2
30°-40°	91.0	22.8
40°-50°	45.7	11.4
50°-60°	15.9	4.0
60°-70°	11.1	2.8
70°-80°	6.2	1.5
80°-90°	1.9	0.5
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	228.3	57.1
0°-40°	319.3	79.8
0°-60°	380.8	95.2
0°-90°	400.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	400.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	387	
5°	378	35
15°	317	88
25°	228	105
35°	148	91
45°	58	46
55°	17	16
65°	11	11
75°	6	6
85°	1	2
90°	0	

TEST NUMBER: P1269909

CATALOG NUMBER: P3AS13R459740DE010 E3DLD1GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	386.8
2.5°	384.9
5°	378.5
7.5°	368.3
10°	354.0
12.5°	336.5
15°	316.7
17.5°	294.6
20°	272.4
22.5°	249.8
25°	228.2
27.5°	207.4
30°	187.2
32.5°	167.8
35°	147.5
37.5°	125.8
40°	102.8
42.5°	80.2
45°	58.1
47.5°	38.3
50°	24.4
52.5°	18.9
55°	17.1
57.5°	15.7
60°	14.3
62.5°	12.9
65°	11.1
67.5°	9.7
70°	8.3
72.5°	6.9
75°	6.0
77.5°	4.6
80°	3.7
82.5°	2.8
85°	1.4
87.5°	0.9
90°	0.0

(END OF REPORT)