

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1271712

Luminaire Tested: P3AS09R509827DE010 E3D1H

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1271712
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-13)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS09R509827DE010 E3D1H
Description: 3in Adjustable LED luminaire with, R50 optic, 2700K CCT AND, 98CRI , E3D1H TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 707.0 lumens
Efficiency: N/A
Efficacy: 64.3 lumens/watt
Spacing Criteria (0/90/45): 0.82 / 0.82 / 0.77
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1271712

CATALOG NUMBER: P3AS09R509827DE010 E3D1H

Luminous Intensity Polar Plot



TEST NUMBER: P1271712

CATALOG NUMBER: P3AS09R509827DE010 E3D1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20					20					20					20
RC	80				70					50					30					10
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	102	102	100
1	114	112	109	107	112	110	108	106	105	104	102	102	101	99	98	97	97	97	97	95
2	109	105	101	98	107	103	100	97	100	97	95	97	95	93	94	93	91	91	91	90
3	105	99	95	91	103	98	94	90	95	92	89	93	90	88	91	88	86	86	86	85
4	100	94	89	85	99	92	88	85	90	87	84	88	85	83	87	84	82	82	82	80
5	96	89	84	80	94	88	83	79	86	82	79	84	81	78	83	80	77	77	77	76
6	92	84	79	75	91	83	78	75	82	78	74	81	77	74	79	76	73	73	73	72
7	88	80	75	71	87	79	74	71	78	74	70	77	73	70	76	72	70	70	70	68
8	84	76	71	67	83	76	71	67	75	70	67	74	69	66	73	69	66	66	66	65
9	81	73	67	64	80	72	67	64	71	67	63	70	66	63	70	66	63	63	63	62
10	78	69	64	61	77	69	64	61	68	64	60	67	63	60	67	63	60	60	60	59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	247064
5°	240479
10°	229499
15°	207765
20°	179752
25°	147444
30°	84697
35°	26314
40°	7070
45°	2481
50°	580
55°	191
60°	88
65°	104
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2481 cd/sqm

TEST NUMBER: P1271712

CATALOG NUMBER: P3AS09R509827DE010 E3D1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	102.3	14.5
10°-20°	253.6	35.9
20°-30°	266.5	37.7
30°-40°	76.3	10.8
40°-50°	7.5	1.1
50°-60°	0.6	0.1
60°-70°	0.2	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	622.4	88.0
0°-40°	698.7	98.8
0°-60°	706.8	100.0
0°-90°	707.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	707.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1127	
5°	1092	102
15°	915	254
25°	609	267
35°	98	76
45°	8	7
55°	0	1
65°	0	0
75°	0	0
85°	0	0
90°	0	

TEST NUMBER: P1271712

CATALOG NUMBER: P3AS09R509827DE010 E3D1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	1126.7
1°	1125.0
2°	1120.0
3°	1112.8
4°	1103.0
5°	1092.5
6°	1081.3
7°	1069.4
8°	1058.1
9°	1045.2
10°	1030.7
11°	1014.0
12°	994.8
13°	970.8
14°	944.9
15°	915.2
16°	883.8
17°	853.3
18°	822.2
19°	794.7
20°	770.3
21°	746.8
22°	720.1
23°	689.5
24°	653.5
25°	609.4
26°	561.5
27°	508.1
28°	455.0
29°	397.6
30°	334.5
31°	275.4
32°	221.0
32.5°	197.3
33°	173.4
34°	133.0
35°	98.3
36°	72.1
37°	53.6
37.5°	46.4
38°	40.2
39°	31.2
40°	24.7
42.5°	14.0
45°	8.0



TEST NUMBER: P1271712

CATALOG NUMBER: P3AS09R509827DE010 E3D1H

CANDELA DISTRIBUTION (continued):

	0°
47.5°	4.5
50°	1.7
52.5°	0.7
55°	0.5
57.5°	0.5
60°	0.2
62.5°	0.2
65°	0.2
67.5°	0.2
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)