

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1273580

Luminaire Tested: P3AS09R159830DE010 E3D1MW

Issue Date: 1/30/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1273580  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-4)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS09R159830DE010 E3D1MW  
Description: 3in Adjustable LED luminaire with, R15 optic, 3000K CCT AND, 98CRI , E3D1MW TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 691.9 lumens  
Efficiency: N/A  
Efficacy: 62.9 lumens/watt  
Spacing Criteria (0/90/45): 0.3 / 0.3 / 0.29  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct

Input Watts (W): 11  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1273580

CATALOG NUMBER: P3AS09R159830DE010 E3D1MW

### Luminous Intensity Polar Plot



TEST NUMBER: P1273580

CATALOG NUMBER: P3AS09R159830DE010 E3D1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |  | 20  |     |     |  | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |  | 30  |     |     |  | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 |
| 1   | 116 | 114 | 112 | 111 | 113 | 112 | 110 | 109 | 108 | 107 | 106 |  | 104 | 103 | 103 |  | 101 |
| 2   | 113 | 110 | 107 | 105 | 111 | 108 | 106 | 104 | 105 | 103 | 101 |  | 102 | 101 | 99  |  | 99  |
| 3   | 110 | 106 | 103 | 101 | 108 | 105 | 102 | 100 | 102 | 100 | 98  |  | 100 | 98  | 97  |  | 98  |
| 4   | 107 | 103 | 100 | 97  | 106 | 102 | 99  | 97  | 100 | 97  | 95  |  | 98  | 96  | 94  |  | 97  |
| 5   | 105 | 100 | 97  | 94  | 104 | 99  | 96  | 94  | 98  | 95  | 93  |  | 96  | 94  | 92  |  | 95  |
| 6   | 103 | 98  | 94  | 92  | 102 | 97  | 94  | 92  | 96  | 93  | 91  |  | 95  | 92  | 91  |  | 94  |
| 7   | 101 | 96  | 92  | 90  | 100 | 95  | 92  | 90  | 94  | 91  | 89  |  | 93  | 91  | 89  |  | 92  |
| 8   | 99  | 94  | 90  | 88  | 98  | 93  | 90  | 88  | 93  | 90  | 88  |  | 92  | 89  | 87  |  | 91  |
| 9   | 97  | 92  | 89  | 87  | 97  | 92  | 89  | 87  | 91  | 88  | 86  |  | 90  | 88  | 86  |  | 90  |
| 10  | 96  | 90  | 87  | 85  | 95  | 90  | 87  | 85  | 89  | 87  | 85  |  | 89  | 86  | 85  |  | 88  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |         |
|-----|---------|
|     | 0°      |
| 0°  | 1345090 |
| 5°  | 1127314 |
| 10° | 531008  |
| 15° | 160092  |
| 20° | 59248   |
| 25° | 23034   |
| 30° | 8584    |
| 35° | 2623    |
| 40° | 945     |
| 45° | 496     |
| 50° | 375     |
| 55° | 421     |
| 60° | 482     |
| 65° | 259     |
| 70° | 321     |
| 75° | 424     |
| 80° | 0       |
| 85° | 0       |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 496 cd/sqm

TEST NUMBER: P1273580

CATALOG NUMBER: P3AS09R159830DE010 E3D1MW

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 395.9  | 57.2      |
| 10°-20°   | 235.4  | 34.0      |
| 20°-30°   | 49.4   | 7.1       |
| 30°-40°   | 8.0    | 1.2       |
| 40°-50°   | 1.4    | 0.2       |
| 50°-60°   | 1.0    | 0.1       |
| 60°-70°   | 0.6    | 0.1       |
| 70°-80°   | 0.3    | 0.0       |
| 80°-90°   | 0.0    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| <hr/>     |        |           |
| 0°-30°    | 680.7  | 98.4      |
| 0°-40°    | 688.7  | 99.5      |
| 0°-60°    | 691.0  | 99.9      |
| 0°-90°    | 691.9  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 691.9  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 6134 |      |
| 5°  | 5121 | 396  |
| 15° | 705  | 235  |
| 25° | 95   | 49   |
| 35° | 10   | 8    |
| 45° | 2    | 1    |
| 55° | 1    | 1    |
| 65° | 0    | 1    |
| 75° | 0    | 0    |
| 85° | 0    | 0    |
| 90° | 0    |      |

TEST NUMBER: P1273580

CATALOG NUMBER: P3AS09R159830DE010 E3D1MW

**CANDELA DISTRIBUTION (FULL):**

| 0°    |        |
|-------|--------|
| 0°    | 6134.1 |
| 1°    | 6114.9 |
| 2°    | 6017.5 |
| 3°    | 5822.8 |
| 4°    | 5537.2 |
| 5°    | 5121.4 |
| 6°    | 4632.8 |
| 7°    | 4074.2 |
| 8°    | 3540.8 |
| 9°    | 2936.8 |
| 10°   | 2384.8 |
| 12.5° | 1286.8 |
| 15°   | 705.2  |
| 17.5° | 413.1  |
| 20°   | 253.9  |
| 22.5° | 155.4  |
| 25°   | 95.2   |
| 27.5° | 57.4   |
| 30°   | 33.9   |
| 32.5° | 19.1   |
| 35°   | 9.8    |
| 37.5° | 5.5    |
| 40°   | 3.3    |
| 42.5° | 2.2    |
| 45°   | 1.6    |
| 47.5° | 1.1    |
| 50°   | 1.1    |
| 52.5° | 1.1    |
| 55°   | 1.1    |
| 57.5° | 1.1    |
| 60°   | 1.1    |
| 62.5° | 0.5    |
| 65°   | 0.5    |
| 67.5° | 0.5    |
| 70°   | 0.5    |
| 72.5° | 0.5    |
| 75°   | 0.5    |
| 77.5° | 0.0    |
| 80°   | 0.0    |
| 82.5° | 0.0    |
| 85°   | 0.0    |
| 87.5° | 0.0    |
| 90°   | 0.0    |

(END OF REPORT)