

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1273960

Luminaire Tested: P3AS13R209830DE010 E3DL1GPH

Issue Date: 1/30/2026

**Test Information**

Test Method: LM-79-2019  
Report Number: P1273960  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-7)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS13R209830DE010 E3DL1GPH  
Description: 3in Adjustable LED luminaire with, R20 optic, 3000K CCT AND, 98CRI , E3DL1GPH TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 368.0 lumens  
Efficiency: N/A  
Efficacy: 25.4 lumens/watt  
Spacing Criteria (0/90/45): 0.44 / 0.44 / 0.46  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct

Input Watts (W): 14.5  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1273960

CATALOG NUMBER: P3AS13R209830DE010 E3DL1GPH

### Luminous Intensity Polar Plot



TEST NUMBER: P1273960

CATALOG NUMBER: P3AS13R209830DE010 E3DL1GPH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |  | 20  |     |     |  | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |  | 30  |     |     |  | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 |
| 1   | 114 | 112 | 110 | 108 | 112 | 110 | 108 | 106 | 106 | 104 | 103 |  | 102 | 101 | 100 |  | 99  |
| 2   | 110 | 106 | 102 | 100 | 108 | 104 | 101 | 98  | 101 | 98  | 96  |  | 98  | 96  | 94  |  | 95  |
| 3   | 106 | 100 | 96  | 93  | 104 | 99  | 95  | 92  | 97  | 93  | 91  |  | 94  | 92  | 89  |  | 92  |
| 4   | 102 | 96  | 91  | 88  | 100 | 95  | 90  | 87  | 92  | 89  | 86  |  | 91  | 88  | 85  |  | 89  |
| 5   | 98  | 91  | 87  | 83  | 97  | 90  | 86  | 83  | 89  | 85  | 82  |  | 87  | 84  | 81  |  | 86  |
| 6   | 95  | 87  | 83  | 79  | 93  | 87  | 82  | 79  | 85  | 81  | 78  |  | 84  | 81  | 78  |  | 83  |
| 7   | 91  | 84  | 79  | 76  | 90  | 83  | 79  | 76  | 82  | 78  | 75  |  | 81  | 78  | 75  |  | 80  |
| 8   | 88  | 81  | 76  | 73  | 87  | 80  | 76  | 73  | 79  | 75  | 72  |  | 78  | 75  | 72  |  | 78  |
| 9   | 85  | 78  | 73  | 70  | 85  | 77  | 73  | 70  | 77  | 73  | 70  |  | 76  | 72  | 69  |  | 75  |
| 10  | 83  | 75  | 71  | 68  | 82  | 75  | 70  | 67  | 74  | 70  | 67  |  | 73  | 70  | 67  |  | 73  |

**AVERAGE LUMINANCE (cd/sqm):**

|     |        |
|-----|--------|
|     | 0°     |
| 0°  | 283135 |
| 5°  | 257384 |
| 10° | 190221 |
| 15° | 117662 |
| 20° | 67206  |
| 25° | 38373  |
| 30° | 21522  |
| 35° | 11698  |
| 40° | 6412   |
| 45° | 3535   |
| 50° | 2047   |
| 55° | 1491   |
| 60° | 1403   |
| 65° | 1297   |
| 70° | 1154   |
| 75° | 1186   |
| 80° | 884    |
| 85° | 1006   |

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
Vertical Angle: 45°  
Luminance: 3535 cd/sqm

TEST NUMBER: P1273960

CATALOG NUMBER: P3AS13R209830DE010 E3DL1GPH

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 101.3  | 27.5      |
| 10°-20°   | 144.5  | 39.3      |
| 20°-30°   | 75.5   | 20.5      |
| 30°-40°   | 29.2   | 7.9       |
| 40°-50°   | 9.5    | 2.6       |
| 50°-60°   | 3.7    | 1.0       |
| 60°-70°   | 2.4    | 0.7       |
| 70°-80°   | 1.5    | 0.4       |
| 80°-90°   | 0.5    | 0.1       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| <hr/>     |        |           |
| 0°-30°    | 321.3  | 87.3      |
| 0°-40°    | 350.4  | 95.2      |
| 0°-60°    | 363.6  | 98.8      |
| 0°-90°    | 368.0  | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 368.0  | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 1291 |      |
| 5°  | 1169 | 101  |
| 15° | 518  | 145  |
| 25° | 159  | 75   |
| 35° | 44   | 29   |
| 45° | 11   | 9    |
| 55° | 4    | 4    |
| 65° | 2    | 2    |
| 75° | 1    | 1    |
| 85° | 0    | 1    |
| 90° | 0    |      |

TEST NUMBER: P1273960

CATALOG NUMBER: P3AS13R209830DE010 E3DL1GPH

**CANDELA DISTRIBUTION (FULL):**

| 0°    |        |
|-------|--------|
| 0°    | 1291.2 |
| 1°    | 1288.7 |
| 2°    | 1273.4 |
| 3°    | 1250.0 |
| 4°    | 1213.7 |
| 5°    | 1169.3 |
| 6°    | 1116.6 |
| 7°    | 1058.3 |
| 8°    | 990.8  |
| 9°    | 925.0  |
| 10°   | 854.3  |
| 12.5° | 679.0  |
| 15°   | 518.3  |
| 17.5° | 387.9  |
| 20°   | 288.0  |
| 22.5° | 213.3  |
| 25°   | 158.6  |
| 27.5° | 117.0  |
| 30°   | 85.0   |
| 32.5° | 61.5   |
| 35°   | 43.7   |
| 37.5° | 31.6   |
| 40°   | 22.4   |
| 42.5° | 16.0   |
| 45°   | 11.4   |
| 47.5° | 8.2    |
| 50°   | 6.0    |
| 52.5° | 4.6    |
| 55°   | 3.9    |
| 57.5° | 3.6    |
| 60°   | 3.2    |
| 62.5° | 2.8    |
| 65°   | 2.5    |
| 67.5° | 2.1    |
| 70°   | 1.8    |
| 72.5° | 1.8    |
| 75°   | 1.4    |
| 77.5° | 1.1    |
| 80°   | 0.7    |
| 82.5° | 0.7    |
| 85°   | 0.4    |
| 87.5° | 0.4    |
| 90°   | 0.0    |

(END OF REPORT)