

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1275055

Luminaire Tested: P3AS02R309835DE010 E3DL1LI

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1275055
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-15)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS02R309835DE010 E3DL1LI
Description: 3in Adjustable LED luminaire with, R30 optic, 3500K CCT AND, 98CRI , E3DL1LI TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 198.0 lumens
Efficiency: N/A
Efficacy: 55.0 lumens/watt
Spacing Criteria (0/90/45): 0.54 / 0.54 / 0.54
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 3.6
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1275055

CATALOG NUMBER: P3AS02R309835DE010 E3DL1LI

Luminous Intensity Polar Plot



TEST NUMBER: P1275055

CATALOG NUMBER: P3AS02R309835DE010 E3DL1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	112	110	108	112	110	108	106	106	104	103		102	101	100		99
2	110	105	102	99	107	104	101	98	101	98	96		98	96	94		95
3	105	100	96	92	103	98	95	91	96	93	90		94	91	89		91
4	101	95	90	87	99	94	89	86	92	88	85		90	87	84		88
5	97	90	85	82	96	89	85	81	88	84	81		86	83	80		85
6	94	86	81	78	92	85	81	77	84	80	77		83	79	76		81
7	90	82	77	74	89	82	77	74	81	76	73		80	76	73		78
8	87	79	74	71	86	79	74	71	78	73	70		77	73	70		76
9	84	76	71	68	83	75	71	68	75	70	67		74	70	67		73
10	81	73	68	65	80	73	68	65	72	68	65		71	67	65		71

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	115539
5°	109971
10°	92494
15°	66697
20°	41374
25°	23542
30°	13065
35°	7121
40°	3750
45°	2016
50°	1092
55°	726
60°	658
65°	675
70°	577
75°	508
80°	505
85°	503

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 2016 cd/sqm

TEST NUMBER: P1275055

CATALOG NUMBER: P3AS02R309835DE010 E3DL1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	45.0	22.7
10°-20°	80.0	40.4
20°-30°	46.2	23.3
30°-40°	17.5	8.9
40°-50°	5.4	2.7
50°-60°	1.8	0.9
60°-70°	1.2	0.6
70°-80°	0.7	0.3
80°-90°	0.2	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	171.2	86.4
0°-40°	188.7	95.3
0°-60°	195.9	98.9
0°-90°	198.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	198.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	527	
5°	500	45
15°	294	80
25°	97	46
35°	27	18
45°	6	5
55°	2	2
65°	1	1
75°	1	1
85°	0	0
90°	0	

TEST NUMBER: P1275055

CATALOG NUMBER: P3AS02R309835DE010 E3DL1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	526.9
1°	526.5
2°	523.3
3°	517.4
4°	509.9
5°	499.6
6°	486.5
7°	471.9
8°	455.6
9°	436.2
10°	415.4
11°	393.0
12°	369.2
13°	344.3
14°	319.1
15°	293.8
17.5°	231.7
20°	177.3
22.5°	131.5
25°	97.3
27.5°	70.7
30°	51.6
32.5°	37.2
35°	26.6
37.5°	18.5
40°	13.1
42.5°	9.2
45°	6.5
47.5°	4.5
50°	3.2
52.5°	2.2
55°	1.9
57.5°	1.7
60°	1.5
62.5°	1.3
65°	1.3
67.5°	1.1
70°	0.9
72.5°	0.7
75°	0.6
77.5°	0.6
80°	0.4
82.5°	0.4
85°	0.2
87.5°	0.0



TEST NUMBER: P1275055
CATALOG NUMBER: P3AS02R309835DE010 E3DL1LI

CANDELA DISTRIBUTION (continued):



(END OF REPORT)