

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1275106

Luminaire Tested: P3AS02R409835DE010 E3CD1MMS

Issue Date: 1/30/2026

**Test Information**


Test Method: LM-79-2019  
Report Number: P1275106  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-24)  
Test Lab: INNOVATION CENTER  
Issue Date: 1/30/2026  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: IRiS  
Catalog Number: P3AS02R409835DE010 E3CD1MMS  
Description: 3in Adjustable LED luminaire with, R40 optic, 3500K CCT AND, 98CRI , E3CD1MMS TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 262.1 lumens  
Efficiency: N/A  
Efficacy: 72.8 lumens/watt  
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.59  
Luminous Opening: Circular (Dia: 0.25' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 3.6  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT

TEST NUMBER: P1275106  
CATALOG NUMBER: P3AS02R409835DE010 E3CD1MMS

### Luminous Intensity Polar Plot





TEST NUMBER: P1275106  
 CATALOG NUMBER: P3AS02R409835DE010 E3CD1MMS

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	115	112	110	109	112	110	109	107	106	105	104	103	102	101	99	98	98	96			96
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	96	95	94	92			92
3	107	102	98	95	105	100	97	94	98	95	93	96	93	91	94	92	90	89			89
4	103	97	93	90	101	96	92	89	94	91	88	92	90	87	91	88	86	85			85
5	100	93	89	86	98	92	88	85	91	87	85	89	86	84	88	85	83	82			82
6	96	90	85	82	95	89	85	82	88	84	81	86	83	81	85	82	80	79			79
7	93	86	82	79	92	86	81	78	84	81	78	83	80	78	82	79	77	76			76
8	90	83	79	75	89	83	78	75	82	78	75	81	77	75	80	77	74	73			73
9	87	80	76	73	86	80	75	73	79	75	72	78	75	72	77	74	72	71			71
10	85	77	73	70	84	77	73	70	76	73	70	76	72	70	75	72	70	69			69

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	137949
5°	137288
10°	132819
15°	117504
20°	76657
25°	27147
30°	5748
35°	1901
40°	687
45°	217
50°	205
55°	229
60°	175
65°	208
70°	128
75°	169
80°	253
85°	0

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 82.5°  
 Luminance: 336 cd/sqm



TEST NUMBER: P1275106  
 CATALOG NUMBER: P3AS02R409835DE010 E3CD1MMS

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	58.7	22.4
10°-20°	136.7	52.1
20°-30°	59.3	22.6
30°-40°	5.5	2.1
40°-50°	0.8	0.3
50°-60°	0.5	0.2
60°-70°	0.4	0.1
70°-80°	0.2	0.1
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	254.7	97.2
0°-40°	260.1	99.3
0°-60°	261.4	99.7
0°-90°	262.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	262.1	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	629	
5°	624	59
15°	518	137
25°	112	59
35°	7	5
45°	1	1
55°	1	1
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P1275106  
CATALOG NUMBER: P3AS02R409835DE010 E3CD1MMS

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	629.1
2.5°	628.4
5°	623.7
7.5°	613.8
10°	596.5
12.5°	567.2
15°	517.6
17.5°	435.4
20°	328.5
22.5°	213.3
25°	112.2
27.5°	48.3
30°	22.7
32.5°	12.3
35°	7.1
37.5°	4.3
40°	2.4
42.5°	1.3
45°	0.7
47.5°	0.6
50°	0.6
52.5°	0.6
55°	0.6
57.5°	0.6
60°	0.4
62.5°	0.4
65°	0.4
67.5°	0.4
70°	0.2
72.5°	0.2
75°	0.2
77.5°	0.2
80°	0.2
82.5°	0.2
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)