

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1275484

Luminaire Tested: P3AS05R459835DE010 E3DL1H

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1275484
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-27)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS05R459835DE010 E3DL1H
Description: 3in Adjustable LED luminaire with, R45 optic, 3500K CCT AND, 98CRI , E3DL1H TRIM
Light Source: -
Ballast/Driver: -


Summary

Lumens per Lamp: N/A
Luminaire Lumens: 432.0 lumens
Efficiency: N/A
Efficacy: 60.0 lumens/watt
Spacing Criteria (0/90/45): 0.69 / 0.69 / 0.69
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 7.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1275484
CATALOG NUMBER: P3AS05R459835DE010 E3DL1H

Luminous Intensity Polar Plot





TEST NUMBER: P1275484
 CATALOG NUMBER: P3AS05R459835DE010 E3DL1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	114	111	109	107	111	109	107	105	105	103	102	101	100	99	98	97	96	94			94
2	109	104	100	97	106	102	99	96	99	96	94	96	94	92	93	91	90	88			88
3	104	98	93	89	102	96	92	88	94	90	87	91	88	86	89	86	84	83			83
4	99	92	87	83	97	91	86	82	89	85	81	87	83	80	85	82	79	78			78
5	94	87	81	77	93	86	81	77	84	80	76	82	79	76	81	78	75	74			74
6	90	82	76	73	89	81	76	72	80	75	72	78	74	71	77	74	71	70			70
7	86	78	72	68	85	77	72	68	76	71	68	75	71	67	74	70	67	66			66
8	83	74	68	65	82	73	68	64	72	68	64	71	67	64	70	67	64	62			62
9	79	70	65	61	78	70	65	61	69	64	61	68	64	61	67	63	61	59			59
10	76	67	62	58	75	67	62	58	66	61	58	65	61	58	65	61	58	57			57

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	162224
5°	158419
10°	145644
15°	123406
20°	95745
25°	66923
30°	42158
35°	24815
40°	14055
45°	6822
50°	2388
55°	1912
60°	1842
65°	1816
70°	1731
75°	1610
80°	1515
85°	1006

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 6822 cd/sqm



TEST NUMBER: P1275484
 CATALOG NUMBER: P3AS05R459835DE010 E3DL1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	66.6	15.4
10°-20°	149.3	34.6
20°-30°	126.7	29.3
30°-40°	60.5	14.0
40°-50°	18.2	4.2
50°-60°	4.6	1.1
60°-70°	3.5	0.8
70°-80°	2.0	0.5
80°-90°	0.6	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	342.6	79.3
0°-40°	403.1	93.3
0°-60°	425.9	98.6
0°-90°	432.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	432.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	740	
5°	720	67
15°	544	149
25°	277	127
35°	93	60
45°	22	18
55°	5	5
65°	4	3
75°	2	2
85°	0	1
90°	0	



TEST NUMBER: P1275484
CATALOG NUMBER: P3AS05R459835DE010 E3DL1H

CANDELA DISTRIBUTION (FULL):

0°	
0°	739.8
2.5°	735.2
5°	719.7
7.5°	693.1
10°	654.1
12.5°	602.3
15°	543.6
17.5°	478.3
20°	410.3
22.5°	341.1
25°	276.6
27.5°	217.9
30°	166.5
32.5°	125.2
35°	92.7
37.5°	68.4
40°	49.1
42.5°	34.0
45°	22.0
47.5°	12.4
50°	7.0
52.5°	5.4
55°	5.0
57.5°	4.6
60°	4.2
62.5°	3.9
65°	3.5
67.5°	3.1
70°	2.7
72.5°	2.3
75°	1.9
77.5°	1.5
80°	1.2
82.5°	0.8
85°	0.4
87.5°	0.4
90°	0.0

(END OF REPORT)