

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1275773

Luminaire Tested: P3AS09R359835DE010 E3DL1LI

Issue Date: 1/30/2026

Test Information

Test Method: LM-79-2019
Report Number: P1275773
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2601-647-19)
Test Lab: INNOVATION CENTER
Issue Date: 1/30/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS09R359835DE010 E3DL1LI
Description: 3in Adjustable LED luminaire with, R35 optic, 3500K CCT AND, 98CRI , E3DL1LI TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 600.0 lumens
Efficiency: N/A
Efficacy: 54.5 lumens/watt
Spacing Criteria (0/90/45): 0.58 / 0.58 / 0.58
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 11
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1275773

CATALOG NUMBER: P3AS09R359835DE010 E3DL1LI

Luminous Intensity Polar Plot



TEST NUMBER: P1275773

CATALOG NUMBER: P3AS09R359835DE010 E3DL1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	112	109	107	112	109	107	106	105	104	102		102	100	99		98
2	109	105	101	98	107	103	100	97	100	97	95		97	95	93		94
3	105	99	95	91	103	98	94	90	95	92	89		93	90	88		91
4	100	94	89	85	99	93	88	85	91	87	84		89	85	83		87
5	96	89	84	80	95	88	83	80	86	82	79		85	81	78		83
6	92	85	80	76	91	84	79	76	83	78	75		81	77	75		80
7	89	81	76	72	88	80	75	72	79	75	71		78	74	71		77
8	85	77	72	69	84	77	72	68	76	71	68		75	71	68		74
9	82	74	69	66	81	74	69	65	73	68	65		72	68	65		71
10	79	71	66	63	78	71	66	63	70	66	63		69	65	62		69

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	302607
5°	290820
10°	253391
15°	194099
20°	129861
25°	78561
30°	45096
35°	25217
40°	13397
45°	6915
50°	3309
55°	2600
60°	2500
65°	2075
70°	2180
75°	1949
80°	2147
85°	1510

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°

Vertical Angle: 45°

Luminance: 6915 cd/sqm

TEST NUMBER: P1275773

CATALOG NUMBER: P3AS09R359835DE010 E3DL1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	120.2	20.0
10°-20°	233.0	38.8
20°-30°	152.5	25.4
30°-40°	61.9	10.3
40°-50°	18.6	3.1
50°-60°	6.3	1.0
60°-70°	4.2	0.7
70°-80°	2.5	0.4
80°-90°	0.9	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	505.7	84.3
0°-40°	567.6	94.6
0°-60°	592.4	98.7
0°-90°	600.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	600.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1380	
5°	1321	120
15°	855	233
25°	325	153
35°	94	62
45°	22	19
55°	7	6
65°	4	4
75°	2	2
85°	1	1
90°	0	

TEST NUMBER: P1275773

CATALOG NUMBER: P3AS09R359835DE010 E3DL1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	1380.0
1°	1377.7
2°	1371.5
3°	1358.9
4°	1344.1
5°	1321.2
6°	1292.7
7°	1260.7
8°	1224.8
9°	1183.7
10°	1138.0
11°	1087.2
12°	1034.2
13°	974.8
14°	918.3
15°	855.0
17.5°	701.4
20°	556.5
22.5°	428.0
25°	324.7
27.5°	242.0
30°	178.1
32.5°	130.7
35°	94.2
37.5°	66.8
40°	46.8
42.5°	32.5
45°	22.3
47.5°	14.8
50°	9.7
52.5°	7.4
55°	6.8
57.5°	6.3
60°	5.7
62.5°	5.1
65°	4.0
67.5°	3.4
70°	3.4
72.5°	2.9
75°	2.3
77.5°	1.7
80°	1.7
82.5°	1.1
85°	0.6
87.5°	0.6



TEST NUMBER: P1275773

CATALOG NUMBER: P3AS09R359835DE010 E3DL1LI

CANDELA DISTRIBUTION (continued):



(END OF REPORT)