

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for
Cooper Lighting Solutions

Brand: IRiS

Report Number: P1281869

Luminaire Tested: P3AS05R50B2750DE010 E3D1H_3500K

Issue Date: 1/29/2026

Test Information

Test Method: LM-79-2019
Report Number: P1281869
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2501-338-13)
Test Lab: INNOVATION CENTER
Issue Date: 1/29/2026
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: IRiS
Catalog Number: P3AS05R50B2750DE010 E3D1H_3500K
Description: 3in Adjustable Boosted Cyan Tunable White LED luminaire with, R50 optic, 3500K CCT AND, 80CRI , E3D1H TRIM
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 558.0 lumens
Efficiency: N/A
Efficacy: 94.6 lumens/watt
Spacing Criteria (0/90/45): 0.82 / 0.82 / 0.77
Luminous Opening: Circular (Dia: 0.25' x H: 0')
CIE Type: Direct

Input Watts (W): 5.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT

TEST NUMBER: P1281869

CATALOG NUMBER: P3AS05R50B2750DE010 E3D1H_3500K

Luminous Intensity Polar Plot



TEST NUMBER: P1281869

CATALOG NUMBER: P3AS05R50B2750DE010 E3D1H_3500K

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10			0
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	112	109	107	112	110	108	106	105	104	102		102	101	99		98	97	97	95
2	109	105	101	98	107	103	100	97	100	97	95		97	95	93		94	93	91	90
3	105	99	95	91	103	98	94	90	95	92	89		93	90	88		91	88	86	85
4	100	94	89	85	99	92	88	85	90	87	84		88	85	83		87	84	82	80
5	96	89	84	80	94	88	83	79	86	82	79		84	81	78		83	80	77	76
6	92	84	79	75	91	83	78	75	82	78	74		81	77	74		79	76	73	72
7	88	80	75	71	87	79	74	71	78	74	70		77	73	70		76	72	70	68
8	84	76	71	67	83	76	71	67	75	70	67		74	69	66		73	69	66	65
9	81	73	67	64	80	72	67	64	71	67	63		70	66	63		70	66	63	62
10	78	69	64	61	77	69	64	61	68	64	60		67	63	60		67	63	60	59

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	195006
5°	189808
10°	181137
15°	163974
20°	141856
25°	116378
30°	66846
35°	20773
40°	5582
45°	1954
50°	478
55°	153
60°	88
65°	104
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
Vertical Angle: 45°
Luminance: 1954 cd/sqm

TEST NUMBER: P1281869

CATALOG NUMBER: P3AS05R50B2750DE010 E3D1H_3500K

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	80.8	14.5
10°-20°	200.1	35.9
20°-30°	210.4	37.7
30°-40°	60.2	10.8
40°-50°	5.9	1.1
50°-60°	0.5	0.1
60°-70°	0.2	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	491.3	88.0
0°-40°	551.5	98.8
0°-60°	557.8	100.0
0°-90°	558.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	558.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	889	
5°	862	81
15°	722	200
25°	481	210
35°	78	60
45°	6	6
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	

TEST NUMBER: P1281869

CATALOG NUMBER: P3AS05R50B2750DE010 E3D1H_3500K

CANDELA DISTRIBUTION (FULL):

0°	
0°	889.3
1°	887.9
2°	884.0
3°	878.2
4°	870.6
5°	862.3
6°	853.4
7°	844.0
8°	835.1
9°	824.9
10°	813.5
11°	800.3
12°	785.1
13°	766.2
14°	745.7
15°	722.3
16°	697.5
17°	673.5
18°	648.9
19°	627.2
20°	607.9
21°	589.4
22°	568.4
23°	544.2
24°	515.8
25°	481.0
26°	443.2
27°	401.0
28°	359.1
29°	313.8
30°	264.0
31°	217.3
32°	174.4
32.5°	155.7
33°	136.8
34°	104.9
35°	77.6
36°	56.9
37°	42.3
37.5°	36.6
38°	31.7
39°	24.6
40°	19.5
42.5°	11.0
45°	6.3



TEST NUMBER: P1281869

CATALOG NUMBER: P3AS05R50B2750DE010 E3D1H_3500K

CANDELA DISTRIBUTION (continued):

	0°
47.5°	3.5
50°	1.4
52.5°	0.6
55°	0.4
57.5°	0.4
60°	0.2
62.5°	0.2
65°	0.2
67.5°	0.2
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)